

1 LEVEL 1 BLDG B - MECHANICAL PLAN
M1.01B SCALE: 1/8" = 1'-0"

G - X KW WALL(SEE PLANS) HEATER QMARK AWH4404F OR EQUAL. EQUIPMENT BY

K --- DUCT UP INTO JOIST BAY, THEN DROP OUT TO SOFFIT AND ROUTE TO EXTERIOR. JOIST BAY TO BE LINED BY GC WITH SHEET ROCK TO MAINTAIN RATED

EXH DUCT UP THROUGH FIRE RATING AND INTO ATTIC, PROVIDE WITH FIRE DAMPER AT EACH PENETRATION OF THE RATED CEILING - DUCT BETWEEN FIRE DAMPERS IN THE

M - x by x INTAKE AND EXHAUST GRILLES FOR FUTURE TI SPACES, LOUVERS TO BE CAPPED AT INTERIOR FOR FUTURE CONNECTIONS - COORDINATE WITH SOFFIT/STORE FRONT SYSTEM. (SEE PLANS FOR SIZES, SEE ARCHITECTURAL FOR EXACT SIZES).

ALL DWELLING UNITS ARE VENTILATED BY MECHANICAL VENTILATION, ENERGY RECOVERY VENTILATORS RUN CONTINUOUSLY (SIZED PER

HALLWAYS ARE VENTILATED BY ENERGY RECOVERY VENTILATORS SIZED

SEE VENTILATION SCHEDULES FOR OTHER COMMON SPACES

KEY PLAN - (NTS)

ARCHITECTS

HACKER

555 SE MLK Jr. Blvd. Suite 501, Portland, OR 97214

homeforward

INC. WWW.MFIA-ENG.COM

EXPIRES: 31DEC23

CONTACT: MARK DENYER

3-15-22

REVISION NO.

TRUE PLAN NORTH

HOME FORWARD 5600 NE 42ND PORTLAND, OR 97218

PERMIT SET

MARCH 18, 2022

As indicated DRAWING TITLE

LEVEL 1 BUILDING B MECHANICAL FLOOR PLAN

SHEET NUMBER

M1.01B