



- GENERAL NOTES:**
1. CONTRACTOR TO COORDINATE PIPE ROUTING WITH OTHER DISCIPLINES.
- KEYED NOTES:**
1. FUTURE VAV BOX.
 2. 3/4" HWS/HWR CAPPED WITH SHUT-OFF VALVE FOR FUTURE.
 3. 1-1/4" HWS/HWR CAPPED WITH SHUT-OFF VALVE FOR FUTURE.
 4. CONNECT (N)3/4" HWS/HWR TO (E) MAINS.
 5. T/A SERIES BALANCE VALVE. SEE PIPING SCHEMATIC ON SHEET MP3.0 FOR GPM SETTING.
 6. T/A SERIES 794 DIFFERENTIAL PRESSURE CONTROLLER.

1 MECHANICAL SECOND FLOOR - ADDITION
 M2.2A 1/8"=1'-0"

