

KEYED NOTES:
1. REMOVE LOW RA GRILLE AND REINSTALL 6" ABOVE NEW FINISHED FLOOR ELEVATION.
2. REMOVE EXISTING RA GRILLE/SA DIFFUSER FOR INSTALLATION AT NEW RAISED CEILING. MODIFY EXISTING SHEETMETAL BRANCH DUCT TO DIFFUSER/GRILLE AS NECESSARY.
3. (E)SA DUCTWORK TO BE ENCLOSED IN NEW SOFFIT. (E)DIFFUSER TO BE REMOVED AND RE-INSTALLED AT BOTTOM SURFACE OF NEW SOFFIT.

City Of Bend Approval Stamp:

3	3/15/18	PLAN REVIEW COMMENTS
2	3/13/18	ADDENDUM 1
1	2/19/18	DISTRICT REVIEW COMMENTS
#	Date	Description
Revision Schedule		

PERMIT & CONSTRUCTION SET

PILOT BUTTE MIDDLE SCHOOL - BLDGS E&F

1501 NE Neff Road,
Bend OR 97701

BLRB architects

TACOMA	SPOKANE	PORTLAND	BEND
1250 Pacific Avenue Suite 200 Tacoma WA 98402 253.627.9399	505 W Riverside Suite 100 Spokane WA 99201 509.252.5980	1000 SW 5th Avenue Suite 400 Portland, OR 97204 503.555.0707	404 SW Columbia St Suite 100 Bend, OR 97702 541.330.6666
BLRB.com			


Drawing Title:

MECHANICAL DEMO
PLAN - BUILDING F

Date : 02.19.2018 Drawn By : TB

Revised Date : Project No. 17.34B

Stamp Sheet No.



MPIA
Consulting Engineers
6007 S.E. Ash St.
Portland, OR 97214
PH: (503) 234-0548
FAX: (503) 234-0677
WWW.MPIA-ENG.COM
CONTACT: TAKAKO BAKER

MD2.03

BLRB ARCHITECTS, P.S.