



- KEYED NOTES:
1. REMOVE & RE-INSTALL (E)12X48 LOW RA GRILLE @ 6" ABOVE NEW FLOOR ELEVATION. RE-BALANCE GRILLE TO 2400 CFM.
 2. RE-INSTALL (E)SA/RA GRILLES AT NEW CEILING HEIGHT AND BALANCE TO AIRFLOW SHOWN.
 3. EXTEND (E)SHEETMETAL DUCT TO NEW DIFFUSER LOCATION AND BALANCE TO AIRFLOW SHOWN.
 4. REMOVE & RE-INSTALL (E)12X6 LOW RA GRILLE @ 6" ABOVE NEW FLOOR ELEVATION. RE-BALANCE RA GRILLE TO 100 CFM.
 5. EXTEND DUCT TO BOTTOM SURFACE OF NEW SOFFIT AND RE-INSTALL (E) DIFFUSER. BALANCE SA GRILLE TO AIRFLOW SHOWN.

#	Date	Description
3	3/15/18	PLAN REVIEW COMMENTS
2	3/13/18	ADDENDUM 1
1	2/19/18	DISTRICT REVIEW COMMENTS

Revision Schedule

PERMIT & CONSTRUCTION SET

PILOT BUTTE MIDDLE SCHOOL - BLDGS E&F
1501 NE Neff Road,
Bend OR 97701

BLRB architects

TACOMA	SPOKANE	PORTLAND	BEND
1250 Pacific Avenue Suite 700 Tacoma WA 98402 252.027.5599	555 W Riverside Suite 500 Spokane WA 99201 509.352.5580	1000 SW 5th Avenue Suite 1000 Oregon 97204 503.551.0107	404 SW Gamma St Suite 100 Bend OR 97701 541.590.6696
BLRB.com			

Drawing Title:

MECHANICAL FLOOR PLAN - BUILDG F

Date :	02.19.2018	Drawn By :	TB
Revised Date :		Project No.	17.348
Stamp	Sheet No.		

M2.03

Consulting Engineers
2007 S.E. Ash St.
Portland, OR 97214
PHN: (503) 234-0548
FAX: (503) 234-0677
WWW.M2A-ENG.COM
CONTACT: TAKAKO BAKER

1798
JULY 25 1995
SCOTT W. MILLER
EXPIRES: 31 DEC 18

BLRB ARCHITECTS, P.S.