

- ① RELOCATE EXISTING LIGHTING FIXTURE AS SHOWN. EXTEND EXISTING BRANCH CIRCUIT TO NEW LOCATION AND RE-CONNECT.
- ② RELOCATE EXISTING RECEPTACLE AS SHOWN. EXTEND EXISTING BRANCH CIRCUIT TO NEW LOCATION AND RE-CONNECT.
- ③ CONNECT TO SPARE 20A/1P CIRCUIT BREAKER IN EXISTING PANEL.
- ④ DOOR CONTROLLER POWER SUPPLY CONNECTION. COORDINATE EXACT LOCATION WITH DOOR HARDWARE SPECIFICATIONS AND DOOR HARDWARE SUPPLIER.
- ⑤ EXISTING SWITCHES TO REMAIN.

1 ENLARGED FLOOR PLAN – ELECTRICAL  
E1.1 SCALE: 1/4" = 1'-0"

<h1 style="margin: 0;">B B T</h1>		<h2 style="margin: 0;">A R C H I T E C T S</h2>
<p style="margin: 0;">1160 nw Simpson Ave. - Suite 100 - Bend, Oregon 97702</p> <p style="margin: 0;">t. 541.382.5535   f. 541.389.0033</p>		

  

<h3 style="margin: 0;">Bend-La Pine Schools SECURITY UPGRADES</h3> <h3 style="margin: 0;">Pine Ridge Elementary School</h3>		<h3 style="margin: 0;">19840 Hollygrape Street</h3> <h3 style="margin: 0;">Bend, Oregon 97702</h3>
---	--	--

  

ISSUED:	DATE:
PERMIT SET / BID SET	02/14/18
CONFORMANCE SET	03/28/18
APR-11	06/08/18
AS-BUILT	09/04/18

  

JOB NUMBER:	1708
DRAWN BY:	CAW
CHECKED BY:	RLC

  

<p style="margin: 0;">SHEET TITLE</p> <p style="margin: 0;">ENLARGED FLOOR PLAN ELECTRICAL</p>
--

  

<p style="margin: 0;">SHEET NUMBER</p> <h1 style="margin: 0;">E1.1</h1>
---