



APPROX. 120° (TYP. OF 3)

TOP VIEW

NOTE: MATERIALS BASED ON MASON INDUSTRIES. SIZE MATERIALS BASED ON APPLICATION & MANUFACTURER REQUIREMENT.

54" MAX

SUPPORT STRUCTURE

MASON TYPE SCB ANCHORAGE

ROD COUPLING IF REQUIRED

MASON TYPE SRC SEISMIC ROD CLAMP IF REQUIRED

THREADED ROD

ROD STIFFENER ANGLE IF REQUIRED

PIPE CLAMP OR U-BOLT

TRAPEZE SUPPORT

SCBH ONLY SHOWN IN LATERAL DIRECTION FOR CLARITY. ADDITIONAL SCBHs ARE REQUIRED AS SHOWN IN PLAN VIEW BELOW

AIRCRAFT CABLE

MASON SCBH-SEISMIC CABLE BRACE HOOK OR SCB-4 AT LATERAL LOCATION WHEN REQUIRED.

TRANSVERSE

FOR PIPE SUPPORTED MORE THAN THAT IS 2-1/2" OR LARGER SUPPORT W/ ANY ONE PIPE

NOTE: MATERIALS BASED ON MASON BASED ON APPLICATION & MA

WALL EXTERIOR

SECURE TO WALL STUDS OR SOLID BLOCKING.

OAC-1 MANUFACTURE APPROVED WALL BRACKETS. ATTACH OAC-1 TO BRACKET BY MANUFACTURES RECOMMENDATIONS.

COMPRESSOR/CONDENSING UNIT

EXTERIOR PIPING W/ALUM COVER TO PIPE HOOD

SEE 8
M6.02

20 GA. STAINLESS STEEL CURB CAP

#12 SHEET METAL SCREW

UNISTRUT P1026

UNISTRUT P1100

UNISTRUT P1363C

1/4 x 1 1/2 SDS

UNISTRUT P1325

CANT STRIP

ROOF DECK

MIN. 18"

NO ANCHORS IN CURB CAP ALLOWED

REGISTERED PROFESSIONAL
ENGINEER
70996PE
Takako Baker
JULY 9, 2002
TAKAKO BAKER
EXPIRES: 12/31/17

BBT
ARCHITECTS

1160 sw Simpson Ave. - Suite 100 - Bend, Oregon 97702
t 541.382.5535 | f 541.389.8033

MEFA
INC. Consulting Engineers
2007 S.E. Ash St.
Portland, OR 97214
PHN: (503) 234-0548
FAX: (503) 234-0677
WWW.MFIA-ENG.COM
CONTACT: TAKAKO BAKER

WARM SPRINGS TRAVEL CENTER

Madras, OR

No.	Description	Date
1	Owner/CMGC Revisions	10/19/2016

Project Number	1519
Date	OCT. 19, 2016
Drawn By	TB
Checked By	JVB

MECHANICAL DETAILS

BID SET

M6.03

COPYRIGHT © 6/1/2016 7:55:28 AM ARCHITECTS