



PLAN NOTES

- ① CONNECT TO UNSWITCHED LEG OF EXISTING EMERGENCY LIGHTING BRANCH CIRCUIT (BLSL1-3).
- ② CONNECT TO UNSWITCHED LEG OF EXISTING EMERGENCY LIGHTING BRANCH CIRCUIT (BLSL1-5).
- ③ RELOCATE EXISTING LIGHT FIXTURE TO BELOW MECHANICAL / DUCTWORK.
- ④ POWER PACK / RELAY FOR CONTROL OF EXHAUST FAN EF-1. RELAY TO BE ENABLED ANYTIME KITCHEN LIGHTS ARE TURNED ON.

GENERAL NOTES

- A. DAISY CHAIN CAT-5 DATA CABLE FROM "N-LIGHT" CONTROL DEVICES TO ALL "N-LIGHT" ENABLED LIGHTING FIXTURES IN CONTROL ZONES INDICATED. INSTALL DATA CABLE IN CONDUIT WHERE NOT CONCEALED.

1 BASEMENT LIGHTING PLAN
E2.1 SCALE: 1/8" = 1'-0"

Consulting Engineers
2007 S.E. Ash St.
Portland, OR 97214
PHN: (503) 234-0548
FAX: (503) 234-0877
WWW.MFIA-ENG.COM
CONTACT: CHRIS WINER



BLUE ROOM ARCHITECTURE & DESIGN, P.S.

HISTORIC SALTESE SCHOOLHOUSE
BOX 628, VERADALE, WA 99037
(509) 456-6800

www.brdstudio.com

CIVIL ENGINEER

FOOD SERVICE CONSULTANT
DK DESIGN, INC.
15040 NE 95TH ST., #101
REDMOND, WA 98052
(425) 881-8622


MECHANICAL ENGINEER
MFIA INC CONSULTING ENGINEERS
2007 SE ASH STREET
PORTLAND, OR 97214
(503) 234-0548

ELECTRICAL ENGINEER
MFIA INC CONSULTING ENGINEERS
2007 SE ASH STREET
PORTLAND, OR 97214
(503) 234-0548



THIS PROJECT INCLUDES THE INTERIOR REMODEL OF AN EXISTING CRITICAL ACCESS HOSPITAL FACILITY THAT IS TO REMAIN OPERATIONAL AT ALL TIMES. CONTRACTOR BIDS SHALL BE BASED ON VERIFICATION OF EXISTING ONSITE CONDITIONS. UNINTERRUPTED ESSENTIAL HEALTHCARE SERVICES DURING THE CONSTRUCTION PERIOD. ONGOING COORDINATION OF ALL RELATED TRADES FOR CURRENT CODE COMPLIANCE, PATIENT SAFETY, JURISDICTIONAL REVIEW, SYSTEM PERFORMANCE AND UNFORESEEN CLINICAL DISRUPTION(S).

INTERIOR REMODEL FOR:



211 SKYLINE DRIVE
WHITE SALMON, WASHINGTON 98612

PROJECT NUMBER: 180012
DATE: 2/14/2018
DRAWN: CW
REVISIONS:

BASEMENT
LIGHTING
PLAN

E2.1