



- A. FOR VOICE/DATA OUTLETS ON INTERIOR WALLS PROVIDE A SINGLE GANG MUD-RING WITH A 1" CONDUIT FROM THE TOP OF THE MUD-RING TO ACCESSIBLE CEILING SPACE. TERMINATE CONDUIT WITH END CONNECTORS AND THREAD ON PLASTIC BUSHING FOR CABLE PROTECTION. OUTLET SHALL BE AT THE SAME HEIGHT AS ADJACENT POWER OUTLET AND LESS THAN 18" SEPARATION. COORDINATE WITH ELECTRICAL. ON EXTERIOR WALLS UTILIZE AN AIRTIGHT BOX BY AIRFOIL INC. OR APPROVED EQUAL.
- B. COORDINATE ALL DEVICE LOCATIONS WITH LATEST ARCHITECTURAL INTERIOR ELEVATIONS TO VERIFY DEVICES WILL NOT BE OBSTRUCTED.
- C. PROVIDE PULL STRING IN ALL CONDUITS FOR LATER USE.
- D. ALL PENETRATIONS THROUGH FIREWALLS WILL NEED FIRESTOP OF THE APPROPRIATE RATING.

1. COMBINATION PHOTOELECTRIC WITH CO DETECTORS CAN BE USED.
2. ROUGH-IN FOR OWNER FURNISHED, OWNER INSTALLED CCTV SYSTEM.
3. AREA-OF-REFUGE TWO WAY COMMUNICATION PANEL.

**MFI**  
**INC.** Consulting Engineers  
2007 S.E. Ash St.  
Portland, OR 97214  
PHN: (503) 234-0544  
FAX: (503) 234-0677  
WWW.MFI-ENG.COM  
CONTACT: GARY ADOVNIK

**5020 N INTERSTATE**  
PROUD GROUND / HABITAT FOR HUMANITY  
5020 N INTERSTATE AVE.  
PORTLAND, OR 97217

TELCOM PLAN  
SIXTH FLOOR

PROJECT NO.  
17020

10.14.19

REVISIONS:

**CARLETON HART ARCHITECTURE P.C.**  
2830 sw 10th avenue | 200 portland oregon 97206  
503 243 2262 | [www.carltonhart.com](http://www.carltonhart.com)

T3.06