


- GENERAL NOTES:**
1. FIXTURES WITHOUT LABELS ARE EXISTING FIXTURES. REFER TO DEMO PLAN FOR FURTHER DETAILS.
 2. FIXTURE HEIGHTS SHOWN ARE MEASURED TO THE BOTTOM OF FIXTURE ABOVE FINISHED FLOOR.
 3. PROVIDE LABELS TO LIGHT SWITCHES AS SHOWN.
 4. PROVIDE UN-SWITCHED CIRCUIT TO FIXTURE WITH EMERGENCY BATTERY PACK.
 5. TYPE 'L1' FIXTURES TO BE MOUNTED RECESSED TO SOFFIT. FIXTURES SHALL BE ON SWITCHED CIRCUIT 'b'.
 6. LOWER CASE LETTER REPRESENTS SWITCHED CIRCUIT. FIXTURES ARE TO BE WIRED TO CORRESPONDING SWITCHES AS SHOWN.

SHEET NOTES:

- 1 PROVIDE MOUNTING ON CEILING.
- 2 MOUNT FIXTURE TO WITHIN 12" FROM 18" BEAM.
- 3 MOUNT FIXTURE AT LEAST 1.6' FROM 18" BEAM.
- 4 PENDANT LIGHTS. STEM MOUNTED AT 7' A.F.F FROM CEILING.
- 5 PROVIDE PHOTOCELL, INTERMETIC, EK4236S OR EQUAL AT 11' A.F.F PER MANUFACTURER REQUIREMENT. IT SHALL BE WIRED TO EXTERIOR FIXTURES FOR DUSK TO DAWN OPERATION. MATCH VOLTAGE RATING TO THAT OF FIXTURES.

- 6 FIXTURES TO BE LOCATED AT CENTER OF PARTITION WALLS.



1 LIGHTING PLAN
E2.1 SCALE: 1/8" = 1/0"

LEGEND:

- OC = OCCUPANCY SENSOR
- PC = PHOTOCELL
- D = DIMMING

RECORD DRAWING:
THIS DRAWING HAS BEEN UPDATED TO REFLECT CHANGES MADE DURING CONSTRUCTION BASED UPON INFORMATION FURNISHED TO THE ENGINEER BY THE INSTALLATION CONTRACTOR. NO WARRANTY, EITHER EXPRESSED OR IMPLIED, IS GIVEN BY THE ENGINEER AS TO THE ACCURACY AND/OR COMPLETENESS OF THIS INFORMATION.

AS-BUILT PREPARED 1.22.2020

FOSTER SHELTER
6144 SE FOSTER RD, PORTLAND, OREGON 97206
CLIENT: MULTNOMAH COUNTY



PROJECT NO.	ISSUE DATE
17-0918	05.04.2018
REVISIONS	CHECKSHEET 5.23.2018
	OWNER CHANGES 2.26.2019

SHEET

ELECTRICAL LIGHTING PLAN
E2.1

PERMIT SET
© MERRYMAN BARNES ARCHITECTS, INC.