


GENERAL NOTES:

1. DEMOLISH EXISTING ELECTRICAL EQUIPMENT IN ELECTRICAL ROOM. COORDINATE WITH PGE TO REMOVE EXISTING METER. SEE DEMO PLAN.
2. DISCONNECT POWER TO ALL EXISTING RECEPTACLES. RECONNECT POWER TO WHERE SHOWN.
3. DISCONNECT POWER TO ALL EXISTING LIGHT FIXTURES. RELOCATE AND RE-CIRCUIT PER E2.1. SEE E0.2 FOR EXISTING FIXTURES.
4. PROVIDE METERING EQUIPMENT PER UTILITY REQUIREMENT.

SHEET NOTES:

- 1 RETROFIT EXISTING RECEPTACLES WITH GFI RATED RECEPTACLES.
- 2 REUSE EXISTING RECEPTACLE.
- 3 STACKED WASHER/DRYER.
- 4 PROVIDE A NEMA 6-30 RECEPTACLE AT 30"+ ABOVE FINISHED FLOOR FOR EACH DRYER.
- 5 PROVIDE A NEMA 5-15 RECEPTACLE AT 30"+ ABOVE FINISHED FLOOR FOR EACH WASHER.
- 6 PROVIDE A WATER HEATER CIRCUIT DISCONNECT FOR A SINGLE POINT CONNECTION PER SECTION 223000.
- 7 PROVIDE NEMA 5-20R RECEPTACLE DEDICATED FOR COPIER MACHINE. PROVIDE LABEL AT RECEPTACLE.

- 8 PROVIDE NEMA 5-20R RECEPTACLE DEDICATED FOR IT EQUIPMENT.
- 9 PROVIDE RECEPTACLES IN FLOOR BOX SPECIFIED IN 'T' DRAWING FOR FUTURE FRONT DESK. COORDINATE LOCATION WITH ARCHITECT.
- 10 PROVIDE A NEW QUAD TO REPLACE EXISTING.



1 ELECTRICAL POWER PLAN
E3.1 SCALE: 1/8" = 1'-0"

LEGEND:

TR = TAMPER RESISTANT

RECORD DRAWING:
THIS DRAWING HAS BEEN UPDATED TO REFLECT CHANGES MADE DURING CONSTRUCTION BASED UPON INFORMATION FURNISHED TO THE ENGINEER BY THE INSTALLATION CONTRACTOR. NO WARRANTY, EITHER EXPRESSED OR IMPLIED, IS GIVEN BY THE ENGINEER AS TO THE ACCURACY AND/OR COMPLETENESS OF THIS INFORMATION.

AS-BUILT PREPARED 1.22.2020

FOSTER SHELTER

6144 SE FOSTER RD, PORTLAND, OREGON 97206
CLIENT: MULTNOMAH COUNTY



MERRYMAN BARNES ARCHITECTS 4713 N ALBINA AVE, SUITE 304 PORTLAND, OREGON 97217 P: 503.222.3793

| | |
|-------------------------|--------------------------|
| PROJECT NO. 17-0918 | ISSUE DATE 05.04.2018 |
| REVISIONS | |
| CHECKSHEET 5.23.2018 | |
| OWNER CHANGES 2.26.2019 | |

SHEET

ELECTRICAL POWER PLAN
E3.1

PERMIT SET
© MERRYMAN BARNES ARCHITECTS, INC.

2/27/2020 12:35:59 PM