

ELECTRICAL SYMBOL LIST

LIGHTING SYMBOLS

	LIGHT FIXTURE, RECESSED
	LIGHT FIXTURE, RECESSED - EMERGENCY
	LIGHT FIXTURE, SURFACE MOUNT
	LIGHT FIXTURE, SURFACE MOUNT - EMERGENCY
	LIGHT FIXTURE, STRIP
	LIGHT FIXTURE, STRIP - EMERGENCY
	DOWNLIGHT FIXTURE, RECESSED
	DOWNLIGHT FIXTURE, RECESSED, WALLWASH
	DOWNLIGHT FIXTURE, RECESSED - EMERGENCY
	LIGHT FIXTURE, WALL MOUNT
	LIGHT FIXTURE, CEILING MOUNT
	RECESSED LIGHT FIXTURE, WALL MOUNT
	LIGHT FIXTURE, WALL MOUNT
	LIGHT FIXTURE, WALL SCONCE
	LIGHT FIXTURE, TRACK W/ HEADS AS SHOWN ON PLAN
	EXIT SIGN, UNIVERSAL MOUNT, W/ DIRECTIONAL ARROW
	EXIT SIGN, WALL MOUNT, +8'-0" A.F.F.
	EMERGENCY LIGHT W/ BATTERY PACK, +8'-0" A.F.F.
	FLOOD LIGHT
	AREA LUMINAIRE
	AREA LUMINAIRE W/STANDBY LAMP
	AREA LUMINAIRE, WALL MOUNT
	AREA LUMINAIRE, POLE MOUNT

SWITCH SYMBOLS

	SWITCH, SPST +48" A.F.F.
	SWITCH, DPST +48" A.F.F.
	SWITCH, 3-WAY +48" A.F.F.
	SWITCH, 4-WAY +48" A.F.F.
	SWITCH, DIMMER +48" A.F.F.
	SWITCH, SPST, W/PILOT LIGHT +48" A.F.F.
	SWITCH, KEY-OPERATED +48" A.F.F.
	SWITCH, TIMED +48" A.F.F.
	PHOTOCELL CONTROL
	OCCUPANCY SENSOR CONTROL

SIGNAL SYMBOLS

	TELEPHONE OUTLET +18" A.F.F.
	DATA OUTLET +18" A.F.F.
	DATA/TELEPHONE OUTLET +18" A.F.F.
	CLOCK
	SIGNAL BELL
	VISUAL ALARM SIGNAL (COLOR AS INDICATED ON PLAN)
	P.A. SPEAKER
	CATV OUTLET (LOCATE AS SHOWN ON PLANS)

FIRE ALARM SYMBOLS

	FIRE ALARM MANUAL PULL STATION, +48" A.F.F.
	MAGNETIC DOOR HOLDER
	SMOKE DETECTOR, W/AUX. CONTACTS
	SMOKE/FIRE DAMPER
	SMOKE DETECTOR, DUCT, IONIZATION TYPE W/SAMPLING TUBE
	SMOKE DETECTOR, IONIZATION TYPE
	SMOKE DETECTOR, PHOTO TYPE
	HEAT DETECTOR, RATE-OF-RISE OR FIXED TEMP.
	FIRE MAIN FLOW DETECTION SWITCH
	FIRE MAIN TAMPER DETECTION SWITCH
	FIRE ALARM BELL, +80" A.F.F.
	FIRE ALARM HORN, +80" A.F.F.
	FIRE ALARM HORN/STROBE, +80" A.F.F.
	FIRE ALARM STROBE, +80" A.F.F.

POWER SYMBOLS

	RECEPTACLE, DUPLEX +18" A.F.F.
	RECEPTACLE, QUAD +18" A.F.F.
	RECEPTACLE, DUPLEX +6" ABV COUNTER
	RECEPTACLE, DUPLEX +18" A.F.F. (ONE OUTLET SWITCHED)
	RECEPTACLE, DUPLEX +18" A.F.F. (BOTH OUTLETS SWITCHED)
	RECEPTACLE, DUPLEX, PEDESTAL MOUNT
	RECEPTACLE, DUPLEX, FLUSH FLOOR MOUNT
	RECEPTACLE, SPECIAL (COORDINATE WITH EQUIPMENT SERVED)
	RELAY
	TIME CLOCK CONTROL
	PUSHBUTTON STATION
	JUNCTION BOX
	THERMOSTAT
	TRANSFORMER
	DISCONNECT, NON-FUSED
	DISCONNECT, FUSED
	ELECTRICAL CONNECTION
	ELECTRICAL CONNECTION, SINGLE MOTOR
	ELECTRICAL CONNECTION, MULTI-MOTOR
	ELECTRICAL DISTRIBUTION PANEL, RECESSED
	ELECTRICAL DISTRIBUTION PANEL, SURFACE
	MISCELLANEOUS PANEL, RECESSED
	MISCELLANEOUS PANEL, SURFACE
	FLUSH FLOOR BOX (W/ DEVICES AS SHOWN ON PLAN)

WIRING SYMBOLS

	PANEL & CIRCUIT NUMBER
	HOMERUN TO PANEL
	CONDUCTOR SIZE (IF OTHER THAN #12)
	PHASE CONDUCTOR
	NEUTRAL CONDUCTOR
	GROUND CONDUCTOR
	CONCEALED CONDUIT
	CONDUIT SIZE
	CONDUIT (UNDER SLAB OR FLOOR)
	FLEXIBLE CONNECTION
	CONDUIT, STUBBED & CAPPED

NOTATIONS

	DRAWING NOTE
	DETAIL REFERENCE: TOP=DETAIL NO., BOTTOM=SHEET NO.
	MECHANICAL EQUIPMENT MARK NO. (SEE EQUIPMENT SCHEDULE)
	EQUIPMENT NO. (SEE EQUIPMENT SCHEDULE)

	NORMAL POWER CIRCUIT LINETYPE
	EMERGENCY POWER CIRCUIT LINETYPE
	EXISTING POWER CIRCUIT LINETYPE

ONE-LINE DIAGRAM SYMBOLS


	ELECTRICAL DISTRIBUTION PANELBOARD (MLO)
	ELECTRICAL DISTRIBUTION PANELBOARD (MCB)
	SUB-FEED CIRCUIT BREAKER
	CIRCUIT BREAKER (TRIP RATING & POLES AS INDICATED ON PLAN)
	MAIN SWITCH (RATING & POLES AS INDICATED ON PLAN)
	FUSE (RATING & CLASS AS INDICATED ON PLAN)
	TRANSFER SWITCH (MANUAL OR AUTOMATIC)
	GENERATOR (RATING AS INDICATED ON PLAN)
	TRANSFORMER (RATING AS INDICATED ON PLAN)
	FUSE (RATING & CLASS AS INDICATED ON PLAN)
	GROUND SYSTEM (SIZE AS INDICATED ON PLAN)
	WATER PIPE GROUND ELECTRODE
	TRANSIENT VOLTAGE SURGE SUPPRESSOR
	UTILITY METER & METER BASE
	UTILITY METER CURRENT TRANSFORMER
	FEEDER NO. (SEE FEEDER SCHEDULE)

ABBREVIATIONS

A'	LIGHT FIXTURE TYPE (SEE FIXTURE LIST)	I.G.	ISOLATED GROUND
A.F.F.	ABOVE FINISHED FLOOR	LCP	LIGHTING CONTROL PANEL
A.F.G.	ABOVE FINAL GRADE	MCB	MAIN CIRCUIT BREAKER
A.F.I.	ARC FAULT INTERRUPTER	MLO	MAIN LUGS ONLY
A.T.S.	TRANSFER SWITCH, AUTOMATIC	N.I.C.	NOT IN CONTRACT
C	CONDUIT	N.L.	NIGHT LIGHT
C.O.	CONDUIT ONLY	P	POLE
CATV	CABLE TELEVISION	PC	PARTIAL CIRCUIT
CB	CIRCUIT BREAKER	PH	PHASE
CCTV	CLOSED CIRCUIT TELEVISION	R.T.U.	REMOTE TELEMETRY UNIT
C.T.	CURRENT TRANSFORMER	T.V.S.S.	TRANSIENT VOLTAGE SURGE SUPPRESSOR
(E)	EXISTING	U.G.	UNDERGROUND
FACP	FIRE ALARM CONTROL PANEL	U.O.N.	UNLESS OTHERWISE NOTED
G.F.I.	GROUND FAULT INTERRUPTER	VFD	VARIABLE FREQUENCY DRIVE
GND	GROUND	W	WIRE
HP	HORSEPOWER	W.G.	WIRE GUARD
		W.P.	WEATHERPROOF

NOTE: SOME OF THE SYMBOLS AND ABBREVIATIONS ON THIS LIST MAY NOT APPLY TO THIS PROJECT.

MFA Consulting Engineers
2007 S.E. Ash St.
Portland, OR 97214
PHN: (503) 234-0548
FAX: (503) 234-0677
INC. WWW.MFA-ENG.COM
CONTACT: DENISE TAYLOR



CARLETON HART ARCHITECTURE P.C.
830 sw 10th avenue #200 portlandoregon 97205
503 243 2252
www.carletonhart.com

SUSAN EMMONS - NORTH BUILDING
680 NW 18TH AVENUE,
PORTLAND, OR

NORTHWEST HOUSING ALTERNATIVES


CONFORMANCE SET

ELECTRICAL
LEGEND

PROJECT NO.
17004
05/28/2021

REVISIONS:

E1.00




GENERAL POWER NOTES:

- A. ALL PLANS ARE CONSIDERED DIAGRAMMATICAL. THEREFORE ALL EQUIPMENT SIZES AND DEVICE LOCATIONS ARE APPROXIMATE AND SUBJECT TO FIELD CONDITIONS AND PRODUCT APPROVAL.
- B. ELECTRICAL SERVICE ENTRANCE EQUIPMENT DESIGN IS BASED ON SIEMENS PRODUCTS. ACTUAL PRODUCTS USED MAY DIFFER IN SIZE AND CONFIGURATION AND SHALL BE NOTED IN FINAL PROJECT DOCUMENTS.
- C. COORDINATE WITH LOCAL UTILITY PROVIDER FOR EXACT SERVICE CONDUIT AND CONDUCTORS REQUIREMENTS.
- D. ALL UTILITY WORK SHALL BE DONE IN ACCORDANCE WITH PGE ELECTRICAL SERVICE REQUIREMENTS.
- E. U.G. PRIMARY FEEDER SHALL HAVE A MINIMUM 48 INCH BURY.
- F. U.G. SECONDARY FEEDER SHALL HAVE A MINIMUM 36 INCH BURY.
- G. REFER TO SHEET E1.11 FOR TYPICAL FEEDER SCHEDULE.
- H. SECONDARY CONDUIT SWEEPS SHALL BE MINIMUM 60 INCH RADIUS WITH A MINIMUM OR 7'-0" STRAIGHT CONDUIT RUN BETWEEN SWEEPS.
- I. LOCATION AND INSTALLATION OF THE PRIMARY AND SECONDARY CONDUITS, TRANSFORMER, ETC. SHALL BE PROVIDED PER PGE ELECTRICAL SERVICE REQUIREMENTS.
- J. REFER TO SHEET E3.01 FOR ELECTRICAL ROOM EQUIPMENT LAYOUT.

PGE REQUIREMENTS

1. CUSTOMER TO PROVIDE ALL TRENCHING AND BACKFILLING. TRENCH TO BE 36 INCHES DEEP AND 30 INCHES WIDE, MEASURED FROM FINAL GRADE.
2. ALL PGE CONDUCTORS TO BE INSTALLED IN GREY SCHEDULE 40, ELECTRICAL GRADE, PVC CONDUIT WITH NYLON PULL STRINGS (MIN 500 LBS. TEST). PGE TO DETERMINE THE SIZE AND NUMBER OF CONDUITS REQUIRED. ALL ELBOWS TO BE 36 INCH (MIN) RADIUS. ALL BENDS MAY BE FACTORY MADE. IF MORE THAN 270 DEGREES OF BENDS OR IF RUN IS LONGER THAN 150 FEET, BENDS MUST BE RIGID STEEL.
3. CONSULT WITH PGE REPRESENTATIVE 2 WEEKS BEFORE STARTING MAIN POWER TRENCHING FOR A PRECONSTRUCTION CONFERENCE. INCLUDED IN THIS CONFERENCE WILL BE EXCAVATOR, PGE, TELCO, CATV, AND GAS.
4. CONTRACTOR TO LOCATE ALL UNDERGROUND UTILITIES BEFORE TRENCHING. COORDINATE WITH CIVIL.

MFA Consulting Engineers
2007 S.E. Ash St.
Portland, OR 97214
PHN: (503) 234-0648
FAX: (503) 234-0677
INC. WWW.MFA-ENG.COM
CONTACT: DENISE TAYLOR




CARLETON HART ARCHITECTURE P.C.
830 sw 10th avenue #200 portlandoregon 97205
503 243 2252
www.carletonhart.com

SUSAN EMMONS - NORTH BUILDING
680 NW 18TH AVENUE,
PORTLAND, OR
NORTHWEST HOUSING ALTERNATIVES
CONFORMANCE SET


ELECTRICAL
SITE PLAN

PROJECT NO.
17004
05/28/2021

REVISIONS: A



1 SITE PLAN - NORTH BUILDING
E1.01 SCALE: 1/8" = 1'-0"



Susan Emmons - North Building							
LOAD SUMMARY - MAIN PANEL 'MDP'							
4/27/2021							
LOAD:	LIGHTS	RECEPT	HEAT	KITCHEN	EQUIP	MOTORS	MISC
Panel H1 (House Loads)	8,320	17,340		14,700	3,600		
Panel M1/M2 (Equip. Loads)	0	720	6,500	0	24,000	20,071	38,460
Panel L1 (Laundry Equip)					23,300		
Panel E1 (Gen. Set) (incl. Elev. #1)	625				2,000	43,476	42,500
Elevator #2						42,500	
MC1 (Tenant Meters)							191,000
MC2 (Tenant Meters)							232,000
MC3 (Tenant Meters)							225,000
SUBTOTAL	8,945	18,060	6,500	14,700	52,900	106,047	688,460
X-FACTOR	1.25	1 + .5	1	0.65	1	1	0.25
CODE LOAD:	11,181	14,030	6,500	9,555	52,900	106,047	688,460

CONN LOAD:	8941 KVA
VOLTS:	208 3ph
TOTAL CALC:	897 KVA
CALC AMPS:	2491 AMPS

ONE-LINE GENERAL NOTES:

- COORDINATE ALL WORK ASSOCIATED WITH ELECTRIC SERVICE WITH LOCAL UTILITY. PROVIDE ALL CONDUIT, GROUNDING, TRANSFORMER VAULT/PAD, ETC., IN ACCORDANCE WITH SERVING UTILITY REQUIREMENTS.
- COORDINATE METERING REQUIREMENTS WITH UTILITY.
- FOR LOAD CENTER FEEDER LENGTHS GREATER THAN 145'-0" FROM METER CENTER, INCREASE WIRE SIZE ONE SIZE UP FOR VOLTAGE DROP.
- PER NEC 240.87, THE ELECTRICAL CONTRACTOR SHALL PROVIDE DOCUMENTATION FOR ARC ENERGY REDUCTION DEVICE(S) FOR CIRCUIT BREAKERS 1200A OR GREATER. CONTRACTOR SHALL PROVIDE AN ENERGY-REDUCING ACTIVE FLASH MITIGATION SYSTEM OR OTHER METHOD APPROVED BY THE NEC.
- ASME A17.1, SECTION 2.27.2.1 THROUGH 5 STATES THAT IF THE EMERGENCY OR STANDBY POWER SYSTEM IS NOT CAPABLE OF OPERATING ALL ELEVATORS SIMULTANEOUSLY, THEN A SELECTOR SWITCH WILL NEED TO BE INSTALLED TO PROVIDE AUTOMATIC SELECTION BETWEEN THE TWO ELEVATOR CARS IN THE EVENT OF A POWER OUTAGE.
- ELEVATOR MANUFACTURER SHALL VERIFY THAT THE ELEVATOR WILL BE SUPPLIED WITH A KEY SWITCH TO OPERATE AND SELECT THE ELEVATOR CARS ON EMERGENCY POWER, AND THAT THE CARS WILL OPERATE IN SEQUENCE. THIS IS UNDERSTOOD TO MEAN THAT ONLY ONE CAR AT A TIME WILL OPERATE ON EMERGENCY POWER AND NOT SIMULTANEOUSLY, THUS PROVING THE 60KW GENERATOR TO BE ADEQUATE TO SUPPORT THE CODE REQUIREMENT FOR EMERGENCY POWER TO A MINIMUM OF ONE ELEVATOR FOR EGRESS IN THE EVENT OF A POWER OUTAGE.

ONE-LINE NOTES:

- NATURAL GAS GENERATOR TO OPERATE ONLY ONE ELEVATOR IN THE EVENT OF A POWER OUTAGE. VERIFY ELEVATOR ELECTRICAL REQUIREMENTS AND CONSULT GENERATOR PROVIDER FOR PROPER SIZING BASED ON STANDBY POWER LOAD. REFER TO PANEL E1 FOR CIRCUITING INFORMATION.
- PROVIDE GROUND FOR SEPARATELY DERIVED SYSTEM PER NEC.
- PROVIDE ELECTRONIC TRIP CIRCUIT BREAKER. EXACT BREAKER TYPE, SETTINGS, ETC. TO BE VERIFIED AND AS DETERMINED BY SELECTIVE COORDINATION STUDY AS PERFORMED BY THE ELECTRICAL DISTRIBUTION EQUIPMENT MANUFACTURER.
- COORDINATE INSTALLATION OF OUTPUT BREAKER WITH GENERATOR MANUFACTURER TO SELECTIVELY COORDINATE WITH POWER STUDY RECOMMENDATIONS.
- THE STANDBY POWER SYSTEM SHALL MEET ALL REQUIREMENTS OF NFPA 110 AND NEC 700. CONTRACTOR SHALL BE AWARE THAT MFIA HAS ATTEMPTED TO INDICATE EQUIPMENT AND SIZES THAT WILL SELECTIVELY COORDINATE, BUT WILL NOT BE KNOWN UNTIL ELECTRICAL EQUIPMENT MANUFACTURER PERFORMS THE REQUIRED POWER STUDIES AS SPECIFIED IN 26 05 73. CHANGES MAY BE NECESSARY AFTER THE BID.

Consulting Engineers
2007 S.E. Ash St.
Portland, OR 97214
PHN: (503) 234-0648
FAX: (503) 234-0677
WWW.MFIA-ENG.COM
CONTACT: DENISE TAYLOR



CARLETON HART ARCHITECTURE P.C.
830 SW 10th Avenue #200 Portland, OR 97205
503 243 2252
www.carletonhart.com

SUSAN EMMONS - NORTH BUILDING
680 NW 18TH AVENUE,
PORTLAND, OR
NORTHWEST HOUSING ALTERNATIVES
CONFORMANCE SET

ELECTRICAL
ONE-LINE DIAGRAM
PROJECT NO.
17004
05/28/2021

REVISIONS: A

E1.11

MFA PANEL SCHEDULE													
panel		mounting		location		connected load amps							
H1 (House Loads)		SURFACE		ELECT RM									
120/208V (SCCR: 42KAIC)		phase		bus & main		calculated load amps							
		3	200A	MLO									
service	va	a/p	no.	a b c	no.	a/p	va	service	va	a/p	no.	a b c	no.
1 LIGHTS - BLDG EXTERIOR	100	20/1	1	*	2	20/1	1260	RECEPTACLES - 1ST FLR					
1 LIGHTS - STAIR 1	240	20/1	3	*	4	20/1	1260	RECEPTACLES - 1ST FLR					
1 LIGHTS - STAIR 2	240	20/1	5	*	6	20/1	1080	RECEPTACLES - 2ND FLR					
1 LTS - FLRS 1 CORR (EGRESS)	435	20/1	7	*	8	20/1	1080	RECEPTACLES - 2ND FLR					
1 LTS - FLRS 2 CORR (EGRESS)	435	20/1	9	*	10	20/1	1080	RECEPTACLES - 2ND FLR					
1 LTS - FLRS 1&2 CORRIDOR	870	20/1	11	*	12	20/1	1080	RECEPTACLES - 2ND FLR					
1 LTS - FLRS 1&2	840	20/1	13	*	14	20/1	1080	RECEPTACLES - 3RD FLR					
1 LTS - FLRS 3 CORR (EGRESS)	435	20/1	15	*	16	20/1	1080	RECEPTACLES - 3RD FLR					
1 LTS - FLRS 4 CORR (EGRESS)	435	20/1	17	*	18	20/1	1080	RECEPTACLES - 4TH FLR					
1 LTS - FLRS 3&4 CORRIDOR	870	20/1	19	*	20	20/1	1080	RECEPTACLES - 4TH FLR					
1 LTS - FLRS 3,4,5,6	1680	20/1	21	*	22	20/1	1080	RECEPTACLES - 5TH FLR					
1 LTS - FLRS 5 CORR (EGRESS)	435	20/1	23	*	24	20/1	1080	RECEPTACLES - 5TH FLR					
1 LTS - FLRS 6 CORR (EGRESS)	435	20/1	25	*	26	20/1	900	RECEPTACLES - 6TH FLR					
1 LTS - FLRS 5&6 CORRIDOR	870	20/1	27	*	28	20/1	900	RECEPTACLES - 6TH FLR					
5 INVERTER INV-1	600	20/1	29	*	30	20/1	500	ELEV MACH RM RECEPT					
5 INVERTER INV-2	600	20/1	31	*	32	20/1	720	RECEPTACLES - MAIL ROOM					
5 INVERTER INV-3	600	20/1	33	*	34	20/1	1500	HOOD/MICRO					
5 INVERTER INV-4	600	20/1	35	*	36	50/2	6000	RANGE					
5 INVERTER INV-5	600	20/1	37	*	38	*	6000	*					
5 INVERTER INV-6	600	20/1	39	*	40	20/1	1200	FRIDGE					
2 ELEV. PIT LTS & RECEPTS	500	20/1	41	*	42	20/1	500	RECEPT - AMENITY KITCHEN					
Phase A		16000 VA						line-line voltage					
Phase B		12960 VA											
Phase C		15000 VA											
Total Connected		43960 VA											
load code:		ph. A	ph. B	ph. C	total	factor		calculated load (va)					
1. LIGHTS=		2680	3660	1980	VA	8320	1.25						
2. RECEPT=		6120	5400	5820	VA	17340	1 + 0.5						
3. HEATING=		0	0	0	VA	0	1.00						
4. KITCHEN=		6000	2700	6000	VA	14700	0.90						
5. EQUIP.=		1200	1200	1200	VA	3600	1.00						
6. MOTORS=		0	0	0	VA	0	1.00						
7. MISC=		0	0	0	VA	0	1.00						
(* 125% of the largest motor + 100% of the balance)						TOTAL =				40900			

MFA PANEL SCHEDULE													
panel		mounting		location		connected load amps							
M1 (Mechanical Loads)		SURFACE		ELECT RM									
120/208V (SCCR: 42KAIC)		phase		bus & main		calculated load amps							
		3	400A	MLO									
service	va	a/p	no.	a b c	no.	a/p	va	service	va	a/p	no.	a b c	no.
5 PHONE BOARD	500	20/1	1	*	2	20/3	1800	TRASH COMPACTOR					
5 COMMUNICATIONS BOARD	500	20/1	3	*	4	*	1800	*					
5 SECURITY SYSTEM	1500	20/1	5	*	6	*	1800	*					
5 AUTO DOORS	1500	20/1	7	*	8	20/1	1500	PALLET JACK CHARGER					
5 ENTRY ACCESS SYSTEM	1500	20/1	9	*	10	20/1	1500	BIKE CHARGING					
5 BUILDING SIGN	1500	20/1	11	*	12	20/1							
3 WH-1, WH-2, WH-3 (GAS)	1500	20/1	13	*	14	20/1	720	RECEPT - TRASH ROOM					
6 RP-1/RP-2	1900	20/1	15	*	16	20/1	1500	EH-2					
6 BP-1	3865	50/3	17	*	18	20/1	1176	SP-1 (ELEV PIT)					
6 *	3865	*	19	*	20	20/1	1500	SMOKE DAMPERS					
6 *	3865	*	21	*	22	20/1	1500	SMOKE DAMPERS					
3 EH-3	500	20/1	23	*	24	20/1	1500	SMOKE DAMPERS					
3 EH-4	1500	20/2	25	*	26	20/1	2000	SMOKE DAMPERS					
3 *	1500	*	27	*	28	20/1	2000	SMOKE DAMPERS					
5 IRRIGATION CONTROLS	1500	20/1	29	*	30	20/1	2000	SMOKE DAMPERS					
3 IHP/OHP-4	4368	30/2	31	*	32	20/1	2000	SMOKE DAMPERS					
3 *	4368	*	33	*	34	30/2	4368	IHP/OHP-4					
SPARE	0	20/1	35	*	36	*	4368	*					
7 PANEL M2	13300	200/3	37	*	38			WHEELCHAIR LIFT					
7 *	13080	*	39	*	40	*							
7 *	12080	*	41	*	42	*							
Phase A		36053 VA						line-line voltage					
Phase B		38381 VA											
Phase C		31789 VA											
Total Connected		107223 VA											
load code:		ph. A	ph. B	ph. C	total	factor		calculated load (va)					
1. LIGHTS=		0	0	0	VA	0	1.25						
2. RECEPT=		720	0	0	VA	720	1 + 0.5						
3. HEATING=		7368	7368	500	VA	15236	1.00						
4. KITCHEN=		0	0	0	VA	0	1.00						
5. EQUIP.=		9000	7000	8000	VA	24000	1.00						
6. MOTORS=		5665	11933	11209	VA	28807	*						
7. MISC=		13300	13080	12080	VA	38460	1.00						
(* 125% of the largest motor + 100% of the balance)						TOTAL =				107223			

MFA PANEL SCHEDULE													
panel		mounting		location		connected load amps						106	
L1 (Laundry)		FLUSH		RM 222									
voltage		phase		bus & main		MLO		calculated load amps					
120/208V		3		150A									
service		va	a/p	no.	a b c	no.	a/p	va	service	va	a/p	no.	69
2	WASHER	500	20/1	1	*	2	40/2	2800	DRYER	*			2
2	WASHER	500	20/1	3	*	4	*	2800	*				2
2	WASHER	500	20/1	5	*	6	40/2	2800	DRYER	*			2
2	WASHER	500	20/1	7	*	8	*	2800	*				2
2	WASHER	500	20/1	9	*	10	40/2	2800	DRYER	*			2
2	WASHER	500	20/1	11	*	12	*	2800	*				2
5	LAUNDRY CARD MACHINE	1500	20/1	13	*	14	40/2	2800	DRYER	*			2
6	EF-4 (FLRS 3,5)	50	20/1	15	*	16	*	2800	*				2
	SPARE	0	20/1	17	*	18	40/2	2800	DRYER	*			2
	SPARE	0	20/1	19	*	20	*	2800	*				2
	SPARE	0	20/1	21	*	22	40/2	2800	DRYER	*			2
	SPARE	0	20/1	23	*	24	*	2800	*				2
	BLANK			25	*	26			BLANK				
	BLANK			27	*	28			BLANK				
	BLANK			29	*	30			BLANK				
	BLANK			31	*	32			BLANK				
	BLANK			33	*	34			BLANK				
	BLANK			35	*	36			BLANK				
	BLANK			37	*	38			BLANK				
	BLANK			39	*	40			BLANK				
	BLANK			41	*	42			BLANK				
Phase A		13700 VA		NOTES:				line-line voltage					
Phase B		12250 VA										208	
Phase C		12200 VA								largest motor (va)			
Total Connected		38150 VA										0	
load code:		ph. A	ph. B	ph. C		total	factor	calculated load (va)					
1. LIGHTS=		0	0	0		VA	0.125					0	
2. RECEPT=		12200	12200	12200		VA	366001 = 0.5					23300	
3. HEATING=		0	0	0		VA	0.1					0	
4. KITCHEN=		0	0	0		VA	0.100					0	
5. EQUIP.=		1500	0	0		VA	1500 1.00					1500	
6. MOTORS=		0	50	0		VA	50 *					50	
7. MISC=		0	0	0		VA	0.100					0	
(* 125% of the largest motor + 100% of the balance)								TOTAL =				24850	


Alphabet Dist. - North Building																				
RESIDENTIAL LOAD SUMMARY - MC1 (SECOND FLOOR)																				
UNIT TYPE:	QTY PER FLOOR						TOTAL	AREA (AVG SF)	LIG/RECEPT (3VA / SF)	SM APPL (1500VA X 2)	LAUNDRY (1500VA)	COOKING (CONNECTED)	MICROWAVE (CONNECTED)	DISHWASHER (CONNECTED)	ELECT DRYER (CONNECTED)	WATER HEATER (CONNECTED)	DISPOSAL (CONNECTED)	MOTORS (CONNECTED)	LARGEST OF: AC/HEATING (CONNECTED)	
	Lw 1	Lw 2	Lw 3	Lw 4	Lw 5	Lw 6														
Studio Unit	13	14	0	0	0	0	27	317	951	3000	0	14500	0	0	0	0	0	0	3000	
TOTALS:	13	14	0	0	0	0	27	8559	25677	81000	0	391500	0	0	0	0	0	0	81000	
VOLTS:								208	3ph											
TOTAL CONNECTED:								579	KVA											
DEMAND FACTOR:								0.33	Based on Total Number of Residential Units = 28-30 (See N.E.C. Article: 220.84)											
TOTAL CALCULATED:								191	KVA											
CALCULATED AMPS:								531	AMPS											
NOTE:																				

Alphabet Dist. - North Building																			
RESIDENTIAL LOAD SUMMARY - MC2 (FOURTH FLOOR)																			
UNIT TYPE:	QTY PER FLOOR						TOTAL	AREA (AVG SF)	LIG/RECEPT (3VA / SF)	SM APPL (1500VA X 2)	LAUNDRY (1500VA)	COOKING (CONNECTED)	MICROWAVE (CONNECTED)	DISHWASHER (CONNECTED)	ELECT DRYER (CONNECTED)	WATER HEATER (CONNECTED)	DISPOSAL (CONNECTED)	MOTORS (CONNECTED)	LARGEST OF: AC/HEATING (CONNECTED)
	LW 1	LW 2	LW 3	LW 4	LW 5	LW 6													
Studio Unit	0	0	18	18	0	0	36	317	951	3000	0	14500	0	0	0	0	0	0	3000
TOTALS:	0	0	18	18	0	0	36	11412	34236	108000	0	522000	0	0	0	0	0	0	108000
VOLTS: 208 3ph																			
TOTAL CONNECTED: 772 KVA																			
DEMAND FACTOR: 0.3 Based on Total Number of Residential Units = 34-36 (See N.E.C. Article: 220.84)																			
TOTAL CALCULATED: 232 KVA																			
CALCULATED AMPS: 643 AMPS																			
NOTE:																			

Alphabet Dist. -- North Building																				
RESIDENTIAL LOAD SUMMARY -- MC3 (SIXTH FLOOR)																				
UNIT TYPE:	QTY PER FLOOR						TOTAL	AREA (AVG SF)	LIG/RECEPT (3VA / SF)	SM APPL (1500VA X 2)	LAUNDRY (1500VA)	COOKING (CONNECTED)	MICROWAVE (CONNECTED)	DISHWASHER (CONNECTED)	ELECT DRYER (CONNECTED)	WATER HEATER (CONNECTED)	DISPOSAL (CONNECTED)	MOTORS (CONNECTED)	LARGEST OF: AC/HEATING (CONNECTED)	
	Lw 1	Lw 2	Lw 3	Lw 4	Lw 5	Lw 6														
Studio Unit	0	0	0	0	18	16	0	34	317	951	3000	0	14500	0	0	0	0	0	0	3000
1Bedroom					1		1	1	350	1050	3000	0	14500	0	0	0	0	0	0	3000
TOTALS:	0	0	0	0	18	17	0	35	11128	33384	105000	0	507500	0	0	0	0	0	0	105000
VOLTS: 208 3ph																				
TOTAL CONNECTED: 751 KVA																				
DEMAND FACTOR: 0.3 Based on Total Number of Residential Units = 34--36 (See N.E.C. Article: 220.84)																				
TOTAL CALCULATED: 225 KVA																				
CALCULATED AMPS: 625 AMPS																				
NOTE:																				

DWELLING UNIT LOAD CALCULATION	
Project:	Susan Emmons N. Bldg Apartments
Unit Type:	Studio
Area:	325 square feet(average)
Minimum Size Feeder (NEC 220.40):	
General lighting load at 3 VA / SF	975 VA
Small Appliance load (2 ckt's at 1500VA each)	3,000 VA
Laundry Load (1 ckt at 1500VA)	0 VA
Electric Range	14,500 VA
Other Cooking Appliance Load (Microwave Oven)	0 VA
Dishwasher Load	0 VA
Electric Dryer Load	0 VA
Electric Water Heater Load	0 VA
Disposal load	0 VA
Other motor loads	0 VA
Total "General Loads"	18,475 VA
First 10 kVA of "general loads" at 100%	10,000 VA
Remainder of "general loads" at 40%	3,390 VA
Net "general load"	13,390 VA
Largest of:	3,000 VA of electric space heating (less than 4) at 65%
-or-	VA of electric space heating (4 or more) at 40%
-or-	VA of air conditioning/cooling/heat pumps at 100%
TOTAL LOAD	15,340 VA
For 120/240-volt, 3-wire, single-phase service or feeder,	
15,340 VA / 240 volts =	64 Amps
Therefore, this dwelling unit shall be permitted to be served by a 100 amp service.	

MFIA CIRCUIT DIRECTORY										27-Apr-21
Loadcenter Name	mounting				location					
LC-STUDIO (TYPICAL)	RECESSED									
voltage	phase				bus & main					
208/120	1				100A MLO (SCCR: 10K)					
service	6/6	no.	L1	L2	no.	6/6	service			
LIGHTS-KITCHEN/LIVING	20/1(A)	1	*	2	20/1(A)	APPLIANCE CIRCUIT				
LTS & RECEPT - BATH	20/1	3	*	4	20/1(A)	APPLIANCE CIRCUIT				
RECEPT - LIVING	20/1(A)	5	*	6	20/1	REFRIGERATOR				
RECEPT - LIVING	20/1(A)	7	*	8	20/1	SPARE				
RECEPT - (optional)	20/1(A)	9	*	10	50/2	RANGE				
SMART PANEL (optional)	20/1	11	*	12	*					
SPARE	20/1	13	*	14	20/1	SPARE				
SPARE	20/1	15	*	16	20/2	HEAT				
SPARE	20/1	17	*	18	*					
SPARE	20/1	19	*	20	20/1	SPARE				
BLANK	-----	21	*	22	-----	BLANK				
BLANK	-----	23	*	24	-----	BLANK				
BLANK	-----	25		26	-----	BLANK				
BLANK	-----	27		28	-----	BLANK				
BLANK	-----	29		30	-----	BLANK				
NOTES:										
1. (A) DENOTES: ARC-FAULT INTERRUPTER CIRCUIT BREAKER. INSTALL PER NEC 210.12										
2. LOADS FOR THIS PANEL ARE INDICATED ON THE "DWELLING UNIT LOAD CALCULATION".										
3. BREAKER & WIRE SHALL BE SIZED FOR EQUIPMENT INSTALLED.										
4. (G) DENOTES GFCI RATED BREAKER.										



1
E1.13

TYPICAL METER ELEVATION

NOT TO SCALE

TYPICAL METER ARRANGEMENT PER PGE REQUIREMENTS. COMPONENTS SHOWN ARE APPROXIMATE BASED ON VENDOR INFORMATION. ACTUAL EQUIPMENT TO BE INSTALLED MAY VARY. ELECTRICAL CONTRACTOR TO PROVIDE CUTSHEETS OF THE PRODUCTS INSTALLED UPON SUBMITTAL REVIEW & APPROVAL.

MFIA Consulting Engineers
2007 S.E. Ash St.
Portland, OR 97214
PHN: (503) 234-0648
FAX: (503) 234-0677
TNC. WWW.MFIA-ENG.COM
CONTACT: DENISE TAYLOR



CARLETON HART ARCHITECTURE P.C.
830 sw 10th avenue #200 portlandoregon97205
503 243 2252
www.carletonhart.com

SUSAN EMMONS - NORTH BUILDING
680 NW 18TH AVENUE,
PORTLAND, OR

NORTHWEST HOUSING ALTERNATIVES

CONFORMANCE SET

ELECTRICAL
SCHEDULES & DETAILS
PROJECT NO.
17004
05/28/2021

REVISIONS: A

LIGHTING FIXTURE LIST					
TYPE	LAMP	MANUFACTURER	CATALOG NUMBER	DESCRIPTION	OPTIONS
A1 A1E	LED 3000K 2000LM/80CRI 25W	LITHONIA (OR APPROVED OTHER)	ZLIN SERIES	TYPE :.4" GEN. PURPOSE STRIP MOUNTING :SURFACE HOUSING :STEEL LENS/REFL.:DIFFUSED ACRYLIC VOLTAGE :MVOLT BALLAST :LED DRIVER	TYPE 'AE' SIMILAR TO TYPE 'A' EXCEPT WITH EMERGENCY BATTERY BACK-UP EQUIP. RMS, TRASH RM
A2	LED 3500K 3000LM/80CRI 23W	LITHONIA (OR APPROVED OTHER)	FEML48 SERIES	TYPE :.4" ENCLOSED INDUSTRIAL MOUNTING :SURFACE HOUSING :POLYCARBONATE LENS/REFL.:CLEAR POLYCARBONATE VOLTAGE :MVOLT BALLAST :LED DRIVER	ELEVATOR PIT & TOP OF SHAFT
B1 B1E	LED 3000K 3600LM/80CRI 34W	FAIL SAFE (OR APPROVED OTHER)	HVSL8 SERIES	TYPE :.4" WRAP AROUND MOUNTING :SURFACE HOUSING :STEEL LENS/REFL.:ACRYLIC VOLTAGE :MVOLT BALLAST :LED DRIVER	B1E TO BE PROVIDED WITH EMERGENCY BATTERY BALLAST. PROVIDE WITH INTEGRAL OCCUPANCY. SENSOR, DIM50 STANDBY MODE. STAIRWELLS
B3 B3E	LED 3000K 575LM/FT 80CRI 20W	NEO RAY LIGHTING (OR APPROVED OTHER)	S124DS-C SERIES	TYPE :.4FT LINEAR FIXTURE MOUNTING :SURFACE HOUSING :STEEL LENS/REFL.:STRAIGHT BLADE DIFFUSER VOLTAGE :MVOLT BALLAST :LED DRIVER (0-10 DIMMING)	B3E PROVIDED WITH EMERGENCY BATTERY BACKUP. MATTE WHITE FINISH VERIFY MOUNTING TYPE W/ ARCHITECT OFFICE, TRASH RMS LAUNDRY, BIKE RMS
C1 C1E	LED 1300LM/80CRI 3000K 16W	USAI LIGHTING (OR APPROVED OTHER)	B4RD 16G1 SERIES	TYPE :.4.5" DIA. DOWNLIGHT MOUNTING :RECESSED HOUSING :STEEL LENS/REFL.:ACRYLIC VOLTAGE :MVOLT BALLAST :LED DRIVER (0-10 DIMMING)	C1E PROVIDED WITH EMERGENCY BATTERY BACK UP. 90 DEGREE BEAM TRIMLESS/WHITE FINISH IC RATED ELEV. LOBBIES, MAIL ROOM
C2 C2E	LED 3000K 975LM 14W	USAI LIGHTING (OR APPROVED OTHER)	BEVELED 1020 SERIES	TYPE :.4.5" DIA. DOWNLIGHT MOUNTING :RECESSED HOUSING :ALUMINUM LENS/REFL.:SOLITE VOLTAGE :MVOLT BALLAST :LED DRIVER	C2E TO BE PROVIDED WITH EMERGENCY BATTERY BACK UP. FLANGE TRIM/WHITE FINISH UL LISTED WET LOCATION MAIN BUILDING ENTRANCES
C3 C3E	LED 3000K 2000LM 10W	LITHONIA LIGHTING (OR APPROVED OTHER)	WDG1 P2 SERIES	TYPE :EXTERIOR WALL PACK MOUNTING :SURFACE (+8'-0") HOUSING :ALUMINUM LENS/REFL.:ACRYLIC VOLTAGE :MVOLT BALLAST :LED DRIVER	C3E TO BE PROVIDED WITH EMERGENCY BATTERY BACK UP. WHITE FINISH TYPE VW DISTRIBUTION WET LOCATION LISTED BUILDING COURTYARD
C4N	(2) LED A19 3000K 10W	SEA GULL LIGHTING (NO SUBSTITUTE)	8313802-12	TYPE :EXTERIOR WALL SCONCE MOUNTING :SURFACE (+8'-0") HOUSING :ALUMINUM LENS/REFL.:NA VOLTAGE :120V BALLAST :INTEGRAL LED DRIVER	C4E TO BE PROVIDED WITH REMOTE EMERGENCY BATTERY BACK UP. WHITE FINISH WET LOCATION LISTED BUILDING SERVICE ENTRANCES
C5	LED 3000K 50W	WAC LIGHTING (NO SUBSTITUTE)	HR-D425LED	TYPE :.4" DIA ADJ. SPOT MOUNTING :SURFACE HOUSING :ALUMINUM LENS/REFL.:NA VOLTAGE :12V BALLAST :LED DRIVER	PROVIDE APPROPRIATE HOUSING AND LOW VOLTAGE TRANSFORMER ELEVATOR LOBBY
F1	(2) LED A19 3000K 1530LM 30W	JUSTICE DESIGN (NO SUBSTITUTE)	CLD-7564W	TYPE :EXTERIOR WALL SCONCE MOUNTING :SURFACE (+8'-0") HOUSING :ALUMINUM LENS/REFL.:ACRYLIC VOLTAGE :120V BALLAST :LED DRIVER	ADA COMPLIANT. VERIFY MOUNTING HEIGHT. WHITE FINISH WET LOCATION LISTED MAIN BUILDING ENTRANCE
D1	LED 1020LM/FT 3000K (6.7W/FT)	KELVIX LIGHTING (OR APPROVED EQUAL)	VT35K-WR-24V SERIES CH-011 CHANNEL	TYPE :LINEAR LED TAPE (18'-0") MOUNTING :SURFACE (IN CHANNEL) HOUSING :ALUMINUM LENS/REFL.:ACRYLIC/FROSTED VOLTAGE :24 VOLT DC BALLAST :LED DRIVER	VERIFY EXACT LENGTHS W/ARCHITECT CHANNEL TYPE PER ARCHITECT PROVIDE APPROPRIATE TRANSFORMER(S) AND ACCESSORIES FOR EACH LOCATION. UL LISTED WET LOCATION
L1 Ⓢ	LED 3000K 1620LM 18W	LIGHTOLOGY (OR APPROVED OTHER)	RLM801450	TYPE :.18" DECORATIVE PENDANT MOUNTING :SUSPENDED HOUSING : LENS/REFL.:GLASS GLOBE VOLTAGE :120V BALLAST :INTEGRAL LED DRIVER	MATTE BLACK FINISH PROVIDE WITH ADJUSTABLE SUSPENSION CORD. LOBBY
L2	LED 3000K 35710LM 42W	LIGHTOLOGY (OR APPROVED OTHER)	HAMPTON SERIES	TYPE :.20.9" DIA CEILING LIGHT MOUNTING :SURFACE HOUSING :METAL LENS/REFL.:ACRYLIC VOLTAGE :120V BALLAST :INTEGRAL LED DRIVER	MATTE BLACK FINISH MAIL ROOM
L3	LED 3000K 2000LM 22W	ALCON LIGHTING (OR APPROVED OTHER)	11170-12 SERIES	TYPE :.12" DIA CEILING LIGHT MOUNTING :SURFACE HOUSING :METAL LENS/REFL.:ACRYLIC VOLTAGE :120V BALLAST :INTEGRAL LED DRIVER	WHITE FINISH CORRIDORS, AMENITY, RESTROOM

LIGHTING FIXTURE LIST					
TYPE	LAMP	MANUFACTURER	CATALOG NUMBER	DESCRIPTION	OPTIONS
U1	LED 700LM/90CRI 3000K (10W)	LIGHTOLIER (OR APPROVED EQUAL)	SDSR SERIES	TYPE :.5" DIA. DOWNLIGHT MOUNTING :SURFACE (J-BOX) HOUSING :ALUMINUM LENS/REFL.:MOLDED POLYMER VOLTAGE :MVOLT BALLAST :LED DRIVER (0-10 DIMMING)	WHITE FINISH UNIT KITCHEN, HALL, BATHROOM
U3	LED 1300LM/90CRI 3000K 16W	DESIGN CLASSICS (OR APPROVED EQUAL)	PRODUCT #646438 MODEL 1330-30-90	TYPE :.24" VANITY LIGHT MOUNTING :SURFACE (+6" ABOVE MIRROR) HOUSING :STEEL LENS/REFL.:ACRYLIC VOLTAGE :120V BALLAST :INTEGRAL DRIVER	CHROME FINISH UNIT BATHROOM
U4	LED 2500lm 3000K (36W)	MAXIM LIGHTING (OR APPROVED OTHER)	WAFER SERIES #7746W/IT	TYPE :.4FT FLAT PANEL MOUNTING :SURFACE HOUSING :ALUMINUM LENS/REFL.:ACRYLIC VOLTAGE :120V BALLAST :LED DRIVER (0-10 DIMMING)	 UNIT KITCHEN
U5	LED 1200LM 3000K (17W)	PROGRESS LIGHTING (OR APPROVED EQUAL)	P3911 SERIES	TYPE :.14" DIA. CEILING LIGHT MOUNTING :SURFACE HOUSING :STEEL LENS/REFL.:WHITE ACRYLIC VOLTAGE :120V BALLAST :LED DRIVER (0-10 DIMMING)	WHITE FINISH UNIT BEDROOM, LIVING ROOM
X1 X2	LED (GREEN LETTERS) (1.5W)	LITHONIA DMF LIGHTING (OR APPROVED OTHER)	LE EL N SERIES DLED500EM-G	TYPE :EXIT SIGN MOUNTING :UNIVERSAL HOUSING :DIE-CAST ALUMINUM LENS/REFL.:SINGLE FACE/DUAL FACE VOLTAGE :MVOLT BALLAST :NICKLE CADMIUM BATTERY	X1=SINGLE SIDE X2=DOUBLE SIDE
X3	LED (GREEN LETTERS) (1.5W)	LITHONIA (OR APPROVED OTHER)	WLTE SERIES	TYPE :EXIT SIGN MOUNTING :UNIVERSAL HOUSING :DIE-CAST ALUMINUM LENS/REFL.:SINGLE FACE VOLTAGE :MVOLT BALLAST :NICKLE CADMIUM BATTERY	UL LISTED WET LOCATION

MECHANICAL EQUIPMENT SCHEDULE									
NO.	EQUIPMENT NAME	HP/KW	VOLTS	PH	AMPS	CONDUIT	WIRE	GND	CIRCUIT
EF-1	EXHAUST FAN NO.1	8.2W	120	1		1/2"	#12	#12	SEE UNIT PLANS
EF-2	EXHAUST FAN NO.2	8.2W	120	1		1/2"	#12	#12	SEE E3.01
EF-3	EXHAUST FAN NO.3	8.2W	120	1		1/2"	#12	#12	SEE E3.02, E3.04, E3.06
EF-4	EXHAUST FAN NO.4	7.7W	120	1		1/2"	#12	#12	SEE E3.03, E3.05
EF-5	EXHAUST FAN NO.5	1/10 HP	120	1		1/2"	#12	#12	M2-7 (PC)
EF-6	EXHAUST FAN NO.6	7.7W	120	1		1/2"	#12	#12	M2-7 (PC)
EH-1	WALL HEATER NO.1	1.2KW	120V	1		1/2"	#12	#12	SEE UNIT PLANS
EH-2	WALL HEATER NO.2	1.5KW	120	1		1/2"	#12	#12	M1-16
EH-3	WALL HEATER NO.3	500W	120	1		1/2"	#12	#12	M1-23
EH-4	WALL HEATER NO.4	3.0KW	208V	1		1/2"	#12	#12	M1-25,27
IHP-1	MINI SPLIT SYST NO.1 (INDOOR)	(A & B)							
OHP-1	MINI SPLIT SYST NO.1 (OUTDOOR)		208	1	42.0 MCA	3/4"	#6	#10	SEE UNIT PLANS
IHP-2	MINI SPLIT SYST NO.2 (INDOOR)	(A & B)							
OHP-2	MINI SPLIT SYST NO.2 (OUTDOOR)		208	1	22.1 MCA	3/4"	#10	#10	SEE UNIT PLANS
IHP-3	MINI SPLIT SYST NO.3 (INDOOR)	(A & B)							
OHP-3	MINI SPLIT SYST NO.3 (OUTDOOR)		208	1	42.0 MCA	3/4"	#6	#10	M1-34,36
IHP-4	MINI SPLIT SYST NO.4 (INDOOR)								
OHP-4	MINI SPLIT SYST NO.4 (OUTDOOR)		208	1	42.0 MCA	3/4"	#10	#10	M1-31,33
RTU-1	AIR HANDLING UNIT NO.1		208	3	41.0MCA	3/4'	#6	#10	M2-1,3,5
RTU-2	AIR HANDLING UNIT NO.2		208	3	41.0 MCA	1/2"	#10	#10	M2-7,9,11
SP-1	SUMP PUMP NO.1	1/2HP	120	1		1/2"	#12	#12	M1-18
RP-1	RECIRC PUMP NO.1	1/2HP	120	1		1/2"	#12	#12	M1-15 (PC)
RP-2	RECIRC PUMP NO.2	1/2HP	120	1		1/2"	#12	#12	M1-15 (PC)
BP-1	BOOSTER PUMP NO.1	(2) SHP	208	3	28.8 EA.	1"	#4	#10	M1-17,19,21
WH-1	WATER HEATER NO.1 (GAS)		120	1		1/2"	#12	#12	M1-13 (PC)
WH-2	WATER HEATER NO.2 (GAS)		120	1		1/2"	#12	#12	M1-13 (PC)
WH-3	WATER HEATER NO.3 (GAS)		120	1		1/2"	#12	#12	M1-13 (PC)

GENERAL LIGHTING NOTES:

- A. ALL LIGHT FIXTURES SHALL HAVE ENERGY EFFICIENT LAMPING AND BALLASTS.
- B. LIGHT FIXTURES FOR LIVING UNITS SHALL BE "ENERGY STAR" RATED.
- C. VERIFY ALL FIXTURE FINISHES WITH ARCHITECT PRIOR TO BID.
- D. VERIFY ALL FIXTURE MOUNTING HEIGHTS WITH ARCHITECT PRIOR TO BID.
- E. VERIFY ALL FIXTURE LOCATIONS WITH ARCHITECT PRIOR TO ROUGH IN.
- F. ALL INTERIOR LIGHTING SHALL BE 3000 KELVIN UNLESS OTHERWISE NOTED.
- G. ALL PRODUCT SUBSTITUTIONS AND VALUE ENGINEERING SHALL BE SUBMITTED DURING BID PHASE, SHALL MEET DESIGN INTENT AND IS SUBJECT TO OWNER APPROVAL.
- H. EGRESS LIGHTING SHALL BE PROVIDED WITH EMERGENCY BATTERY BACKUP, EITHER INTEGRAL OR REMOTE, AS REQUIRED. EGRESS LIGHTING SHALL BE PROVIDED TO MEET MINIMUM LIGHT LEVELS AS DESCRIBED PER OREGON STRUCTURAL SPECIALTY CODE 1008 AND NFPA 110.
- I. BUILDING MOUNTED LIGHT FIXTURES SHALL BE CONTROLLED VIA PHOTOCELL AND SHALL ACT AS EGRESS LIGHTING IN THE EVENT OF POWER FAILURE.

KEYED LIGHTING NOTES:

1. PROVIDE REMOTE EMERGENCY BATTERY PACK FOR THE FIXTURES IN THE MAIN LOBBY.

GENERAL EQUIPMENT NOTES:

- A. CONTRACTOR/DESIGNER SHALL VERIFY ALL MECHANICAL EQUIPMENT CONNECTION LOAD REQUIREMENTS WITH THE MECHANICAL EQUIPMENT PROVIDER PRIOR TO ROUGH IN.
- B. MECHANICAL EQUIPMENT SIZES SHOWN IN THE MECHANICAL SCHEDULE ABOVE ARE FOR REFERENCE ONLY AND MAY NOT REFLECT THE ACTUAL EQUIPMENT TO BE INSTALLED.

SUSAN EMMONS - NORTH BUILDING
680 NW 18TH AVENUE,
PORTLAND, OR
NORTHWEST HOUSING ALTERNATIVES


CONFORMANCE SET

ELECTRICAL DETAILS

PROJECT NO.
17004










05/28/2021

REVISIONS: A



MEFA Consulting Engineers
2007 S.E. Ash St.
Portland, OR 97214
PHN: (503) 234-0648
FAX: (503) 234-0677
WWW.MFIA-ENG.COM
CONTACT: DENISE TAYLOR

CARLETON HART ARCHITECTURE P.C.
830 sw 10th avenue #200 portlandoregon97205
503 243 2252
www.carletonhart.com



308.2 Forward Reach.

308.2.1 **Unobstructed.** Where a forward reach is unobstructed, the high forward reach shall be 48" maximum and the low forward reach shall be 15" minimum above the floor or ground.


308.2.2 **Obstructed High Reach.** Where a high forward reach is over an obstruction, the clear floor or ground space shall extend beneath the element for a distance not less than the required reach depth over the obstruction. The high forward reach shall be 48" maximum where the reach depth is 20" maximum. Where the reach depth exceeds 20", the high forward reach shall be 44" maximum and the reach depth shall be 25" maximum.

308.3 Side Reach.

308.3.1 **Unobstructed.** Where a clear floor or ground space allows a parallel approach to an element and the side reach is unobstructed, the high side reach shall be 48" maximum and the low side reach shall be 15" minimum above the floor or ground. **Exception:** Existing elements shall be permitted at 54" maximum above the floor or ground.

308.3.2 **Obstructed High Reach.** Where a clear floor or ground space allows a parallel approach to an object and the high side reach is over an obstruction, the height of the obstruction shall be 34" maximum and the depth of the obstruction shall 24" maximum. The high side reach shall be 48" maximum for a reach depth of 10" maximum. Where the reach depth exceeds 10", the high side reach shall be 46" maximum for a reach depth of 24" maximum.

Consulting Engineers
2007 S.E. Ash St.
Portland, OR 97214
PHN: (503) 234-0648
FAX: (503) 234-0677
INC. WWW.MFIA-ENG.COM
CONTACT: DENISE TAYLOR



CARLETON HART ARCHITECTURE P.C.
830 SW 10th Avenue #200 Portland, Oregon 97205
503 243 2252
www.carletonhart.com

SUSAN EMMONS - NORTH BUILDING
680 NW 18TH AVENUE,
PORTLAND, OR

NORTHWEST HOUSING ALTERNATIVES

CONFORMANCE SET



ELECTRICAL DETAILS

PROJECT NO.
17004

05/28/2021

REVISIONS: A

E1.15



1 FIRST FLOOR LIGHTING PLAN
E2.01 SCALE: 1/8" = 1'-0"


GENERAL LIGHTING NOTES:

- ELECTRICAL DRAWINGS ARE DIAGRAMMATICAL AND MAY NOT ACCURATELY REFLECT ACTUAL CONSTRUCTION CONDITIONS. THE ELECTRICAL CONTRACTOR SHALL BE RESPONSIBLE FOR COORDINATING THE INSTALLATION OF ALL ELECTRICAL EQUIPMENT, WITH ALL TRADES PRIOR TO AND DURING CONSTRUCTION.
- THE ELECTRICAL CONTRACTOR SHALL REFER TO THE ARCHITECTURAL DRAWINGS FOR ALL MOUNTING HEIGHTS AND FINISHES OF DEVICES AND FIXTURES.
- REFER TO ENLARGED TYPICAL UNIT PLANS (E4 SERIES SHEETS) FOR TYPICAL POWER & LIGHTING LAYOUTS FOR THE RESIDENTIAL UNITS.
- REFER TO SHEET E1.14 FOR LIGHT FIXTURE SCHEDULE.
- THE CONTRACTOR SHALL CONSULT THE ARCHITECT AND/OR INTERIOR DESIGNER FOR THE EXACT LOCATION OF ALL LIGHT FIXTURES PRIOR TO THE START OF ANY ROUGH IN WORK.
- OCCUPANCY SENSORS SHALL BE FIELD ADJUSTED TO ENSURE COVERAGE AND PROPER CONTROL.
- CORRIDOR LIGHTING TO BE CONSTANT "ON" AND PROVIDED WITH LOCAL MANUAL OVERRIDE SWITCHES FOR MAINTENANCE. ROUTE CORRIDOR LIGHTING VIA TIME CLOCK TO REDUCE LIGHT LEVELS BY 50% DURING PERIODS OF LOW ACTIVITY (EG. MIDNIGHT TO 4AM). REFER TO SHEET E1.15 FOR SWITCH WIRING DIAGRAMS.
- ALL EGRESS FIXTURES SHALL BE WIRED SUCH THAT IN THE EVENT OF A POWER FAILURE, ALL LIGHTS WILL AUTOMATICALLY RETURN TO FULL POWER REGARDLESS OF SWITCH POSITION. REFER TO SWITCHING DETAILS ON SHEET E1.15.

KEYED NOTES:

- CONTINUE CIRCUIT UP THROUGH THE STAIRWELL.
- CORRIDOR LIGHTS NOTED AS NIGHT LIGHTS (N.L.) SHALL BE ON 24/7. ALL OTHER CORRIDOR FIXTURES TO BE CIRCUITED VIA MECHANICAL TIME CLOCK AND SET TO REDUCE THE LIGHT LEVELS DURING PERIODS OF LOW ACTIVITY (EG. 12AM TO 4AM). CONSULT OWNER FOR PREFERRED TIME CLOCK SETTINGS.

MFA Consulting Engineers
2007 S.E. Ash St.
Portland, OR 97214
PHN: (503) 234-0648
FAX: (503) 234-0677
INC. WWW.MFA-ENG.COM
CONTACT: DENISE TAYLOR



CARLETON HART ARCHITECTURE P.C.
830 SW 10th Avenue #200 Portland, Oregon 97205
503 243 2252
www.carletonhart.com

SUSAN EMMONS - NORTH BUILDING
680 NW 18TH AVENUE,
PORTLAND, OR

NORTHWEST HOUSING ALTERNATIVES



CONFORMANCE SET

FIRST FLOOR
LIGHTING PLAN

PROJECT NO.
17004
05/28/2021

REVISIONS: A

E2.01



1 SECOND FLOOR LIGHTING PLAN
SCALE: 1/8" = 1'-0"


GENERAL LIGHTING NOTES:

- ELECTRICAL DRAWINGS ARE DIAGRAMMATICAL AND MAY NOT ACCURATELY REFLECT ACTUAL CONSTRUCTION CONDITIONS. THE ELECTRICAL CONTRACTOR SHALL BE RESPONSIBLE FOR COORDINATING THE INSTALLATION OF ALL ELECTRICAL EQUIPMENT, WITH ALL TRADES PRIOR TO AND DURING CONSTRUCTION.
- THE ELECTRICAL CONTRACTOR SHALL REFER TO THE ARCHITECTURAL DRAWINGS FOR ALL MOUNTING HEIGHTS AND FINISHES OF DEVICES AND FIXTURES.
- REFER TO ENLARGED TYPICAL UNIT PLANS (E4 SERIES SHEETS) FOR TYPICAL POWER & LIGHTING LAYOUTS FOR THE RESIDENTIAL UNITS.
- REFER TO SHEET E1.14 FOR LIGHT FIXTURE SCHEDULE.
- THE CONTRACTOR SHALL CONSULT THE ARCHITECT AND/OR INTERIOR DESIGNER FOR THE EXACT LOCATION OF ALL LIGHT FIXTURES PRIOR TO THE START OF ANY ROUGH IN WORK.
- OCCUPANCY SENSORS SHALL BE FIELD ADJUSTED TO ENSURE COVERAGE AND PROPER CONTROL.
- CORRIDOR LIGHTING TO BE CONSTANT "ON" AND PROVIDED WITH LOCAL MANUAL OVERRIDE SWITCHES FOR MAINTENANCE. ROUTE CORRIDOR LIGHTING VIA TIME CLOCK TO REDUCE LIGHT LEVELS BY 50% DURING PERIODS OF LOW ACTIVITY (EG. MIDNIGHT TO 4AM). REFER TO SHEET E1.15 FOR SWITCH WIRING DIAGRAMS.
- ALL EGRESS FIXTURES SHALL BE WIRED SUCH THAT IN THE EVENT OF A POWER FAILURE, ALL LIGHTS WILL AUTOMATICALLY RETURN TO FULL POWER REGARDLESS OF SWITCH POSITION. REFER TO SWITCHING DETAILS ON SHEET E1.15.

KEYED NOTES:

- CONTINUE CIRCUIT UP THROUGH THE STAIRWELL.
- CORRIDOR LIGHTS NOTED AS NIGHT LIGHTS (NL) SHALL BE ON 24/7. ALL OTHER CORRIDOR FIXTURES TO BE CIRCUITED VIA MECHANICAL TIME CLOCK AND SET TO REDUCE THE LIGHT LEVELS DURING PERIODS OF LOW ACTIVITY (EG. 12AM TO 4AM). CONSULT OWNER FOR PREFERRED TIME CLOCK SETTINGS.

MFA Consulting Engineers
2007 S.E. Ash St.
Portland, OR 97214
PHN: (503) 234-0648
FAX: (503) 234-0677
INC. WWW.MFA-ENG.COM
CONTACT: DENISE TAYLOR





CARLETON HART ARCHITECTURE P.C.
830 SW 10th Avenue #200 Portland, OR 97205
503.243.2252
www.carletonhart.com

SUSAN EMMONS - NORTH BUILDING
680 NW 18TH AVENUE,
PORTLAND, OR
NORTHWEST HOUSING ALTERNATIVES

CONFORMANCE SET

SECOND FLOOR
LIGHTING PLAN
PROJECT NO.
17004
05/28/2021

REVISIONS: A



1 THIRD FLOOR LIGHTING PLAN
E2.03 SCALE: 1/8" = 1'-0"

GENERAL LIGHTING NOTES:

- A. ELECTRICAL DRAWINGS ARE DIAGRAMMATICAL AND MAY NOT ACCURATELY REFLECT ACTUAL CONSTRUCTION CONDITIONS. THE ELECTRICAL CONTRACTOR SHALL BE RESPONSIBLE FOR COORDINATING THE INSTALLATION OF ALL ELECTRICAL EQUIPMENT, WITH ALL TRADES PRIOR TO AND DURING CONSTRUCTION.
- B. THE ELECTRICAL CONTRACTOR SHALL REFER TO THE ARCHITECTURAL DRAWINGS FOR ALL MOUNTING HEIGHTS AND FINISHES OF DEVICES AND FIXTURES.
- C. REFER TO ENLARGED TYPICAL UNIT PLANS (E4 SERIES SHEETS) FOR TYPICAL POWER & LIGHTING LAYOUTS FOR THE RESIDENTIAL UNITS.
- D. REFER TO SHEET E1.14 FOR LIGHT FIXTURE SCHEDULE.
- E. THE CONTRACTOR SHALL CONSULT THE ARCHITECT AND/OR INTERIOR DESIGNER FOR THE EXACT LOCATION OF ALL LIGHT FIXTURES PRIOR TO THE START OF ANY ROUGH IN WORK
- F. OCCUPANCY SENSORS SHALL BE FIELD ADJUSTED TO ENSURE COVERAGE AND PROPER CONTROL.
- G. CORRIDOR LIGHTING TO BE CONSTANT "ON" AND PROVIDED WITH LOCAL MANUAL OVERRIDE SWITCHES FOR MAINTENANCE. ROUTE CORRIDOR LIGHTING VIA TIME CLOCK TO REDUCE LIGHT LEVELS BY 50% DURING PERIODS OF LOW ACTIVITY (EG. MIDNIGHT TO 4AM). REFER TO SHEET E1.15 FOR SWITCH WIRING DIAGRAMS.
- H. ALL EGRESS FIXTURES SHALL BE WIRED SUCH THAT IN THE EVENT OF A POWER FAILURE, ALL LIGHTS WILL AUTOMATICALLY RETURN TO FULL POWER REGARDLESS OF SWITCH POSITION. REFER TO SWITCHING DETAILS ON SHEET E1.15.

KEYED NOTES:

- 1. CONTINUE CIRCUIT UP THROUGH THE STAIRWELL.
- 2. CORRIDOR LIGHTS NOTED AS NIGHT LIGHTS (N.L.) SHALL BE ON 24/7. ALL OTHER CORRIDOR FIXTURES TO BE CIRCUITED VIA MECHANICAL TIME CLOCK AND SET TO REDUCE THE LIGHT LEVELS DURING PERIODS OF LOW ACTIVITY (EG. 12AM TO 4AM). CONSULT OWNER FOR PREFERRED TIME CLOCK SETTINGS.

MFA Consulting Engineers
2007 S.E. Ash St.
Portland, OR 97214
PHN: (503) 234-0648
FAX: (503) 234-0677
INC. WWW.MFA-ENG.COM
CONTACT: DENISE TAYLOR




CARLETON HART ARCHITECTURE P.C.
830 SW 10th Avenue #200 Portland, OR 97205
503.243.2252
www.carletonhart.com

SUSAN EMMONS - NORTH BUILDING
680 NW 18TH AVENUE,
PORTLAND, OR
NORTHWEST HOUSING ALTERNATIVES

THIRD FLOOR
LIGHTING PLAN
PROJECT NO.
17004
05/28/2021

REVISIONS: A




GENERAL LIGHTING NOTES:

- ELECTRICAL DRAWINGS ARE DIAGRAMMATICAL AND MAY NOT ACCURATELY REFLECT ACTUAL CONSTRUCTION CONDITIONS. THE ELECTRICAL CONTRACTOR SHALL BE RESPONSIBLE FOR COORDINATING THE INSTALLATION OF ALL ELECTRICAL EQUIPMENT, WITH ALL TRADES PRIOR TO AND DURING CONSTRUCTION.
- THE ELECTRICAL CONTRACTOR SHALL REFER TO THE ARCHITECTURAL DRAWINGS FOR ALL MOUNTING HEIGHTS AND FINISHES OF DEVICES AND FIXTURES.
- REFER TO ENLARGED TYPICAL UNIT PLANS (E4 SERIES SHEETS) FOR TYPICAL POWER & LIGHTING LAYOUTS FOR THE RESIDENTIAL UNITS.
- REFER TO SHEET E1.14 FOR LIGHT FIXTURE SCHEDULE.
- THE CONTRACTOR SHALL CONSULT THE ARCHITECT AND/OR INTERIOR DESIGNER FOR THE EXACT LOCATION OF ALL LIGHT FIXTURES PRIOR TO THE START OF ANY ROUGH IN WORK.
- OCCUPANCY SENSORS SHALL BE FIELD ADJUSTED TO ENSURE COVERAGE AND PROPER CONTROL.
- CORRIDOR LIGHTING TO BE CONSTANT "ON" AND PROVIDED WITH LOCAL MANUAL OVERRIDE SWITCHES FOR MAINTENANCE. ROUTE CORRIDOR LIGHTING VIA TIME CLOCK TO REDUCE LIGHT LEVELS BY 50% DURING PERIODS OF LOW ACTIVITY (EG. MIDNIGHT TO 4AM). REFER TO SHEET E1.15 FOR SWITCH WIRING DIAGRAMS.
- ALL EGRESS FIXTURES SHALL BE WIRED SUCH THAT IN THE EVENT OF A POWER FAILURE, ALL LIGHTS WILL AUTOMATICALLY RETURN TO FULL POWER REGARDLESS OF SWITCH POSITION. REFER TO SWITCHING DETAILS ON SHEET E1.15.

KEYED NOTES:

- CONTINUE CIRCUIT UP THROUGH THE STAIRWELL.
- CORRIDOR LIGHTS NOTED AS NIGHT LIGHTS (N.L.) SHALL BE ON 24/7. ALL OTHER CORRIDOR FIXTURES TO BE CIRCUITED VIA MECHANICAL TIME CLOCK AND SET TO REDUCE THE LIGHT LEVELS DURING PERIODS OF LOW ACTIVITY (EG. 12AM TO 4AM). CONSULT OWNER FOR PREFERRED TIME CLOCK SETTINGS.

MFA Consulting Engineers
2007 S.E. Ash St.
Portland, OR 97214
PHN: (503) 234-0648
FAX: (503) 234-0677
INC. WWW.MFA-ENG.COM
CONTACT: DENISE TAYLOR



CARLETON HART ARCHITECTURE P.C.
830 SW 10th Avenue #200 Portland, OR 97205
503.243.2252
www.carletonhart.com

SUSAN EMMONS - NORTH BUILDING
680 NW 18TH AVENUE,
PORTLAND, OR
NORTHWEST HOUSING ALTERNATIVES



CONFORMANCE SET

FOURTH FLOOR
LIGHTING PLAN

PROJECT NO.
17004
05/28/2021

REVISIONS:

E2.04



1 FIFTH FLOOR LIGHTING PLAN
E2.05 SCALE: 1/8" = 1'-0"


GENERAL LIGHTING NOTES:

- ELECTRICAL DRAWINGS ARE DIAGRAMMATICAL AND MAY NOT ACCURATELY REFLECT ACTUAL CONSTRUCTION CONDITIONS. THE ELECTRICAL CONTRACTOR SHALL BE RESPONSIBLE FOR COORDINATING THE INSTALLATION OF ALL ELECTRICAL EQUIPMENT, WITH ALL TRADES PRIOR TO AND DURING CONSTRUCTION.
- THE ELECTRICAL CONTRACTOR SHALL REFER TO THE ARCHITECTURAL DRAWINGS FOR ALL MOUNTING HEIGHTS AND FINISHES OF DEVICES AND FIXTURES.
- REFER TO ENLARGED TYPICAL UNIT PLANS (E4 SERIES SHEETS) FOR TYPICAL POWER & LIGHTING LAYOUTS FOR THE RESIDENTIAL UNITS.
- REFER TO SHEET E1.14 FOR LIGHT FIXTURE SCHEDULE.
- THE CONTRACTOR SHALL CONSULT THE ARCHITECT AND/OR INTERIOR DESIGNER FOR THE EXACT LOCATION OF ALL LIGHT FIXTURES PRIOR TO THE START OF ANY ROUGH IN WORK.
- OCCUPANCY SENSORS SHALL BE FIELD ADJUSTED TO ENSURE COVERAGE AND PROPER CONTROL.
- CORRIDOR LIGHTING TO BE CONSTANT "ON" AND PROVIDED WITH LOCAL MANUAL OVERRIDE SWITCHES FOR MAINTENANCE. ROUTE CORRIDOR LIGHTING VIA TIME CLOCK TO REDUCE LIGHT LEVELS BY 50% DURING PERIODS OF LOW ACTIVITY (EG. MIDNIGHT TO 4AM). REFER TO SHEET E1.15 FOR SWITCH WIRING DIAGRAMS.
- ALL EGRESS FIXTURES SHALL BE WIRED SUCH THAT IN THE EVENT OF A POWER FAILURE, ALL LIGHTS WILL AUTOMATICALLY RETURN TO FULL POWER REGARDLESS OF SWITCH POSITION. REFER TO SWITCHING DETAILS ON SHEET E1.15.

KEYED NOTES:

- CONTINUE CIRCUIT UP THROUGH THE STAIRWELL.
- CORRIDOR LIGHTS NOTED AS NIGHT LIGHTS (N.L.) SHALL BE ON 24/7. ALL OTHER CORRIDOR FIXTURES TO BE CIRCUITED VIA MECHANICAL TIME CLOCK AND SET TO REDUCE THE LIGHT LEVELS DURING PERIODS OF LOW ACTIVITY (EG. 12AM TO 4AM). CONSULT OWNER FOR PREFERRED TIME CLOCK SETTINGS.

MFA Consulting Engineers
2007 S.E. Ash St.
Portland, OR 97214
PHN: (503) 234-0648
FAX: (503) 234-0677
INC. WWW.MFA-ENG.COM
CONTACT: DENISE TAYLOR




CARLETON HART ARCHITECTURE P.C.
830 sw 10th avenue #200 portlandoregon 97205
503 243 2252
www.carletonhart.com

SUSAN EMMONS - NORTH BUILDING
680 NW 18TH AVENUE,
PORTLAND, OR
NORTHWEST HOUSING ALTERNATIVES

FIFTH FLOOR
LIGHTING PLAN
PROJECT NO.
17004
05/28/2021

REVISIONS: A

E2.05



1. CONTINUE CIRCUIT UP THROUGH THE STAIRWELL.
2. CORRIDOR LIGHTS NOTED AS NIGHT LIGHTS (N.L.) SHALL BE ON 24/7. ALL OTHER CORRIDOR FIXTURES TO BE CIRCUITED VIA MECHANICAL TIME CLOCK AND SET TO REDUCE THE LIGHT LEVELS DURING PERIODS OF LOW ACTIVITY (EG. 12AM TO 4AM). CONSULT OWNER FOR PREFERRED TIME CLOCK SETTINGS.

SUSAN EMMONS - NORTH BUILDING
680 NW 18TH AVENUE,
PORTLAND, OR

CONFORMANCE SET



PROJECT NO.
17004

05/28/2021

REVISIONS:

#

E2.06



1 FIRST FLOOR POWER PLAN
E3.01 SCALE: 1/8" = 1'-0"

GENERAL POWER NOTES:

- A. ALL PLANS ARE CONSIDERED DIAGRAMMATICAL. THEREFORE ALL EQUIPMENT SIZES AND DEVICE LOCATIONS ARE APPROXIMATE AND SUBJECT TO FIELD CONDITIONS AND PRODUCT APPROVAL.
- B. ELECTRICAL CONTRACTOR TO PROVIDE THERMOSTATS NOT SUPPLIED BY MECHANICAL CONTRACTOR. CONSULT MECHANICAL PLANS FOR ADDITIONAL INFORMATION.
- C. ELECTRICAL CONTRACTOR SHALL PROVIDE INSTALLATION AND FINAL CONNECTION OF THERMOSTATS. CONSULT MECHANICAL CONTRACTOR FOR EXACT REQUIREMENTS PRIOR TO ROUGH IN.
- D. REFER TO INTERIOR DECORATOR AND/OR ARCHITECTURAL DRAWINGS FOR DIMENSIONED LOCATION(S) AND ELEVATIONS OF FIXTURES & DEVICES. OTHER DEVICES SHOWN ON THE ELECTRICAL PLANS AND NOT INDICATED ON THE DECORATOR'S OR ARCHITECT'S DRAWINGS, SHALL BE INSTALLED AT STANDARD MOUNTING HEIGHT AS INDICATED THE SYMBOL LIST.
- E. REFER TO ENLARGED TYPICAL UNIT PLANS (E4 SERIES SHEETS) FOR TYPICAL POWER & LIGHTING LAYOUTS FOR THE APARTMENT UNITS.
- F. ELECTRICAL EQUIPMENT SHOWN IN THE ELECTRICAL ROOMS IS APPROXIMATE. BASED ON TYPICAL PRODUCTS. CONTRACTOR SHALL VERIFY ANY SUBMITTED EQUIPMENT WILL FIT WITHIN THE SPACE PROVIDED. PRIOR TO PRODUCT SUBMITTAL REVIEW.
- G. ELECTRICAL CONTRACTOR SHALL COORDINATE WITH THE LOW VOLTAGE ('T' SERIES) PLANS, INCLUDING FIRE ALARM AND SYSTEMS INSTALLER, AND PROVIDE ROUGH IN AS NEEDED.
- H. GENERAL PURPOSE CONVENIENCE RECEPTACLES LOCATED ON THE BUILDING EXTERIOR, OTHER THAN INTERIOR COURT YARD, SHALL BE EQUIPPED WITH A LOCKING, WEATHER PROOF COVER.

KEYED NOTES:

- 1. GENERATOR DISCONNECT. SEE ONE-LINE DIAGRAM ON SHEET E1.11.
- 2. PROVIDE ONE 20A, 120V, 1P CIRCUIT FOR GENERATOR REMOTE ANNUNCIATOR. FED FROM PANEL E1.
- 3. PROVIDE ONE 20A, 120V, 1P POWER CONNECTION FOR BUILDING SIGNS. CIRCUIT AS INDICATED VIA TIME CLOCK. MOUNT JUNCTION BOX TIGHT TO CEILING (AT BUILDING INTERIOR), COORDINATING EXACT LOCATION WITH SIGN INSTALLER'S SLEEVE AND PER ARCHITECT'S DIRECTION.
- 4. PROVIDE ONE 20A, 120V, 1P CIRCUIT FROM PANEL H1 FOR BUILDING ENTRY ACCESS CONTROL SYSTEM AND PROVIDE ROUGH IN AND WIRING TO ACCESS POINTS LOCATED ON PLANS. CONSULT WITH LOW VOLTAGE SYSTEMS INSTALLER AND THE 'T' SERIES SHEETS FOR ADDITIONAL INFORMATION.
- 5. VERIFY ELEVATOR EQUIPMENT LOCATION AND ELECTRICAL REQUIREMENTS WITH ARCHITECT AND/OR ELEVATOR PROVIDER.
- 6. PROVIDE ONE 20A, 120V, 1P CIRCUIT FROM PANEL H1 FOR AUTOMATIC DOOR OPENERS.
- 7. ELECTRICAL SERVICE METER ROOMS SHALL HAVE OUTWARD SWING DOORS EQUIPPED WITH PANIC HARDWARE. PROVIDE A KEY BOX AT THE EXTERIOR FOR ELECTRICAL UTILITIES' 24/7 ACCESS.
- 8. LOW VOLTAGE/COMMUNICATIONS SYSTEM DEMARCATION BOARD(S). COORDINATE LOCATIONS AND ELECTRICAL POWER REQUIREMENTS WITH THE TELECOM PLANS ('T' SERIES SHEETS) AND LOW VOLTAGE SYSTEMS INSTALLERS, AND PROVIDE ROUGH IN AND/OR FINAL ELECTRICAL POWER CONNECTIONS & DEVICES. REFER PANEL 'M1' SCHEDULE ON E1.12 FOR CIRCUITS.
- 9. DEDICATED POWER FOR WHEELCHAIR LIFT. VERIFY EXACT REQUIREMENTS WITH MANUFACTURER/INSTALLER PRIOR TO ROUGH IN.
- 10. DEDICATED 20A, 120V RECEPTACLE FOR PALLET JACK CHARGING.
- 11. PROVIDE ONE 30A, 208V, 1PH ELECTRICAL CIRCUIT FOR TRASH COMPACTOR. FEED FROM PANEL M1.
- 12. DEDICATED 20A, 120V RECEPTACLE FOR ELECTRIC BIKE CHARGING.
- 13. EMERGENCY LIGHTING INVERTER. EVENLITE LM 535, 120V, 1P, OR APPROVED OTHER. REFER TO PANEL H1 FOR CIRCUITING.
- 14. CONTINUOUS OPERATION EXHAUST FAN TO BE TIED INTO THE LIGHTING CIRCUIT FOR THIS AREA, AHEAD OF THE LIGHTING CONTROLS. CONSULT MECHANICAL PLANS AND/OR EQUIPMENT INSTALLER FOR EXACT POWER REQUIREMENTS PRIOR TO ROUGH IN.
- 15. REFER TO TYPICAL UNIT PLANS ON THE E4 SERIES SHEETS FOR ADDITIONAL INFORMATION REGARDING THE HVAC EQUIPMENT LOCATIONS AND CIRCUITING. COORDINATE WITH MECHANICAL INSTALLER.
- 16. COORDINATE WITH LANDSCAPE DESIGNER/INSTALLER FOR EXACT LOCATION AND POWER REQUIREMENTS OF ANY IRRIGATION CONTROLLER. PROVIDE POWER CONNECTION FROM PANEL 'M1' AND SLEEVE TO GRADE.
- 17. PROVIDE ALL CIRCUITING FOR LAUNDRY MACHINES FROM PANEL 'L1'.
- 18. ROOF TOP GFCI RECEPTACLES TO BE PROVIDED WITHIN A 25FT RADIUS OF ALL MECHANICAL EQUIPMENT PER CODE. LOCATIONS SHOWN REPRESENT THIS. FINAL LOCATION(S) SHALL BE FIELD DETERMINED AND INSTALLED PER CODE.
- 19. REFER TO 'T' SERIES SHEETS AND COORDINATE POWER REQUIREMENTS FOR THE FACP PANEL AND DEMARCATION BOARDS.
- 20. ELECTRICAL CONTRACTOR TO CONSULT THE MECHANICAL PLANS AND COORDINATE WITH THE MECHANICAL INSTALLER FOR ANY POWER CONNECTIONS NEEDED FOR DAMPERS. PROVIDE ANY ROUGH IN AND/OR FINAL ELECTRICAL CONNECTIONS.
- 21. PROVIDE ONE 20A, 120V CIRCUIT DISCONNECT SWITCH FOR RADON MITIGATION SYSTEM. CONSULT INSTALLER FOR EXACT REQUIREMENTS PRIOR TO ROUGH IN. CIRCUIT AS INDICATED.
- 22. PROVIDE ONE 20A, 120V, 1P CIRCUIT FOR "WAVEPOINT" SYSTEM PER OWNER'S DIRECTION. CONSULT ARCHITECT FOR EXACT LOCATION.



M Consulting Engineers
2007 S.E. Ash St.
Portland, OR 97214
PHN: (503) 234-0648
FAX: (503) 234-0677
TNC. WWW.MFIA-ENG.COM
CONTACT: DENISE TAYLOR



CARLETON HART ARCHITECTURE P.C.
830 SW 10th Avenue #200 Portland, OR 97205
503 243 2252
www.carletonhart.com

SUSAN EMMONS - NORTH BUILDING
680 NW 18TH AVENUE,
PORTLAND, OR
NORTHWEST HOUSING ALTERNATIVES
CONFORMANCE SET

FIRST FLOOR
POWER PLAN
PROJECT NO.
17004
05/28/2021
REVISIONS: A



1
E3.02

SECOND FLOOR POWER PLAN

SCALE: 1/8" = 1'-0"


GENERAL POWER NOTES:

- ALL PLANS ARE CONSIDERED DIAGRAMMATICAL. THEREFORE ALL EQUIPMENT SIZES AND DEVICE LOCATIONS ARE APPROXIMATE AND SUBJECT TO FIELD CONDITIONS AND PRODUCT APPROVAL.
- ELECTRICAL CONTRACTOR TO PROVIDE THERMOSTATS NOT SUPPLIED BY MECHANICAL CONTRACTOR. CONSULT MECHANICAL PLANS FOR ADDITIONAL INFORMATION.
- ELECTRICAL CONTRACTOR SHALL PROVIDE INSTALLATION AND FINAL CONNECTION OF THERMOSTATS. CONSULT MECHANICAL CONTRACTOR FOR EXACT REQUIREMENTS PRIOR TO ROUGH IN.
- REFER TO INTERIOR DECORATOR AND/OR ARCHITECTURAL DRAWINGS FOR DIMENSIONED LOCATION(S) AND ELEVATIONS OF FIXTURES & DEVICES. OTHER DEVICES SHOWN ON THE ELECTRICAL PLANS AND NOT INDICATED ON THE DECORATOR'S OR ARCHITECT'S DRAWINGS, SHALL BE INSTALLED AT STANDARD MOUNTING HEIGHT AS INDICATED THE SYMBOL LIST.
- REFER TO ENLARGED TYPICAL UNIT PLANS (E4 SERIES SHEETS) FOR TYPICAL POWER & LIGHTING LAYOUTS FOR THE APARTMENT UNITS.
- ELECTRICAL EQUIPMENT SHOWN IN THE ELECTRICAL ROOMS IS APPROXIMATE, BASED ON TYPICAL PRODUCTS. CONTRACTOR SHALL VERIFY ANY SUBMITTED EQUIPMENT WILL FIT WITHIN THE SPACE PROVIDED, PRIOR TO PRODUCT SUBMITTAL REVIEW.
- ELECTRICAL CONTRACTOR SHALL COORDINATE WITH THE LOW VOLTAGE ('T' SERIES) PLANS, INCLUDING FIRE ALARM AND SYSTEMS INSTALLER, AND PROVIDE ROUGH IN AS NEEDED.
- GENERAL PURPOSE CONVENIENCE RECEPTACLES LOCATED ON THE BUILDING EXTERIOR, OTHER THAN INTERIOR COURT YARD, SHALL BE EQUIPPED WITH A LOCKING, WEATHER PROOF COVER.

KEYED NOTES:

- GENERATOR DISCONNECT. SEE ONE-LINE DIAGRAM ON SHEET E1.11.
- PROVIDE ONE 20A, 120V, 1P CIRCUIT FOR GENERATOR REMOTE ANNUNCIATOR. FED FROM PANEL E1.
- PROVIDE ONE 20A, 120V, 1P POWER CONNECTION FOR BUILDING SIGNS. CIRCUIT AS INDICATED VIA TIME CLOCK. MOUNT JUNCTION BOX TIGHT TO CEILING (AT BUILDING INTERIOR), COORDINATING EXACT LOCATION WITH SIGN INSTALLER'S SLEEVE AND PER ARCHITECT'S DIRECTION.
- PROVIDE ONE 20A, 120V, 1P CIRCUIT FROM PANEL H1 FOR BUILDING ENTRY ACCESS CONTROL SYSTEM AND PROVIDE ROUGH IN AND WIRING TO ACCESS POINTS LOCATED ON PLANS. CONSULT WITH LOW VOLTAGE SYSTEMS INSTALLER AND THE 'T' SERIES SHEETS FOR ADDITIONAL INFORMATION.
- VERIFY ELEVATOR EQUIPMENT LOCATION AND ELECTRICAL REQUIREMENTS WITH ARCHITECT AND/OR ELEVATOR PROVIDER.
- PROVIDE ONE 20A, 120V, 1P CIRCUIT FROM PANEL H1 FOR AUTOMATIC DOOR OPENERS.
- ELECTRICAL SERVICE METER ROOMS SHALL HAVE OUTWARD SWING DOORS EQUIPPED WITH PANIC HARDWARE. PROVIDE A KEY BOX AT THE EXTERIOR FOR ELECTRICAL UTILITIES' 24/7 ACCESS.
- LOW VOLTAGE/COMMUNICATIONS SYSTEM DEMARCATION BOARD(S). COORDINATE LOCATIONS AND ELECTRICAL POWER REQUIREMENTS WITH THE TELECOM PLANS ('T' SERIES SHEETS) AND LOW VOLTAGE SYSTEMS INSTALLERS, AND PROVIDE ROUGH IN AND/OR FINAL ELECTRICAL POWER CONNECTIONS & DEVICES. REFER PANEL 'M1' SCHEDULE ON E1.12 FOR CIRCUITS.
- DEDICATED POWER FOR WHEELCHAIR LIFT. VERIFY EXACT REQUIREMENTS WITH MANUFACTURER/INSTALLER PRIOR TO ROUGH IN.
- DEDICATED 20A, 120V RECEPTACLE FOR PALLET JACK CHARGING.
- PROVIDE ONE 30A, 208V, 1PH ELECTRICAL CIRCUIT FOR TRASH COMPACTOR. FEED FROM PANEL M1.
- DEDICATED 20A, 120V RECEPTACLE FOR ELECTRIC BIKE CHARGING.
- EMERGENCY LIGHTING INVERTER. EVENLITE LM 535, 120V, 1P, OR APPROVED OTHER. REFER TO PANEL H1 FOR CIRCUITING.
- CONTINUOUS OPERATION EXHAUST FAN TO BE TIED INTO THE LIGHTING CIRCUIT FOR THIS AREA, AHEAD OF THE LIGHTING CONTROLS. CONSULT MECHANICAL PLANS AND/OR EQUIPMENT INSTALLER FOR EXACT POWER REQUIREMENTS PRIOR TO ROUGH IN.
- REFER TO TYPICAL UNIT PLANS ON THE E4 SERIES SHEETS FOR ADDITIONAL INFORMATION REGARDING THE HVAC EQUIPMENT LOCATIONS AND CIRCUITING. COORDINATE WITH MECHANICAL INSTALLER.
- COORDINATE WITH LANDSCAPE DESIGNER/INSTALLER FOR EXACT LOCATION AND POWER REQUIREMENTS OF ANY IRRIGATION CONTROLLER. PROVIDE POWER CONNECTION FROM PANEL 'M1' AND SLEEVE TO GRADE.
- PROVIDE ALL CIRCUITING FOR LAUNDRY MACHINES FROM PANEL 'L1'.
- ROOF TOP GFCI RECEPTACLES TO BE PROVIDED WITHIN A 25FT RADIUS OF ALL MECHANICAL EQUIPMENT PER CODE. LOCATIONS SHOWN REPRESENT THIS. FINAL LOCATION(S) SHALL BE FIELD DETERMINED AND INSTALLED PER CODE.
- REFER TO 'T' SERIES SHEETS AND COORDINATE POWER REQUIREMENTS FOR THE FACP PANEL AND DEMARCATION BOARDS.
- ELECTRICAL CONTRACTOR TO CONSULT THE MECHANICAL PLANS AND COORDINATE WITH THE MECHANICAL INSTALLER FOR ANY POWER CONNECTIONS NEEDED FOR DAMPERS. PROVIDE ANY ROUGH IN AND/OR FINAL ELECTRICAL CONNECTIONS.
- PROVIDE ONE 20A, 120V CIRCUIT DISCONNECT SWITCH FOR RADON MITIGATION SYSTEM. CONSULT INSTALLER FOR EXACT REQUIREMENTS PRIOR TO ROUGH IN. CIRCUIT AS INDICATED.
- PROVIDE ONE 20A, 120V, 1P CIRCUIT FOR "WAVEPOINT" SYSTEM PER OWNER'S DIRECTION. CONSULT ARCHITECT FOR EXACT LOCATION.

MFI Consulting Engineers
2007 S.E. Ash St.
Portland, OR 97214
PHN: (503) 234-0648
FAX: (503) 234-0677
INC. WWW.MFIA-ENG.COM
CONTACT: DENISE TAYLOR



CARLETON HART ARCHITECTURE P.C.
830 SW 10th Avenue #200 Portland, OR 97205
503.243.2252
www.carletonhart.com

SUSAN EMMONS - NORTH BUILDING
680 NW 18TH AVENUE,
PORTLAND, OR

NORTHWEST HOUSING ALTERNATIVES

CONFORMANCE SET



SECOND FLOOR
POWER PLAN

PROJECT NO.
17004

05/28/2021

REVISIONS: A

E3.02



1 THIRD FLOOR POWER PLAN
E3.03 SCALE: 1/8" = 1'-0"

GENERAL POWER NOTES:

- ALL PLANS ARE CONSIDERED DIAGRAMMATICAL. THEREFORE ALL EQUIPMENT SIZES AND DEVICE LOCATIONS ARE APPROXIMATE AND SUBJECT TO FIELD CONDITIONS AND PRODUCT APPROVAL.
- ELECTRICAL CONTRACTOR TO PROVIDE THERMOSTATS NOT SUPPLIED BY MECHANICAL CONTRACTOR. CONSULT MECHANICAL PLANS FOR ADDITIONAL INFORMATION.
- ELECTRICAL CONTRACTOR SHALL PROVIDE INSTALLATION AND FINAL CONNECTION OF THERMOSTATS. CONSULT MECHANICAL CONTRACTOR FOR EXACT REQUIREMENTS PRIOR TO ROUGH IN.
- REFER TO INTERIOR DECORATOR AND/OR ARCHITECTURAL DRAWINGS FOR DIMENSIONED LOCATION(S) AND ELEVATIONS OF FIXTURES & DEVICES. OTHER DEVICES SHOWN ON THE ELECTRICAL PLANS AND NOT INDICATED ON THE DECORATOR'S OR ARCHITECT'S DRAWINGS, SHALL BE INSTALLED AT STANDARD MOUNTING HEIGHT AS INDICATED THE SYMBOL LIST.
- REFER TO ENLARGED TYPICAL UNIT PLANS (E4 SERIES SHEETS) FOR TYPICAL POWER & LIGHTING LAYOUTS FOR THE APARTMENT UNITS.
- ELECTRICAL EQUIPMENT SHOWN IN THE ELECTRICAL ROOMS IS APPROXIMATE. BASED ON TYPICAL PRODUCTS. CONTRACTOR SHALL VERIFY ANY SUBMITTED EQUIPMENT WILL FIT WITHIN THE SPACE PROVIDED. PRIOR TO PRODUCT SUBMITTAL REVIEW.
- ELECTRICAL CONTRACTOR SHALL COORDINATE WITH THE LOW VOLTAGE ("T" SERIES) PLANS, INCLUDING FIRE ALARM AND SYSTEMS INSTALLER, AND PROVIDE ROUGH IN AS NEEDED.
- GENERAL PURPOSE CONVENIENCE RECEPTACLES LOCATED ON THE BUILDING EXTERIOR, OTHER THAN INTERIOR COURT YARD, SHALL BE EQUIPPED WITH A LOCKING, WEATHER PROOF COVER.

KEYED NOTES:

- GENERATOR DISCONNECT. SEE ONE-LINE DIAGRAM ON SHEET E1.11.
- PROVIDE ONE 20A, 120V, 1P CIRCUIT FOR GENERATOR REMOTE ANNUNCIATOR. FED FROM PANEL E1.
- PROVIDE ONE 20A, 120V, 1P POWER CONNECTION FOR BUILDING SIGNS. CIRCUIT AS INDICATED VIA TIME CLOCK. MOUNT JUNCTION BOX TIGHT TO CEILING (AT BUILDING INTERIOR), COORDINATING EXACT LOCATION WITH SIGN INSTALLER'S SLEEVE AND PER ARCHITECT'S DIRECTION.
- PROVIDE ONE 20A, 120V, 1P CIRCUIT FROM PANEL H1 FOR BUILDING ENTRY ACCESS CONTROL SYSTEM AND PROVIDE ROUGH IN AND WIRING TO ACCESS POINTS LOCATED ON PLANS. CONSULT WITH LOW VOLTAGE SYSTEMS INSTALLER AND THE "T" SERIES SHEETS FOR ADDITIONAL INFORMATION.
- VERIFY ELEVATOR EQUIPMENT LOCATION AND ELECTRICAL REQUIREMENTS WITH ARCHITECT AND/OR ELEVATOR PROVIDER.
- PROVIDE ONE 20A, 120V, 1P CIRCUIT FROM PANEL H1 FOR AUTOMATIC DOOR OPENERS.
- ELECTRICAL SERVICE METER ROOMS SHALL HAVE OUTWARD SWING DOORS EQUIPPED WITH PANIC HARDWARE. PROVIDE A KEY BOX AT THE EXTERIOR FOR ELECTRICAL UTILITIES' 24/7 ACCESS.
- LOW VOLTAGE/COMMUNICATIONS SYSTEM DEMARCATION BOARD(S). COORDINATE LOCATIONS AND ELECTRICAL POWER REQUIREMENTS WITH THE TELECOM PLANS ("T" SERIES SHEETS) AND LOW VOLTAGE SYSTEMS INSTALLERS, AND PROVIDE ROUGH IN AND/OR FINAL ELECTRICAL POWER CONNECTIONS & DEVICES. REFER PANEL "M1" SCHEDULE ON E1.12 FOR CIRCUITS.
- DEDICATED POWER FOR WHEELCHAIR LIFT. VERIFY EXACT REQUIREMENTS WITH MANUFACTURER/INSTALLER PRIOR TO ROUGH IN.
- DEDICATED 20A, 120V RECEPTACLE FOR PALLET JACK CHARGING.
- PROVIDE ONE 30A, 208V, 1PH ELECTRICAL CIRCUIT FOR TRASH COMPACTOR. FEED FROM PANEL M1.
- DEDICATED 20A, 120V RECEPTACLE FOR ELECTRIC BIKE CHARGING.
- EMERGENCY LIGHTING INVERTER. EVENLITE LM 535, 120V, 1P, OR APPROVED OTHER. REFER TO PANEL H1 FOR CIRCUITING.
- CONTINUOUS OPERATION EXHAUST FAN TO BE TIED INTO THE LIGHTING CIRCUIT FOR THIS AREA, AHEAD OF THE LIGHTING CONTROLS. CONSULT MECHANICAL PLANS AND/OR EQUIPMENT INSTALLER FOR EXACT POWER REQUIREMENTS PRIOR TO ROUGH IN.
- REFER TO TYPICAL UNIT PLANS ON THE E4 SERIES SHEETS FOR ADDITIONAL INFORMATION REGARDING THE HVAC EQUIPMENT LOCATIONS AND CIRCUITING. COORDINATE WITH MECHANICAL INSTALLER.
- COORDINATE WITH LANDSCAPE DESIGNER/INSTALLER FOR EXACT LOCATION AND POWER REQUIREMENTS OF ANY IRRIGATION CONTROLLER. PROVIDE POWER CONNECTION FROM PANEL "M1" AND SLEEVE TO GRADE.
- PROVIDE ALL CIRCUITING FOR LAUNDRY MACHINES FROM PANEL "L1".
- ROOF TOP GFCI RECEPTACLES TO BE PROVIDED WITHIN A 25FT RADIUS OF ALL MECHANICAL EQUIPMENT PER CODE. LOCATIONS SHOWN REPRESENT THIS. FINAL LOCATION(S) SHALL BE FIELD DETERMINED AND INSTALLED PER CODE.
- REFER TO "T" SERIES SHEETS AND COORDINATE POWER REQUIREMENTS FOR THE FACP PANEL AND DEMARCATION BOARDS.
- ELECTRICAL CONTRACTOR TO CONSULT THE MECHANICAL PLANS AND COORDINATE WITH THE MECHANICAL INSTALLER FOR ANY POWER CONNECTIONS NEEDED FOR DAMPERS. PROVIDE ANY ROUGH IN AND/OR FINAL ELECTRICAL CONNECTIONS.
- PROVIDE ONE 20A, 120V CIRCUIT DISCONNECT SWITCH FOR RADON MITIGATION SYSTEM. CONSULT INSTALLER FOR EXACT REQUIREMENTS PRIOR TO ROUGH IN. CIRCUIT AS INDICATED.
- PROVIDE ONE 20A, 120V, 1P CIRCUIT FOR "WAVEPOINT" SYSTEM PER OWNER'S DIRECTION. CONSULT ARCHITECT FOR EXACT LOCATION.

M Consulting Engineers
2007 S.E. Ash St.
Portland, OR 97214
PH: (503) 234-0648
FAX: (503) 234-0677
TNC. WWW.MFIA-ENG.COM
CONTACT: DENISE TAYLOR



CARLETON HART ARCHITECTURE P.C.
830 SW 10th Avenue #200 Portland, OR 97205
503.243.2252
www.carletonhart.com



SUSAN EMMONS - NORTH BUILDING
680 NW 18TH AVENUE,
PORTLAND, OR
NORTHWEST HOUSING ALTERNATIVES
CONFORMANCE SET

THIRD FLOOR
POWER PLAN

PROJECT NO.
17004
05/28/2021

REVISIONS: A

E3.03



1 FOURTH FLOOR POWER PLAN
E3.04 SCALE: 1/8" = 1'-0"

GENERAL POWER NOTES:

- A. ALL PLANS ARE CONSIDERED DIAGRAMMATICAL. THEREFORE ALL EQUIPMENT SIZES AND DEVICE LOCATIONS ARE APPROXIMATE AND SUBJECT TO FIELD CONDITIONS AND PRODUCT APPROVAL.
- B. ELECTRICAL CONTRACTOR TO PROVIDE THERMOSTATS NOT SUPPLIED BY MECHANICAL CONTRACTOR. CONSULT MECHANICAL PLANS FOR ADDITIONAL INFORMATION.
- C. ELECTRICAL CONTRACTOR SHALL PROVIDE INSTALLATION AND FINAL CONNECTION OF THERMOSTATS. CONSULT MECHANICAL CONTRACTOR FOR EXACT REQUIREMENTS PRIOR TO ROUGH IN.
- D. REFER TO INTERIOR DECORATOR AND/OR ARCHITECTURAL DRAWINGS FOR DIMENSIONED LOCATION(S) AND ELEVATIONS OF FIXTURES & DEVICES. OTHER DEVICES SHOWN ON THE ELECTRICAL PLANS AND NOT INDICATED ON THE DECORATOR'S OR ARCHITECT'S DRAWINGS, SHALL BE INSTALLED AT STANDARD MOUNTING HEIGHT AS INDICATED THE SYMBOL LIST.
- E. REFER TO ENLARGED TYPICAL UNIT PLANS (E4 SERIES SHEETS) FOR TYPICAL POWER & LIGHTING LAYOUTS FOR THE APARTMENT UNITS.
- F. ELECTRICAL EQUIPMENT SHOWN IN THE ELECTRICAL ROOMS IS APPROXIMATE, BASED ON TYPICAL PRODUCTS. CONTRACTOR SHALL VERIFY ANY SUBMITTED EQUIPMENT WILL FIT WITHIN THE SPACE PROVIDED, PRIOR TO PRODUCT SUBMITTAL REVIEW.
- G. ELECTRICAL CONTRACTOR SHALL COORDINATE WITH THE LOW VOLTAGE ('T' SERIES) PLANS, INCLUDING FIRE ALARM AND SYSTEMS INSTALLER, AND PROVIDE ROUGH IN AS NEEDED.
- H. GENERAL PURPOSE CONVENIENCE RECEPTACLES LOCATED ON THE BUILDING EXTERIOR, OTHER THAN INTERIOR COURT YARD, SHALL BE EQUIPPED WITH A LOCKING, WEATHER PROOF COVER.

KEYED NOTES:

- 1. GENERATOR DISCONNECT. SEE ONE-LINE DIAGRAM ON SHEET E1.11.
- 2. PROVIDE ONE 20A, 120V, 1P CIRCUIT FOR GENERATOR REMOTE ANNUNCIATOR. FED FROM PANEL E1.
- 3. PROVIDE ONE 20A, 120V, 1P POWER CONNECTION FOR BUILDING SIGNS. CIRCUIT AS INDICATED VIA TIME CLOCK. MOUNT JUNCTION BOX TIGHT TO CEILING (AT BUILDING INTERIOR), COORDINATING EXACT LOCATION WITH SIGN INSTALLER'S SLEEVE AND PER ARCHITECT'S DIRECTION.
- 4. PROVIDE ONE 20A, 120V, 1P CIRCUIT FROM PANEL H1 FOR BUILDING ENTRY ACCESS CONTROL SYSTEM AND PROVIDE ROUGH IN AND WIRING TO ACCESS POINTS LOCATED ON PLANS. CONSULT WITH LOW VOLTAGE SYSTEMS INSTALLER AND THE 'T' SERIES SHEETS FOR ADDITIONAL INFORMATION.
- 5. VERIFY ELEVATOR EQUIPMENT LOCATION AND ELECTRICAL REQUIREMENTS WITH ARCHITECT AND/OR ELEVATOR PROVIDER.
- 6. PROVIDE ONE 20A, 120V, 1P CIRCUIT FROM PANEL H1 FOR AUTOMATIC DOOR OPENERS.
- 7. ELECTRICAL SERVICE METER ROOMS SHALL HAVE OUTWARD SWING DOORS EQUIPPED WITH PANIC HARDWARE. PROVIDE A KEY BOX AT THE EXTERIOR FOR ELECTRICAL UTILITIES' 24/7 ACCESS.
- 8. LOW VOLTAGE/COMMUNICATIONS SYSTEM DEMARCATION BOARD(S). COORDINATE LOCATIONS AND ELECTRICAL POWER REQUIREMENTS WITH THE TELECOM PLANS ('T' SERIES SHEETS) AND LOW VOLTAGE SYSTEMS INSTALLERS, AND PROVIDE ROUGH IN AND/OR FINAL ELECTRICAL POWER CONNECTIONS & DEVICES. REFER PANEL 'M1' SCHEDULE ON E1.12 FOR CIRCUITS.
- 9. DEDICATED POWER FOR WHEELCHAIR LIFT. VERIFY EXACT REQUIREMENTS WITH MANUFACTURER/INSTALLER PRIOR TO ROUGH IN.
- 10. DEDICATED 20A, 120V RECEPTACLE FOR PALLET JACK CHARGING.
- 11. PROVIDE ONE 30A, 208V, 1PH ELECTRICAL CIRCUIT FOR TRASH COMPACTOR. FEED FROM PANEL M1.
- 12. DEDICATED 20A, 120V RECEPTACLE FOR ELECTRIC BIKE CHARGING.
- 13. EMERGENCY LIGHTING INVERTER, EVENLITE LM 535, 120V, 1P, OR APPROVED OTHER. REFER TO PANEL H1 FOR CIRCUITING.
- 14. CONTINUOUS OPERATION EXHAUST FAN TO BE TIED INTO THE LIGHTING CIRCUIT FOR THIS AREA, AHEAD OF THE LIGHTING CONTROLS. CONSULT MECHANICAL PLANS AND/OR EQUIPMENT INSTALLER FOR EXACT POWER REQUIREMENTS PRIOR TO ROUGH IN.
- 15. REFER TO TYPICAL UNIT PLANS ON THE E4 SERIES SHEETS FOR ADDITIONAL INFORMATION REGARDING THE HVAC EQUIPMENT LOCATIONS AND CIRCUITING. COORDINATE WITH MECHANICAL INSTALLER.
- 16. COORDINATE WITH LANDSCAPE DESIGNER/INSTALLER FOR EXACT LOCATION AND POWER REQUIREMENTS OF ANY IRRIGATION CONTROLLER. PROVIDE POWER CONNECTION FROM PANEL 'M1' AND SLEEVE TO GRADE.
- 17. PROVIDE ALL CIRCUITING FOR LAUNDRY MACHINES FROM PANEL 'L1'.
- 18. ROOF TOP GFCI RECEPTACLES TO BE PROVIDED WITHIN A 25FT RADIUS OF ALL MECHANICAL EQUIPMENT PER CODE. LOCATIONS SHOWN REPRESENT THIS. FINAL LOCATION(S) SHALL BE FIELD DETERMINED AND INSTALLED PER CODE.
- 19. REFER TO 'T' SERIES SHEETS AND COORDINATE POWER REQUIREMENTS FOR THE FACP PANEL AND DEMARCATION BOARDS.
- 20. ELECTRICAL CONTRACTOR TO CONSULT THE MECHANICAL PLANS AND COORDINATE WITH THE MECHANICAL INSTALLER FOR ANY POWER CONNECTIONS NEEDED FOR DAMPERS. PROVIDE ANY ROUGH IN AND/OR FINAL ELECTRICAL CONNECTIONS.
- 21. PROVIDE ONE 20A, 120V CIRCUIT DISCONNECT SWITCH FOR RADON MITIGATION SYSTEM. CONSULT INSTALLER FOR EXACT REQUIREMENTS PRIOR TO ROUGH IN. CIRCUIT AS INDICATED.
- 22. PROVIDE ONE 20A, 120V, 1P CIRCUIT FOR "WAVEPOINT" SYSTEM PER OWNER'S DIRECTION. CONSULT ARCHITECT FOR EXACT LOCATION.

M Consulting Engineers
2007 S.E. Ash St.
Portland, OR 97214
PHN: (503) 234-0648
FAX: (503) 234-0677
INC. WWW.MFIA-ENG.COM
CONTACT: DENISE TAYLOR





CARLETON HART ARCHITECTURE P.C.
830 SW 10th Avenue #200 Portland, Oregon 97205
www.carletonhart.com
503 243 2252

SUSAN EMMONS - NORTH BUILDING
680 NW 18TH AVENUE,
PORTLAND, OR
NORTHWEST HOUSING ALTERNATIVES
CONFORMANCE SET

FOURTH FLOOR
POWER PLAN
PROJECT NO.
17004
05/28/2021

REVISIONS: A

COPYRIGHT - CARLETON HART ARCHITECTURE DO NOT REPRODUCE WITHOUT PERMISSION



1
E3.05

FIFTH FLOOR POWER PLAN
SCALE: 1/8" = 1'-0"

GENERAL POWER NOTES:

- ALL PLANS ARE CONSIDERED DIAGRAMMATICAL. THEREFORE ALL EQUIPMENT SIZES AND DEVICE LOCATIONS ARE APPROXIMATE AND SUBJECT TO FIELD CONDITIONS AND PRODUCT APPROVAL.
- ELECTRICAL CONTRACTOR TO PROVIDE THERMOSTATS NOT SUPPLIED BY MECHANICAL CONTRACTOR. CONSULT MECHANICAL PLANS FOR ADDITIONAL INFORMATION.
- ELECTRICAL CONTRACTOR SHALL PROVIDE INSTALLATION AND FINAL CONNECTION OF THERMOSTATS. CONSULT MECHANICAL CONTRACTOR FOR EXACT REQUIREMENTS PRIOR TO ROUGH IN.
- REFER TO INTERIOR DECORATOR AND/OR ARCHITECTURAL DRAWINGS FOR DIMENSIONED LOCATION(S) AND ELEVATIONS OF FIXTURES & DEVICES. OTHER DEVICES SHOWN ON THE ELECTRICAL PLANS AND NOT INDICATED ON THE DECORATOR'S OR ARCHITECT'S DRAWINGS, SHALL BE INSTALLED AT STANDARD MOUNTING HEIGHT AS INDICATED THE SYMBOL LIST.
- REFER TO ENLARGED TYPICAL UNIT PLANS (E4 SERIES SHEETS) FOR TYPICAL POWER & LIGHTING LAYOUTS FOR THE APARTMENT UNITS.
- ELECTRICAL EQUIPMENT SHOWN IN THE ELECTRICAL ROOMS IS APPROXIMATE, BASED ON TYPICAL PRODUCTS. CONTRACTOR SHALL VERIFY ANY SUBMITTED EQUIPMENT WILL FIT WITHIN THE SPACE PROVIDED, PRIOR TO PRODUCT SUBMITTAL REVIEW.
- ELECTRICAL CONTRACTOR SHALL COORDINATE WITH THE LOW VOLTAGE ('T' SERIES) PLANS, INCLUDING FIRE ALARM AND SYSTEMS INSTALLER, AND PROVIDE ROUGH IN AS NEEDED.
- GENERAL PURPOSE CONVENIENCE RECEPTACLES LOCATED ON THE BUILDING EXTERIOR, OTHER THAN INTERIOR COURT YARD, SHALL BE EQUIPPED WITH A LOCKING, WEATHER PROOF COVER.

KEYED NOTES:

- GENERATOR DISCONNECT. SEE ONE-LINE DIAGRAM ON SHEET E1.11.
- PROVIDE ONE 20A, 120V, 1P CIRCUIT FOR GENERATOR REMOTE ANNUNCIATOR. FED FROM PANEL E1.
- PROVIDE ONE 20A, 120V, 1P POWER CONNECTION FOR BUILDING SIGNS. CIRCUIT AS INDICATED VIA TIME CLOCK. MOUNT JUNCTION BOX TIGHT TO CEILING (AT BUILDING INTERIOR), COORDINATING EXACT LOCATION WITH SIGN INSTALLER'S SLEEVE AND PER ARCHITECT'S DIRECTION.
- PROVIDE ONE 20A, 120V, 1P CIRCUIT FROM PANEL H1 FOR BUILDING ENTRY ACCESS CONTROL SYSTEM AND PROVIDE ROUGH IN AND WIRING TO ACCESS POINTS LOCATED ON PLANS. CONSULT WITH LOW VOLTAGE SYSTEMS INSTALLER AND THE 'T' SERIES SHEETS FOR ADDITIONAL INFORMATION.
- VERIFY ELEVATOR EQUIPMENT LOCATION AND ELECTRICAL REQUIREMENTS WITH ARCHITECT AND/OR ELEVATOR PROVIDER.
- PROVIDE ONE 20A, 120V, 1P CIRCUIT FROM PANEL H1 FOR AUTOMATIC DOOR OPENERS.
- ELECTRICAL SERVICE METER ROOMS SHALL HAVE OUTWARD SWING DOORS EQUIPPED WITH PANIC HARDWARE. PROVIDE A KEY BOX AT THE EXTERIOR FOR ELECTRICAL UTILITIES' 24/7 ACCESS.
- LOW VOLTAGE/COMMUNICATIONS SYSTEM DEMARCATION BOARD(S). COORDINATE LOCATIONS AND ELECTRICAL POWER REQUIREMENTS WITH THE TELECOM PLANS ('T' SERIES SHEETS) AND LOW VOLTAGE SYSTEMS INSTALLERS, AND PROVIDE ROUGH IN AND/OR FINAL ELECTRICAL POWER CONNECTIONS & DEVICES. REFER PANEL 'M1' SCHEDULE ON E1.12 FOR CIRCUITS.
- DEDICATED POWER FOR WHEELCHAIR LIFT. VERIFY EXACT REQUIREMENTS WITH MANUFACTURER/INSTALLER PRIOR TO ROUGH IN.
- DEDICATED 20A, 120V RECEPTACLE FOR PALLET JACK CHARGING.
- PROVIDE ONE 30A, 208V, 1PH ELECTRICAL CIRCUIT FOR TRASH COMPACTOR. FEED FROM PANEL M1.
- DEDICATED 20A, 120V RECEPTACLE FOR ELECTRIC BIKE CHARGING.
- EMERGENCY LIGHTING INVERTER. EVENLITE LM 535, 120V, 1P, OR APPROVED OTHER. REFER TO PANEL H1 FOR CIRCUITING.
- CONTINUOUS OPERATION EXHAUST FAN TO BE TIED INTO THE LIGHTING CIRCUIT FOR THIS AREA, AHEAD OF THE LIGHTING CONTROLS. CONSULT MECHANICAL PLANS AND/OR EQUIPMENT INSTALLER FOR EXACT POWER REQUIREMENTS PRIOR TO ROUGH IN.
- REFER TO TYPICAL UNIT PLANS ON THE E4 SERIES SHEETS FOR ADDITIONAL INFORMATION REGARDING THE HVAC EQUIPMENT LOCATIONS AND CIRCUITING. COORDINATE WITH MECHANICAL INSTALLER.
- COORDINATE WITH LANDSCAPE DESIGNER/INSTALLER FOR EXACT LOCATION AND POWER REQUIREMENTS OF ANY IRRIGATION CONTROLLER. PROVIDE POWER CONNECTION FROM PANEL 'M1' AND SLEEVE TO GRADE.
- PROVIDE ALL CIRCUITING FOR LAUNDRY MACHINES FROM PANEL 'L1'.
- ROOF TOP GFCI RECEPTACLES TO BE PROVIDED WITHIN A 25FT RADIUS OF ALL MECHANICAL EQUIPMENT PER CODE. LOCATIONS SHOWN REPRESENT THIS. FINAL LOCATION(S) SHALL BE FIELD DETERMINED AND INSTALLED PER CODE.
- REFER TO 'T' SERIES SHEETS AND COORDINATE POWER REQUIREMENTS FOR THE FACP PANEL AND DEMARCATION BOARDS.
- ELECTRICAL CONTRACTOR TO CONSULT THE MECHANICAL PLANS AND COORDINATE WITH THE MECHANICAL INSTALLER FOR ANY POWER CONNECTIONS NEEDED FOR DAMPERS. PROVIDE ANY ROUGH IN AND/OR FINAL ELECTRICAL CONNECTIONS.
- PROVIDE ONE 20A, 120V CIRCUIT DISCONNECT SWITCH FOR RADON MITIGATION SYSTEM. CONSULT INSTALLER FOR EXACT REQUIREMENTS PRIOR TO ROUGH IN. CIRCUIT AS INDICATED.
- PROVIDE ONE 20A, 120V, 1P CIRCUIT FOR "WAVEPOINT" SYSTEM PER OWNER'S DIRECTION. CONSULT ARCHITECT FOR EXACT LOCATION.

MFA Consulting Engineers
2007 S.E. Ash St.
Portland, OR 97214
PHN: (503) 234-0648
FAX: (503) 234-0677
INC. WWW.MFA-ENG.COM
CONTACT: DENISE TAYLOR



CARLETON HART ARCHITECTURE P.C.
830 SW 10th Avenue #200 Portland, Oregon 97205
503.243.2252
www.carletonhart.com

SUSAN EMMONS - NORTH BUILDING
680 NW 18TH AVENUE,
PORTLAND, OR
NORTHWEST HOUSING ALTERNATIVES


CONFORMANCE SET

FIFTH FLOOR
POWER PLAN

PROJECT NO.
17004
05/28/2021



REVISIONS:

E3.05



3.06

COPYRIGHT - CANTELON PART ARCHITECTURE DO NOT REPRODUCE WITHOUT PERMISSION



1 ROOF LEVEL POWER PLAN
E3.07 SCALE: 1/8" = 1'-0"


GENERAL POWER NOTES:

- ALL PLANS ARE CONSIDERED DIAGRAMMATICAL. THEREFORE ALL EQUIPMENT SIZES AND DEVICE LOCATIONS ARE APPROXIMATE AND SUBJECT TO FIELD CONDITIONS AND PRODUCT APPROVAL.
- ELECTRICAL CONTRACTOR TO PROVIDE THERMOSTATS NOT SUPPLIED BY MECHANICAL CONTRACTOR. CONSULT MECHANICAL PLANS FOR ADDITIONAL INFORMATION.
- ELECTRICAL CONTRACTOR SHALL PROVIDE INSTALLATION AND FINAL CONNECTION OF THERMOSTATS. CONSULT MECHANICAL CONTRACTOR FOR EXACT REQUIREMENTS PRIOR TO ROUGH IN.
- REFER TO INTERIOR DECORATOR AND/OR ARCHITECTURAL DRAWINGS FOR DIMENSIONED LOCATION(S) AND ELEVATIONS OF FIXTURES & DEVICES. OTHER DEVICES SHOWN ON THE ELECTRICAL PLANS AND NOT INDICATED ON THE DECORATOR'S OR ARCHITECT'S DRAWINGS, SHALL BE INSTALLED AT STANDARD MOUNTING HEIGHT AS INDICATED THE SYMBOL LIST.
- REFER TO ENLARGED TYPICAL UNIT PLANS (E4 SERIES SHEETS) FOR TYPICAL POWER & LIGHTING LAYOUTS FOR THE APARTMENT UNITS.
- ELECTRICAL EQUIPMENT SHOWN IN THE ELECTRICAL ROOMS IS APPROXIMATE, BASED ON TYPICAL PRODUCTS. CONTRACTOR SHALL VERIFY ANY SUBMITTED EQUIPMENT WILL FIT WITHIN THE SPACE PROVIDED, PRIOR TO PRODUCT SUBMITTAL REVIEW.
- ELECTRICAL CONTRACTOR SHALL COORDINATE WITH THE LOW VOLTAGE ('T' SERIES) PLANS, INCLUDING FIRE ALARM AND SYSTEMS INSTALLER, AND PROVIDE ROUGH IN AS NEEDED.
- GENERAL PURPOSE CONVENIENCE RECEPTACLES LOCATED ON THE BUILDING EXTERIOR, OTHER THAN INTERIOR COURT YARD, SHALL BE EQUIPPED WITH A LOCKING, WEATHER PROOF COVER.

KEYED NOTES:

- GENERATOR DISCONNECT. SEE ONE-LINE DIAGRAM ON SHEET E1.11.
- PROVIDE ONE 20A, 120V, 1P CIRCUIT FOR GENERATOR REMOTE ANNUNCIATOR. FED FROM PANEL E1.
- PROVIDE ONE 20A, 120V, 1P POWER CONNECTION FOR BUILDING SIGNS. CIRCUIT AS INDICATED VIA TIME CLOCK. MOUNT JUNCTION BOX TIGHT TO CEILING (AT BUILDING INTERIOR), COORDINATING EXACT LOCATION WITH SIGN INSTALLER'S SLEEVE AND PER ARCHITECT'S DIRECTION.
- PROVIDE ONE 20A, 120V, 1P CIRCUIT FROM PANEL H1 FOR BUILDING ENTRY ACCESS CONTROL SYSTEM AND PROVIDE ROUGH IN AND WIRING TO ACCESS POINTS LOCATED ON PLANS. CONSULT WITH LOW VOLTAGE SYSTEMS INSTALLER AND THE 'T' SERIES SHEETS FOR ADDITIONAL INFORMATION.
- VERIFY ELEVATOR EQUIPMENT LOCATION AND ELECTRICAL REQUIREMENTS WITH ARCHITECT AND/OR ELEVATOR PROVIDER.
- PROVIDE ONE 20A, 120V, 1P CIRCUIT FROM PANEL H1 FOR AUTOMATIC DOOR OPENERS.
- ELECTRICAL SERVICE METER ROOMS SHALL HAVE OUTWARD SWING DOORS EQUIPPED WITH PANIC HARDWARE. PROVIDE A KEY BOX AT THE EXTERIOR FOR ELECTRICAL UTILITIES' 24/7 ACCESS.
- LOW VOLTAGE/COMMUNICATIONS SYSTEM DEMARCATION BOARD(S). COORDINATE LOCATIONS AND ELECTRICAL POWER REQUIREMENTS WITH THE TELECOM PLANS ('T' SERIES SHEETS) AND LOW VOLTAGE SYSTEMS INSTALLERS, AND PROVIDE ROUGH IN AND/OR FINAL ELECTRICAL POWER CONNECTIONS & DEVICES. REFER PANEL 'M1' SCHEDULE ON E1.12 FOR CIRCUITS.
- DEDICATED POWER FOR WHEELCHAIR LIFT. VERIFY EXACT REQUIREMENTS WITH MANUFACTURER/INSTALLER PRIOR TO ROUGH IN.
- DEDICATED 20A, 120V RECEPTACLE FOR PALLET JACK CHARGING.
- PROVIDE ONE 30A, 208V, 1PH ELECTRICAL CIRCUIT FOR TRASH COMPACTOR. FEED FROM PANEL M1.
- DEDICATED 20A, 120V RECEPTACLE FOR ELECTRIC BIKE CHARGING.
- EMERGENCY LIGHTING INVERTER. EVENLITE LM 535, 120V, 1P, OR APPROVED OTHER. REFER TO PANEL H1 FOR CIRCUITING.
- CONTINUOUS OPERATION EXHAUST FAN TO BE TIED INTO THE LIGHTING CIRCUIT FOR THIS AREA, AHEAD OF THE LIGHTING CONTROLS. CONSULT MECHANICAL PLANS AND/OR EQUIPMENT INSTALLER FOR EXACT POWER REQUIREMENTS PRIOR TO ROUGH IN.
- REFER TO TYPICAL UNIT PLANS ON THE E4 SERIES SHEETS FOR ADDITIONAL INFORMATION REGARDING THE HVAC EQUIPMENT LOCATIONS AND CIRCUITING. COORDINATE WITH MECHANICAL INSTALLER.
- COORDINATE WITH LANDSCAPE DESIGNER/INSTALLER FOR EXACT LOCATION AND POWER REQUIREMENTS OF ANY IRRIGATION CONTROLLER. PROVIDE POWER CONNECTION FROM PANEL 'M1' AND SLEEVE TO GRADE.
- PROVIDE ALL CIRCUITING FOR LAUNDRY MACHINES FROM PANEL 'L1'.
- ROOF TOP GFCI RECEPTACLES TO BE PROVIDED WITHIN A 25FT RADIUS OF ALL MECHANICAL EQUIPMENT PER CODE. LOCATIONS SHOWN REPRESENT THIS. FINAL LOCATION(S) SHALL BE FIELD DETERMINED AND INSTALLED PER CODE.
- REFER TO 'T' SERIES SHEETS AND COORDINATE POWER REQUIREMENTS FOR THE FACP PANEL AND DEMARCATION BOARDS.
- ELECTRICAL CONTRACTOR TO CONSULT THE MECHANICAL PLANS AND COORDINATE WITH THE MECHANICAL INSTALLER FOR ANY POWER CONNECTIONS NEEDED FOR DAMPERS. PROVIDE ANY ROUGH IN AND/OR FINAL ELECTRICAL CONNECTIONS.
- PROVIDE ONE 20A, 120V CIRCUIT DISCONNECT SWITCH FOR RADON MITIGATION SYSTEM. CONSULT INSTALLER FOR EXACT REQUIREMENTS PRIOR TO ROUGH IN. CIRCUIT AS INDICATED.
- PROVIDE ONE 20A, 120V, 1P CIRCUIT FOR "WAVEPOINT" SYSTEM PER OWNER'S DIRECTION. CONSULT ARCHITECT FOR EXACT LOCATION.

MFA Consulting Engineers
2007 S.E. Ash St.
Portland, OR 97214
PHN: (503) 234-0648
FAX: (503) 234-0677
TNC. WWW.MFA-ENG.COM
CONTACT: DENISE TAYLOR



CARLETON HART ARCHITECTURE P.C.
830 SW 10th Avenue #200 Portland, Oregon 97205
503 243 2252
www.carletonhart.com

SUSAN EMMONS - NORTH BUILDING
680 NW 18th Avenue,
PORTLAND, OR

NORTHWEST HOUSING ALTERNATIVES

CONFORMANCE SET


ROOF LEVEL
POWER PLAN

PROJECT NO.
17004


05/28/2021

REVISIONS: A


E3.07




1
E4.01
UNIT TYPE 1-STUDIO
TYPICAL LIGHTING PLAN
SCALE: 1/4" = 1'-0"




3
E4.01
UNIT TYPE 2-STUDIO
TYPICAL LIGHTING PLAN
SCALE: 1/4" = 1'-0"




5
E4.01
UNIT TYPE 3C-STUDIO
TYPICAL LIGHTING PLAN
SCALE: 1/4" = 1'-0"




7
E4.01
UNIT TYPE 4-STUDIO
TYPICAL LIGHTING PLAN
SCALE: 1/4" = 1'-0"




2
E4.01
UNIT TYPE 1-STUDIO
TYPICAL POWER PLAN
SCALE: 1/4" = 1'-0"



4
E4.01
UNIT TYPE 2-STUDIO
TYPICAL POWER PLAN
SCALE: 1/4" = 1'-0"



6
E4.01
UNIT TYPE 3C-STUDIO
TYPICAL POWER PLAN
SCALE: 1/4" = 1'-0"



8
E4.01
UNIT TYPE 4-STUDIO
TYPICAL POWER PLAN
SCALE: 1/4" = 1'-0"


GENERAL NOTES:

- ALL PLANS ARE DIAGRAMMATICAL. CONSULT ARCHITECTURAL PLANS FOR EXACT LOCATION OF ALL DEVICES AND FIXTURES.
- REFER TO SHEET E1.14 FOR TYPICAL UNIT LOAD CENTER DIRECTORIES.
- ALL LIGHT SWITCHES SHALL BE ROCKER STYLE, SUCH AS LEVITON DECORA, OR APPROVED EQUAL.
- REFER TO ARCHITECTURAL REFLECTED CEILING PLANS FOR EXACT FIXTURE LOCATIONS. CONSULT INTERIOR DESIGNER FOR MOUNTING HEIGHTS NOT SPECIFIED.
- KITCHEN RECEPTACLES LOCATED IN ISLANDS OR PENINSULAS WHERE THE BACK SPLASH WILL NOT ACCOMMODATE VERTICAL PLACEMENT OR THE DUPLEX RECEPTACLE, THE CONTRACTOR SHALL ROTATE THE DEVICE 90 DEGREES SO THAT THE RECEPTACLE IS INSTALLED HORIZONTALLY.
- REFER TO DETAILS ON SHEET E1.15 FOR ADDITIONAL INFORMATION REGARDING ADA REACH REQUIREMENTS FOR RECEPTACLE AND SWITCH MOUNTING HEIGHT.
- STANDARD RECEPTACLE MOUNTING HEIGHT IS 18" A.F.F. UNLESS OTHERWISE SPECIFIED. RECEPTACLES LOCATED BELOW WINDOW SILLS SHALL NOT BE LESS THE 15" A.F.F.
- ALL PLANS ARE DIAGRAMMATICAL. CONSULT ARCHITECTURAL PLANS AND ELEVATIONS FOR EXACT LOCATION AND MOUNTING HEIGHT OF ALL DEVICES AND FIXTURES.
- REFER TO SHEET E1.13 FOR TYPICAL UNIT LOAD CENTER DIRECTORIES.
- RECEPTACLE FOR PTHP UNIT SHALL BE LOCATED BELOW THE UNIT, NEAR THE BASE OF THE WALL SUCH THAT THE CORD SET IS CONCEALED AS MUCH AS POSSIBLE. COORDINATE INSTALLATION WITH THE MECHANICAL INSTALLER.
- COORDINATE WITH THE 'T' SERIES SHEETS AND PROVIDE ROUGH IN FOR LOW VOLTAGE SYSTEMS SUCH AS TELEVISION CABLE OUTLETS AND FIRE ALARM DEVICES.

KEYED NOTES:

- PROVIDE WIRE CONNECTION FOR THERMOSTAT(S). COORDINATE WITH MECHANICAL INSTALLER FOR EXACT LOCATION AND POWER REQUIREMENTS PRIOR TO ROUGH IN.
- NOT USED.
- PROVIDE ONE 15A, RECEPTACLE CIRCUIT FROM TENANT LOAD CENTER FOR TELECOM SMART PANEL. COORDINATE WORK WITH SERVICE PROVIDER FOR EXACT LOCATION AND FINAL CONNECTION.
- REFER TO TYPICAL BATHROOM SWITCHING DETAILS ON SHEET E1.15.
- SWITCHED RECEPTACLE. SEE TYPICAL LIGHTING PLAN FOR SWITCH LOCATION.
- COMBINATION EXHAUST FAN & LIGHT SHALL BE TIED INTO THE BATHROOM LIGHTING CIRCUIT. VERIFY EXACT LOCATION W/MECHANICAL INSTALLER PRIOR TO ROUGH IN.
- REFER TO E3 SHEETS FOR HVAC EQUIPMENT LOCATION(S) & TYPE IN EACH UNIT. REVIEW & COORDINATE WITH THE MECHANICAL PLANS AND THE MECHANICAL INSTALLER FOR EXACT LOCATIONS AND ELECTRICAL REQUIREMENTS PRIOR TO ROUGH IN. PROVIDE CIRCUITING AS INDICATED. INDOOR HEAT PUMP UNITS ARE INTERCONNECTED WITH OUTDOOR UNIT LOCATED ON THE ROOF. POWER CONNECTION FOR PTHP UNIT SHALL BE LOCATED BELOW THE UNIT, NEAR THE BASE OF THE WALL SUCH THAT THE CORD SET IS CONCEALED AS MUCH AS POSSIBLE. CONSULT MECHANICAL PLANS TO DETERMINE WHETHER PTHP UNITS ARE CORD & PLUG OR HARDWIRED AND PROVIDE THE APPROPRIATE CONNECTION TYPE.
- 120V, 1P POWER CONNECTION FOR WATER METER. COORDINATE EXACT LOCATION WITH PLUMBING INSTALLER AND TIE INTO BATHROOM POWER CIRCUIT.
- PROVIDE 120V, 20A POWER FOR CEILING MOUNTED FAN/LIGHT COMBO AND TIE INTO BATHROOM LIGHTING CIRCUIT AND SWITCHING. REFER TO SHEET E1.15 FOR SWITCHING DIAGRAMS. REFER TO MECHANICAL PLANS FOR ADDITIONAL INFORMATION ON THE FAN AND COORDINATE INSTALLATION PRIOR TO ROUGH IN.

MFA
INC.
Consulting Engineers
2007 S.E. Ash St.
Portland, OR 97214
PHN: (503) 234-0548
FAX: (503) 234-0677
WWW.MFIA-ENG.COM
CONTACT: DENISE TAYLOR



CARLETON HART ARCHITECTURE P.C.
830 SW 10th Avenue #200 Portland, Oregon 97205
503.243.2252
www.carletonhart.com

SUSAN EMMONS - NORTH BUILDING
680 NW 18TH AVENUE,
PORTLAND, OR

NORTHWEST HOUSING ALTERNATIVES


CONFORMANCE SET

TYPICAL ENLARGED
UNIT PLANS


PROJECT NO.
17004
05/28/2021

REVISIONS:


E4.01



UNIT TYPE 5-STUDIO
TYPICAL LIGHTING PLAN
1
E4.02 SCALE: 1/4" = 1'-0"



UNIT TYPE 6B-STUDIO
TYPICAL LIGHTING PLAN
3
E4.02 SCALE: 1/4" = 1'-0"




UNIT TYPE 7-STUDIO
TYPICAL LIGHTING PLAN
5
E4.02 SCALE: 1/4" = 1'-0"

GENERAL NOTES:


- ALL PLANS ARE DIAGRAMMATICAL. CONSULT ARCHITECTURAL PLANS FOR EXACT LOCATION OF ALL DEVICES AND FIXTURES.
- REFER TO SHEET E1.14 FOR TYPICAL UNIT LOAD CENTER DIRECTORIES.
- ALL LIGHT SWITCHES SHALL BE ROCKER STYLE, SUCH AS LEVITON DECORA, OR APPROVED EQUAL.
- REFER TO ARCHITECTURAL REFLECTED CEILING PLANS FOR EXACT FIXTURE LOCATIONS. CONSULT INTERIOR DESIGNER FOR MOUNTING HEIGHTS NOT SPECIFIED.
- KITCHEN RECEPTACLES LOCATED IN ISLANDS OR PENINSULAS WHERE THE BACK SPLASH WILL NOT ACCOMMODATE VERTICAL PLACEMENT OR THE DUPLEX RECEPTACLE, THE CONTRACTOR SHALL ROTATE THE DEVICE 90 DEGREES SO THAT THE RECEPTACLE IS INSTALLED HORIZONTALLY.
- REFER TO DETAILS ON SHEET E1.15 FOR ADDITIONAL INFORMATION REGARDING ADA REACH REQUIREMENTS FOR RECEPTACLE AND SWITCH MOUNTING HEIGHT.
- STANDARD RECEPTACLE MOUNTING HEIGHT IS 18" A.F.F. UNLESS OTHERWISE SPECIFIED. RECEPTACLES LOCATED BELOW WINDOW SILLS SHALL NOT BE LESS THE 15" A.F.F.
- ALL PLANS ARE DIAGRAMMATICAL. CONSULT ARCHITECTURAL PLANS AND ELEVATIONS FOR EXACT LOCATION AND MOUNTING HEIGHT OF ALL DEVICES AND FIXTURES.
- REFER TO SHEET E1.13 FOR TYPICAL UNIT LOAD CENTER DIRECTORIES.
- RECEPTACLE FOR PTHP UNIT SHALL BE LOCATED BELOW THE UNIT, NEAR THE BASE OF THE WALL SUCH THAT THE CORD SET IS CONCEALED AS MUCH AS POSSIBLE. COORDINATE INSTALLATION WITH THE MECHANICAL INSTALLER.
- COORDINATE WITH THE 'I' SERIES SHEETS AND PROVIDE ROUGH IN FOR LOW VOLTAGE SYSTEMS SUCH AS TELEVISION CABLE OUTLETS AND FIRE ALARM DEVICES.

KEYED NOTES:


- PROVIDE WIRE CONNECTION FOR THERMOSTAT(S). COORDINATE WITH MECHANICAL INSTALLER FOR EXACT LOCATION AND POWER REQUIREMENTS PRIOR TO ROUGH IN.
- NOT USED.
- PROVIDE ONE 15A, RECEPTACLE CIRCUIT FROM TENANT LOAD CENTER FOR TELECOM SMART PANEL. COORDINATE WORK WITH SERVICE PROVIDER FOR EXACT LOCATION AND FINAL CONNECTION.
- REFER TO TYPICAL BATHROOM SWITCHING DETAILS ON SHEET E1.15.
- SWITCHED RECEPTACLE. SEE TYPICAL LIGHTING PLAN FOR SWITCH LOCATION.
- COMBINATION EXHAUST FAN & LIGHT SHALL BE TIED INTO THE BATHROOM LIGHTING CIRCUIT. VERIFY EXACT LOCATION W/MECHANICAL INSTALLER PRIOR TO ROUGH IN.
- REFER TO E3 SHEETS FOR HVAC EQUIPMENT LOCATION(S) & TYPE IN EACH UNIT. REVIEW & COORDINATE WITH THE MECHANICAL PLANS AND THE MECHANICAL INSTALLER FOR EXACT LOCATIONS AND ELECTRICAL REQUIREMENTS PRIOR TO ROUGH IN. PROVIDE CIRCUITING AS INDICATED. INDOOR HEAT PUMP UNITS ARE INTERCONNECTED WITH OUTDOOR UNIT LOCATED ON THE ROOF. POWER CONNECTION FOR PTHP UNIT SHALL BE LOCATED BELOW THE UNIT, NEAR THE BASE OF THE WALL SUCH THAT THE CORD SET IS CONCEALED AS MUCH AS POSSIBLE. CONSULT MECHANICAL PLANS TO DETERMINE WHETHER PTHP UNITS ARE CORD & PLUG OR HARDWIRED AND PROVIDE THE APPROPRIATE CONNECTION TYPE.
- 120V, 1P POWER CONNECTION FOR WATER METER. COORDINATE EXACT LOCATION WITH PLUMBING INSTALLER AND TIE INTO BATHROOM POWER CIRCUIT.
- PROVIDE 120V, 20A POWER FOR CEILING MOUNTED FAN/LIGHT COMBO AND TIE INTO BATHROOM LIGHTING CIRCUIT AND SWITCHING. REFER TO SHEET E1.15 FOR SWITCHING DIAGRAMS. REFER TO MECHANICAL PLANS FOR ADDITIONAL INFORMATION ON THE FAN AND COORDINATE INSTALLATION PRIOR TO ROUGH IN.



UNIT TYPE 5-STUDIO
TYPICAL POWER PLAN
2
E4.02 SCALE: 1/4" = 1'-0"





UNIT TYPE 6-STUDIO
TYPICAL POWER PLAN
4
E4.02 SCALE: 1/4" = 1'-0"



UNIT TYPE 7-STUDIO
TYPICAL POWER PLAN
6
E4.02 SCALE: 1/4" = 1'-0"

Consulting Engineers
2007 S.E. Ash St.
Portland, OR 97214
PHN: (503) 234-0548
FAX: (503) 234-0677
WWW.MPIA-ENG.COM
CONTACT: DENISE TAYLOR



CARLETON HART ARCHITECTURE P.C.
830 SW 10th Avenue #200 Portland, OR 97205
503.243.2252
www.carletonhart.com

SUSAN EMMONS - NORTH BUILDING
680 NW 18TH AVENUE,
PORTLAND, OR

NORTHWEST HOUSING ALTERNATIVES


CONFORMANCE SET

TYPICAL ENLARGED
UNIT PLANS


PROJECT NO.
17004
05/28/2021

REVISIONS: A


COPYRIGHT - CARLETON HART ARCHITECTURE DO NOT REPRODUCE WITHOUT PERMISSION




1
E4.03
UNIT TYPE 1B-STUDIO
TYPICAL LIGHTING PLAN
SCALE: 1/4" = 1'-0"




3
E4.03
UNIT TYPE 2B-STUDIO
TYPICAL LIGHTING PLAN
SCALE: 1/4" = 1'-0"




5
E4.03
UNIT TYPE 3B-STUDIO
TYPICAL LIGHTING PLAN
SCALE: 1/4" = 1'-0"




7
E4.03
UNIT TYPE 4A
TYPICAL LIGHTING PLAN
SCALE: 1/4" = 1'-0"




2
E4.03
UNIT TYPE 1B-STUDIO
TYPICAL POWER PLAN
SCALE: 1/4" = 1'-0"



4
E4.03
UNIT TYPE 2B-STUDIO
TYPICAL POWER PLAN
SCALE: 1/4" = 1'-0"



6
E4.03
UNIT TYPE 3B-STUDIO
TYPICAL POWER PLAN
SCALE: 1/4" = 1'-0"



8
E4.03
UNIT TYPE 4A
TYPICAL POWER PLAN
SCALE: 1/4" = 1'-0"


GENERAL NOTES:

- ALL PLANS ARE DIAGRAMMATICAL. CONSULT ARCHITECTURAL PLANS FOR EXACT LOCATION OF ALL DEVICES AND FIXTURES.
- REFER TO SHEET E1.14 FOR TYPICAL UNIT LOAD CENTER DIRECTORIES.
- ALL LIGHT SWITCHES SHALL BE ROCKER STYLE, SUCH AS LEVITON DECORA, OR APPROVED EQUAL.
- REFER TO ARCHITECTURAL REFLECTED CEILING PLANS FOR EXACT FIXTURE LOCATIONS. CONSULT INTERIOR DESIGNER FOR MOUNTING HEIGHTS NOT SPECIFIED.
- KITCHEN RECEPTACLES LOCATED IN ISLANDS OR PENINSULAS WHERE THE BACK SPLASH WILL NOT ACCOMMODATE VERTICAL PLACEMENT OR THE DUPLEX RECEPTACLE, THE CONTRACTOR SHALL ROTATE THE DEVICE 90 DEGREES SO THAT THE RECEPTACLE IS INSTALLED HORIZONTALLY.
- REFER TO DETAILS ON SHEET E1.15 FOR ADDITIONAL INFORMATION REGARDING ADA REACH REQUIREMENTS FOR RECEPTACLE AND SWITCH MOUNTING HEIGHT.
- STANDARD RECEPTACLE MOUNTING HEIGHT IS 18" A.F.F. UNLESS OTHERWISE SPECIFIED. RECEPTACLES LOCATED BELOW WINDOW SILLS SHALL NOT BE LESS THE 15" A.F.F.
- ALL PLANS ARE DIAGRAMMATICAL. CONSULT ARCHITECTURAL PLANS AND ELEVATIONS FOR EXACT LOCATION AND MOUNTING HEIGHT OF ALL DEVICES AND FIXTURES.
- REFER TO SHEET E1.13 FOR TYPICAL UNIT LOAD CENTER DIRECTORIES.
- RECEPTACLE FOR PTHP UNIT SHALL BE LOCATED BELOW THE UNIT, NEAR THE BASE OF THE WALL SUCH THAT THE CORD SET IS CONCEALED AS MUCH AS POSSIBLE. COORDINATE INSTALLATION WITH THE MECHANICAL INSTALLER.
- COORDINATE WITH THE "T" SERIES SHEETS AND PROVIDE ROUGH IN FOR LOW VOLTAGE SYSTEMS SUCH AS TELEVISION CABLE OUTLETS AND FIRE ALARM DEVICES.

KEYED NOTES:

- PROVIDE WIRE CONNECTION FOR THERMOSTAT(S). COORDINATE WITH MECHANICAL INSTALLER FOR EXACT LOCATION AND POWER REQUIREMENTS PRIOR TO ROUGH IN.
- NOT USED.
- PROVIDE ONE 15A, RECEPTACLE CIRCUIT FROM TENANT LOAD CENTER FOR TELECOM SMART PANEL. COORDINATE WORK WITH SERVICE PROVIDER FOR EXACT LOCATION AND FINAL CONNECTION.
- REFER TO TYPICAL BATHROOM SWITCHING DETAILS ON SHEET E1.15.
- SWITCHED RECEPTACLE. SEE TYPICAL LIGHTING PLAN FOR SWITCH LOCATION.
- COMBINATION EXHAUST FAN & LIGHT SHALL BE TIED INTO THE BATHROOM LIGHTING CIRCUIT. VERIFY EXACT LOCATION W/MECHANICAL INSTALLER PRIOR TO ROUGH IN.
- REFER TO E3 SHEETS FOR HVAC EQUIPMENT LOCATION(S) & TYPE IN EACH UNIT. REVIEW & COORDINATE WITH THE MECHANICAL PLANS AND THE MECHANICAL INSTALLER FOR EXACT LOCATIONS AND ELECTRICAL REQUIREMENTS PRIOR TO ROUGH IN. PROVIDE CIRCUITING AS INDICATED. INDOOR HEAT PUMP UNITS ARE INTERCONNECTED WITH OUTDOOR UNIT LOCATED ON THE ROOF. POWER CONNECTION FOR PTHP UNIT SHALL BE LOCATED BELOW THE UNIT, NEAR THE BASE OF THE WALL SUCH THAT THE CORD SET IS CONCEALED AS MUCH AS POSSIBLE. CONSULT MECHANICAL PLANS TO DETERMINE WHETHER PTHP UNITS ARE CORD & PLUG OR HARDWIRED AND PROVIDE THE APPROPRIATE CONNECTION TYPE.
- 120V, 1P POWER CONNECTION FOR WATER METER. COORDINATE EXACT LOCATION WITH PLUMBING INSTALLER AND TIE INTO BATHROOM POWER CIRCUIT.
- PROVIDE 120V, 20A POWER FOR CEILING MOUNTED FAN/LIGHT COMBO AND TIE INTO BATHROOM LIGHTING CIRCUIT AND SWITCHING. REFER TO SHEET E1.15 FOR SWITCHING DIAGRAMS. REFER TO MECHANICAL PLANS FOR ADDITIONAL INFORMATION ON THE FAN AND COORDINATE INSTALLATION PRIOR TO ROUGH IN.


MFA INC.
Consulting Engineers
2007 S.E. Ash St.
Portland, OR 97214
PHN: (503) 234-0548
FAX: (503) 234-0677
WWW.MFA-ENG.COM
CONTACT: DENISE TAYLOR




CARLETON HART ARCHITECTURE P.C.
830 SW 10th Avenue #200 Portland, Oregon 97205
503.243.2252
www.carletonhart.com

SUSAN EMMONS - NORTH BUILDING
680 NW 18TH AVENUE,
PORTLAND, OR
NORTHWEST HOUSING ALTERNATIVES
CONFORMANCE SET


TYPICAL ENLARGED
UNIT PLANS
PROJECT NO.
17004
05/28/2021
REVISIONS: A




UNIT TYPE 5B-STUDIO
TYPICAL LIGHTING PLAN
1
E4.04 SCALE: 1/4" = 1'-0"




UNIT TYPE 6B-STUDIO
TYPICAL LIGHTING PLAN
3
E4.04 SCALE: 1/4" = 1'-0"




UNIT TYPE 7B-STUDIO
TYPICAL LIGHTING PLAN
5
E4.04 SCALE: 1/4" = 1'-0"



UNIT TYPE 5B-STUDIO
TYPICAL POWER PLAN
2
E4.04 SCALE: 1/4" = 1'-0"



UNIT TYPE 6B-STUDIO
TYPICAL POWER PLAN
4
E4.04 SCALE: 1/4" = 1'-0"



UNIT TYPE 7B-STUDIO
TYPICAL POWER PLAN
6
E4.04 SCALE: 1/4" = 1'-0"

GENERAL NOTES:

- ALL PLANS ARE DIAGRAMMATICAL. CONSULT ARCHITECTURAL PLANS FOR EXACT LOCATION OF ALL DEVICES AND FIXTURES.
- REFER TO SHEET E1.14 FOR TYPICAL UNIT LOAD CENTER DIRECTORIES.
- ALL LIGHT SWITCHES SHALL BE ROCKER STYLE, SUCH AS LEVITON DECORA OR APPROVED EQUAL.
- REFER TO ARCHITECTURAL REFLECTED CEILING PLANS FOR EXACT FIXTURE LOCATIONS. CONSULT INTERIOR DESIGNER FOR MOUNTING HEIGHTS NOT SPECIFIED.
- KITCHEN RECEPTACLES LOCATED IN ISLANDS OR PENINSULAS WHERE THE BACK SPLASH WILL NOT ACCOMMODATE VERTICAL PLACEMENT OR THE DUPLEX RECEPTACLE, THE CONTRACTOR SHALL ROTATE THE DEVICE 90 DEGREES SO THAT THE RECEPTACLE IS INSTALLED HORIZONTALLY.
- REFER TO DETAILS ON SHEET E1.15 FOR ADDITIONAL INFORMATION REGARDING ADA REACH REQUIREMENTS FOR RECEPTACLE AND SWITCH MOUNTING HEIGHT.
- STANDARD RECEPTACLE MOUNTING HEIGHT IS 18" A.F.F. UNLESS OTHERWISE SPECIFIED. RECEPTACLES LOCATED BELOW WINDOW SILLS SHALL NOT BE LESS THAN 15" A.F.F.
- ALL PLANS ARE DIAGRAMMATICAL. CONSULT ARCHITECTURAL PLANS AND ELEVATIONS FOR EXACT LOCATION AND MOUNTING HEIGHT OF ALL DEVICES AND FIXTURES.
- REFER TO SHEET E1.13 FOR TYPICAL UNIT LOAD CENTER DIRECTORIES.
- RECEPTACLE FOR PTHP UNIT SHALL BE LOCATED BELOW THE UNIT, NEAR THE BASE OF THE WALL SUCH THAT THE CORD SET IS CONCEALED AS MUCH AS POSSIBLE. COORDINATE INSTALLATION WITH THE MECHANICAL INSTALLER.
- COORDINATE WITH THE 'T' SERIES SHEETS AND PROVIDE ROUGH IN FOR LOW VOLTAGE SYSTEMS SUCH AS TELEVISION CABLE OUTLETS AND FIRE ALARM DEVICES.

KEYED NOTES:

- PROVIDE WIRE CONNECTION FOR THERMOSTAT(S). COORDINATE WITH MECHANICAL INSTALLER FOR EXACT LOCATION AND POWER REQUIREMENTS PRIOR TO ROUGH IN.
- NOT USED.
- PROVIDE ONE 15A, RECEPTACLE CIRCUIT FROM TENANT LOAD CENTER FOR TELECOM SMART PANEL. COORDINATE WORK WITH SERVICE PROVIDER FOR EXACT LOCATION AND FINAL CONNECTION.
- REFER TO TYPICAL BATHROOM SWITCHING DETAILS ON SHEET E1.15.
- SWITCHED RECEPTACLE. SEE TYPICAL LIGHTING PLAN FOR SWITCH LOCATION.
- COMBINATION EXHAUST FAN & LIGHT SHALL BE TIED INTO THE BATHROOM LIGHTING CIRCUIT. VERIFY EXACT LOCATION W/MECHANICAL INSTALLER PRIOR TO ROUGH IN.
- REFER TO E3 SHEETS FOR HVAC EQUIPMENT LOCATION(S) & TYPE IN EACH UNIT. REVIEW & COORDINATE WITH THE MECHANICAL PLANS AND THE MECHANICAL INSTALLER FOR EXACT LOCATIONS AND ELECTRICAL REQUIREMENTS PRIOR TO ROUGH IN. PROVIDE CIRCUITING AS INDICATED. INDOOR HEAT PUMP UNITS ARE INTERCONNECTED WITH OUTDOOR UNIT LOCATED ON THE ROOF. POWER CONNECTION FOR PTHP UNIT SHALL BE LOCATED BELOW THE UNIT, NEAR THE BASE OF THE WALL SUCH THAT THE CORD SET IS CONCEALED AS MUCH AS POSSIBLE. CONSULT MECHANICAL PLANS TO DETERMINE WHETHER PTHP UNITS ARE CORD & PLUG OR HARDWIRED AND PROVIDE THE APPROPRIATE CONNECTION TYPE.
- 120V, 1P POWER CONNECTION FOR WATER METER. COORDINATE EXACT LOCATION WITH PLUMBING INSTALLER AND TIE INTO BATHROOM POWER CIRCUIT.
- PROVIDE 120V, 20A POWER FOR CEILING MOUNTED FAN/LIGHT COMBO AND TIE INTO BATHROOM LIGHTING CIRCUIT AND SWITCHING. REFER TO SHEET E1.15 FOR SWITCHING DIAGRAMS. REFER TO MECHANICAL PLANS FOR ADDITIONAL INFORMATION ON THE FAN AND COORDINATE INSTALLATION PRIOR TO ROUGH IN.

REGISTERED PROFESSIONAL
ENGINEER
16,597
OREGON
JULY 20, 1993
ROBERT L. CONNELL
EXPIRES 12-31-2021

CARLETON HART ARCHITECTURE P.C.
830 SW 10th Avenue #200 Portland, OR 97205
503.243.2252
www.carletonhart.com


SUSAN EMMONS - NORTH BUILDING
680 NW 18TH AVENUE,
PORTLAND, OR
NORTHWEST HOUSING ALTERNATIVES
CONFORMANCE SET

TYPICAL ENLARGED
UNIT PLANS


PROJECT NO.
17004
05/28/2021

REVISIONS:


COPYRIGHT - CARLETON HART ARCHITECTURE DO NOT REPRODUCE WITHOUT PERMISSION




UNIT TYPE 8A-STUDIO
TYPICAL LIGHTING PLAN
1
E4.05 SCALE: 1/4" = 1'-0"




UNIT TYPE 9A-1BEDRM
TYPICAL LIGHTING PLAN
3
E4.05 SCALE: 1/4" = 1'-0"




UNIT TYPE 10B
TYPICAL LIGHTING PLAN
5
E4.05 SCALE: 1/4" = 1'-0"



UNIT TYPE 8A-STUDIO
TYPICAL POWER PLAN
2
E4.05 SCALE: 1/4" = 1'-0"



UNIT TYPE 9A-1BEDRM
TYPICAL POWER PLAN
4
E4.05 SCALE: 1/4" = 1'-0"



UNIT TYPE 10B
TYPICAL POWER PLAN
6
E4.05 SCALE: 1/4" = 1'-0"


GENERAL NOTES:

- ALL PLANS ARE DIAGMATICAL. CONSULT ARCHITECTURAL PLANS FOR EXACT LOCATION OF ALL DEVICES AND FIXTURES.
- REFER TO SHEET E1.14 FOR TYPICAL UNIT LOAD CENTER DIRECTORIES.
- ALL LIGHT SWITCHES SHALL BE ROCKER STYLE, SUCH AS LEVITON DECORA, OR APPROVED EQUAL.
- REFER TO ARCHITECTURAL REFLECTED CEILING PLANS FOR EXACT FIXTURE LOCATIONS. CONSULT INTERIOR DESIGNER FOR MOUNTING HEIGHTS NOT SPECIFIED.
- KITCHEN RECEPTACLES LOCATED IN ISLANDS OR PENINSULAS WHERE THE BACK SPLASH WILL NOT ACCOMMODATE VERTICAL PLACEMENT OR THE DUPLEX RECEPTACLE, THE CONTRACTOR SHALL ROTATE THE DEVICE 90 DEGREES SO THAT THE RECEPTACLE IS INSTALLED HORIZONTALLY.
- REFER TO DETAILS ON SHEET E1.15 FOR ADDITIONAL INFORMATION REGARDING ADA REACH REQUIREMENTS FOR RECEPTACLE AND SWITCH MOUNTING HEIGHT.
- STANDARD RECEPTACLE MOUNTING HEIGHT IS 18" A.F.F. UNLESS OTHERWISE SPECIFIED. RECEPTACLES LOCATED BELOW WINDOW SILLS SHALL NOT BE LESS THAN 15" A.F.F.
- ALL PLANS ARE DIAGMATICAL. CONSULT ARCHITECTURAL PLANS AND ELEVATIONS FOR EXACT LOCATION AND MOUNTING HEIGHT OF ALL DEVICES AND FIXTURES.
- REFER TO SHEET E1.13 FOR TYPICAL UNIT LOAD CENTER DIRECTORIES.
- RECEPTACLE FOR PTHP UNIT SHALL BE LOCATED BELOW THE UNIT, NEAR THE BASE OF THE WALL SUCH THAT THE CORD SET IS CONCEALED AS MUCH AS POSSIBLE. COORDINATE INSTALLATION WITH THE MECHANICAL INSTALLER.
- COORDINATE WITH THE 'T' SERIES SHEETS AND PROVIDE ROUGH IN FOR LOW VOLTAGE SYSTEMS SUCH AS TELEVISION CABLE OUTLETS AND FIRE ALARM DEVICES.

KEYED NOTES:

- PROVIDE WIRE CONNECTION FOR THERMOSTAT(S). COORDINATE WITH MECHANICAL INSTALLER FOR EXACT LOCATION AND POWER REQUIREMENTS PRIOR TO ROUGH IN.
- NOT USED.
- PROVIDE ONE 15A, RECEPTACLE CIRCUIT FROM TENANT LOAD CENTER FOR TELECOM SMART PANEL. COORDINATE WORK WITH SERVICE PROVIDER FOR EXACT LOCATION AND FINAL CONNECTION.
- REFER TO TYPICAL BATHROOM SWITCHING DETAILS ON SHEET E1.15.
- SWITCHED RECEPTACLE. SEE TYPICAL LIGHTING PLAN FOR SWITCH LOCATION.
- COMBINATION EXHAUST FAN & LIGHT SHALL BE TIED INTO THE BATHROOM LIGHTING CIRCUIT. VERIFY EXACT LOCATION W/MECHANICAL INSTALLER PRIOR TO ROUGH IN.
- REFER TO E3 SHEETS FOR HVAC EQUIPMENT LOCATION(S) & TYPE IN EACH UNIT. REVIEW & COORDINATE WITH THE MECHANICAL PLANS AND THE MECHANICAL INSTALLER FOR EXACT LOCATIONS AND ELECTRICAL REQUIREMENTS PRIOR TO ROUGH IN. PROVIDE CIRCUITING AS INDICATED. INDOOR HEAT PUMP UNITS ARE INTERCONNECTED WITH OUTDOOR UNIT LOCATED ON THE ROOF. POWER CONNECTION FOR PTHP UNIT SHALL BE LOCATED BELOW THE UNIT, NEAR THE BASE OF THE WALL SUCH THAT THE CORD SET IS CONCEALED AS MUCH AS POSSIBLE. CONSULT MECHANICAL PLANS TO DETERMINE WHETHER PTHP UNITS ARE CORD & PLUG OR HARDWIRED AND PROVIDE THE APPROPRIATE CONNECTION TYPE.
- 120V, 1P POWER CONNECTION FOR WATER METER. COORDINATE EXACT LOCATION WITH PLUMBING INSTALLER AND TIE INTO BATHROOM POWER CIRCUIT.
- PROVIDE 120V, 20A POWER FOR CEILING MOUNTED FAN/LIGHT COMBO AND TIE INTO BATHROOM LIGHTING CIRCUIT AND SWITCHING. REFER TO SHEET E1.15 FOR SWITCHING DIAGRAMS. REFER TO MECHANICAL PLANS FOR ADDITIONAL INFORMATION ON THE FAN AND COORDINATE INSTALLATION PRIOR TO ROUGH IN.

MEFA INC.
Consulting Engineers
2007 S.E. Ash St.
Portland, OR 97214
PHN: (503) 234-0548
FAX: (503) 234-0877
WWW.MFIA-ENG.COM
CONTACT: DENISE TAYLOR



CARLETON HART ARCHITECTURE P.C.
830 SW 10th Avenue #200 Portland, OR 97205
503.243.2252
www.carletonhart.com

SUSAN EMMONS - NORTH BUILDING
680 NW 18TH AVENUE,
PORTLAND, OR

NORTHWEST HOUSING ALTERNATIVES

CONFORMANCE SET

TYPICAL ENLARGED
UNIT PLANS
PROJECT NO.
17004
05/28/2021

REVISIONS: