SECTION 28 31 00 - ADDRESSABLE FIRE ALARM

PART 1 - GENERAL

1.1 SUMMARY

- A. This Section covers fire alarm systems, including initiating devices, notification appliances, controls, and supervisory devices.
- B. Work covered by this section includes the furnishing of labor, equipment, and materials for installation of the fire alarm system as indicated on the drawings and specifications.
- C. The Fire Alarm System shall consist of all necessary hardware equipment and software programming to perform the following functions:
 - 1. Fire alarm system detection, notification operations and elevator control.
- D. A residential grade smoke and carbon monoxide detectors will be required in the units.
- 1.2 SCOPE OF WORK
 - A. This building will require both a building fire alarm system and residential grade devices to be installed. Follow all applicable codes for the type of device to be installed.

1.3 ACCEPTABLE EQUIPMENT AND SERVICE PROVIDERS

- A. Manufacturers: Silent Knight, Safetech, Hochiki or approved equal
- B. Being listed as an acceptable Manufacturer in no way relieves obligation to provide all equipment and features in accordance with these specifications.
- C. The equipment and service provider shall be a nationally recognized company specializing in fire alarm and detection systems. This provider shall employ factory trained and NICET Level II, Level III, and Level IV certified technicians, and shall maintain a service organization within 50 miles of this project location. The equipment and service provider shall have a minimum of 10 years experience in the fire protective signaling systems industry.

1.4 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions apply to this section.
- B. The work covered by this section is to be coordinated with related work as specified

elsewhere in the specifications. Requirements of the following sections apply:

- 1. Division 26: "Basic Electrical Materials and Methods."
- 2. Division 26: "Wiring Methods."
- 3. Division 21: "Fire Protection".
- 4. Division 23: "HVAC Systems".
- 5. Division 23: "Building Automation and Control".
- C. The system and all associated operations shall be in accordance with the following:
 - 1. National Fire Protection Association (NFPA)
 - 2. National Electric Code (NEC)
 - 3. Americans with Disabilities Act (ADA)
 - 4. Institute of Electrical and Electronics Engineers (IEEE)
 - 5. Underwriters Laboratories (UL)
 - 6. International Building Code (IBC)
 - 7. International Fire Code (IFC)
 - 8. Occupational Safety and Health Administration (OSHA)
 - 9. Authorities Having Jurisdiction (AHJ)
 - 10. Oregon Structural Specialty Code (OSSC)

1.5 SYSTEM DESCRIPTION

- A. General: Provide a complete, non-coded, addressable, microprocessor-based fire alarm system with initiating devices, notification appliances, and monitoring and control devices as indicated on the drawings and as specified herein.
- B. Software: The fire alarm system shall allow for loading and editing instructions and operating sequences as necessary. The system shall be capable of 100% on-site programming to accommodate system expansion and facilitate changes in operation. All programming shall be capable of being accomplished via the front panel and via a lap top computer. All software operations shall be stored in a non-volatile programmable memory within the FACP. Loss of primary and secondary power shall not erase the instructions stored in memory.
- C. The ability for selective input/output control functions based on alarm grouping is to also be incorporated in the resident software programming of the system.
- D. History Logs: The system shall provide a means to recall alarms and trouble conditions in chronological order for the purpose of recreating an event history. Separate alarm, supervisory and trouble logs shall be provided.
 - 1. The control panel shall have the ability to store a minimum of one hundred (100) events in an alarm log plus a minimum of three hundred (300) events in a separate trouble log and a minimum of one hundred (100) events in a supervisory log. These events shall be stored in a battery protected random access memory (RAM). Real time and date shall accompany all history event recording.
 - 2. History logs shall be capable of being viewed separately or shall be selectable for viewing as a combined history log that displays both alarm and trouble events

in chronological order.

- E. Remote Access:
 - 1. The system shall be fully programmable from the front panel display
 - 2. A personal computer or technician's laptop, configured with terminal emulation software shall have the ability to access the FACP for diagnostics, maintenance reporting, programming and information gathering.
- F. Required Functions: The following are required system functions and operating features:
 - 1. Priority of Signals: Fire alarm events have highest priority. Subsequent alarm events are queued in the order received and do not affect existing alarm conditions. Priority Two, Supervisory and Trouble events have second-, third-, and fourth-level priority, respectively. Signals of a higher-level priority take precedence over signals of lower priority even though the lower-priority condition occurred first. Annunciate all events regardless of priority or order received.
 - 2. Noninterfering: The activation of an addressable device does not prevent the receipt of signals from subsequent activations.
 - 3. Transmission to an approved Supervising Station: Automatically route alarm, supervisory, and trouble signals to an approved supervising station service provider, under another contract.
 - 4. Annunciation: Operation of alarm and supervisory initiating devices shall be annunciated at the FACP and the remote annunciator, indicating the type of device, the operational state of the device (i.e alarm, trouble or supervisory) and shall display the custom label associated with the device.
 - 5. General Alarm: A system general alarm shall include:
 - a. Indication of alarm condition at the FACP and the annunciator(s).
 - b. Identification of the device/zone that is the source of the alarm at the FACP and the annunciator(s).
 - c. Operation of audible and visible notification appliances until silenced at FACP.
 - d. Audible Alarm Notification shall operate as a Temporal Code pattern.
 - e. Closing doors normally held open by magnetic door holders.
 - f. Unlocking designated doors.
 - g. Shutting down supply and return fans serving zone where alarm is initiated.
 - h. Closing smoke dampers on system serving zone where alarm is initiated.
 - i. Initiation of smoke control sequence.
 - j. Transmission of signal to the supervising station.
 - k. Initiation of elevator Phase I functions (recall, shunt trip, illumination of indicator in cab, etc.) in accordance with ASME/ANSI A17.1, when specified detectors or sensors are activated, as appropriate.
 - 6. Supervisory Operations: Upon activation of a supervisory device such as a tamper switch, the system shall operate as follows:
 - a. Activate the system supervisory service audible signal and illuminate the LED at the FACP and the graphic annunciator.
 - b. Pressing the Supervisory Acknowledge key will silence the supervisory audible signal while maintaining the Supervisory LED "on" indicating offnormal condition.
 - c. Record the event in the FACP historical log.
 - d. Transmission of supervisory signal to the supervising station.

- 7. Alarm Silencing: If the "Alarm Silence" button is pressed, all audible alarm signals shall cease operation except the fire sprinkler bell.
- 8. System Reset
 - a. The "System Reset" button shall be used to return the system to its normal state. Display messages shall provide operator assurance of the sequential steps ("IN PROGRESS", "RESET COMPLETED") as they occur. The system shall verify all circuits or devices are restored prior to resetting the system to avoid the potential for re-alarming the system. The display message shall indicate "ALARM PRESENT, SYSTEM RESET ABORTED."
 - b. Should an alarm condition continue, the system will remain in an alarmed state.
- 9. Manual Control: Manual controls shall be supervised so that an "off normal" position of any switch shall cause an "off normal" system trouble. The "off normal" status shall be clearly identified in plain-language on the FACP alphanumeric display.
 - a. Manual Bypass Control: The ability to perform a manual bypass of selected automatic functions shall be provided.
 - b. Circuit Enable/Disable Control: The system shall have provisions for disabling and enabling each circuit individually for maintenance or testing purposes.
- 10. WALKTEST: The system shall have a one person test feature. Enabling the one person test feature at the FACP shall activate the "One Person Testing" mode of the system as follows:
 - a. The city circuit connection and suppression release circuits shall be bypassed for the testing group.
 - b. Control relay functions associated to the testing group shall be bypassed.
 - c. The FACP shall indicate a trouble condition.
 - d. The alarm activation of any initiation device in the testing group shall cause the audible notification appliances to sound a code to identify the device.
 - e. The control panel shall automatically reset itself after signaling is complete.
 - f. Any momentary opening of an initiating or notification appliance circuit wiring shall cause the audible signals to sound for 4 seconds indicating the trouble condition.
- G. Analog Smoke Sensors:
 - 1. Monitoring: FACP shall individually monitor sensors for calibration, sensitivity, and alarm condition, and shall individually adjust for sensitivity. The FACP shall determine the condition of each sensor by comparing the sensor value to the stored values.
 - 2. Environmental Compensation: The FACP shall maintain a moving average of the sensor's smoke chamber value to automatically compensate for dust, dirt, and other conditions that could affect detection operations.
 - 3. Programmable Sensitivity: Photoelectric Smoke Sensors shall have 2 sensitivity levels ranging from 2.5% or 3.7%, programmed and monitored from the FACP.
 - 4. Sensitivity Testing Reports: The FACP shall provide sensor reports that meet NFPA 72 calibrated test method requirements. The reports shall be viewed on a Maintenance Terminal CRT Display or printed for annual recording and logging of the calibration maintenance schedule.
 - 5. The FACP shall automatically indicate when an individual sensor needs cleaning. The system shall provide a means to automatically indicate when a sensor

requires cleaning. When a sensor's average value reaches a predetermined value, (3) progressive levels of reporting are provided. The first level shall indicate if a sensor is close to a trouble reporting condition and will be indicated on the FACP as "ALMOST DIRTY." This condition provides a means to alert maintenance staff of a sensor approaching dirty without creating a trouble in the system. If this indicator is ignored and the second level is reached, a "DIRTY SENSOR" condition shall be indicated at the FACP and subsequently a system trouble is reported [to the Supervising Station][none]. The sensor base LED shall glow steady giving a visible indication at the sensor location. The "DIRTY SENSOR" condition shall not affect the sensitivity level required to alarm the sensor. If a "DIRTY SENSOR" is left unattended, and its average value increases to a third predetermined value, an "EXCESSIVELY DIRTY SENSOR" trouble condition shall be indicated at the control unit.

- 6. The FACP shall continuously perform an automatic self-test on each sensor that will check sensor electronics and ensure the accuracy of the values being transmitted. Any sensor that fails this test shall indicate a "SELF TEST ABNORMAL" trouble condition.
- H. Fire Suppression Monitoring:
 - 1. Water flow: Activation of a water flow switch shall initiate general alarm operations.
 - 2. Sprinkler valve tamper switch: The activation of any valve tamper switch shall activate system supervisory operations.
 - 3. WSO: Water flow switch and sprinkler valve tamper switch shall be capable of existing on the same initiating zone. Activation of either device shall distinctly report which device is in alarm on the initiating zone.
- I. Audible Alarm Notification: By horns in areas as indicated on drawings.
- J. Power Requirements:
 - 1. The control panel shall receive AC power via a dedicated fused disconnect circuit.
 - 2. The system shall be provided with sufficient battery capacity to operate the entire system upon loss of normal AC power in a normal supervisory mode for a period of 24 hours with 5 minutes of alarm operation at the end of this period. The system shall automatically transfer to battery standby upon power failure. All battery charging and recharging operations shall be automatic.
 - 3. All circuits requiring system-operating power shall be 24 VDC and shall be individually fused at the control panel.
 - 4. The incoming power to the system shall be supervised so that any power failure will be indicated at the control panel. A green "power on" LED shall be displayed continuously while incoming power is present.
 - 5. The system batteries shall be supervised so that a low battery condition or disconnection of the battery shall be indicated at the control panel.
 - 6. The system shall support 100% of addressable devices in alarm operated at the same time, under both primary(AC) and secondary (battery) power conditions.
 - 7. Loss of primary power shall sound a trouble signal at the FACP. FACP shall indicate when the system is operating on an alternate power supply.

1.6 SUBMITTALS

- A. General: Submit the following according to Conditions of Contract.
- B. Product data sheets for system components highlighted to indicate the specific products, features, or functions required to meet this specification. Alternate or asequal products submitted under this contract must provide a detailed line-by-line comparison of how the submitted product meets, exceeds, or does not comply with this specification.
- C. Wiring diagrams from manufacturer.
- D. Shop drawings showing system details including location of FACP, all devices, circuiting and details of graphic annunciator.
- E. System power and battery charts with performance graphs and voltage drop calculations to assure that the system will operate in accordance with the prescribed backup time periods and under all voltage conditions in accordance with UL and NFPA standards.
- F. System operation description including method of operation and supervision of each type of circuit and sequence of operations for all manually and automatically initiated system inputs and outputs. A list of all input and output points in the system shall be provided with a label indicating location or use of IDC, SLC, NAC, RAC, Sensor, and auxiliary control circuits.
- G. Submission to Authority Having Jurisdiction: In addition to routine submission of the above material, make an identical submission to the authority having jurisdiction. Include copies of shop drawings as required to depict component locations to facilitate review. Upon receipt of comments from the Authority, make resubmissions, if required, to make clarifications or revisions to obtain approval.

1.7 QUALITY ASSURANCE

- A. Installer Qualifications: A factory authorized installer is to perform the work of this section.
- B. Each and every item of the Fire Alarm System shall be listed under the appropriate category by Underwriters Laboratories, Inc. (UL), and shall bear the "UL" label.

1.8 EXTRA MATERIALS

- A. General: Furnish extra materials, packaged with protective covering for storage, and identified with labels clearly describing contents as follows:
- B. Break Rods for Manual Stations: Furnish quantity equal to 15 percent of the number of

manual stations installed; minimum of 6 rods.

- C. Notification Appliances: Furnish quantity equal to 10 percent of each type and number of units installed, but not less than one of each type.
- D. Smoke Detectors or Sensors, Fire Detectors, and Flame Detectors: Furnish quantity equal to 10 percent of each type and number of units installed but not less than one of each type.
- E. Detector or Sensor Bases: Furnish quantity equal to 2 percent of each type and number of units installed but not less than one of each type.
- F. Sensor Bases: Furnish quantity equal to 2 percent of the number of units of each type installed but not less than one of each type.

PART 2 - PRODUCTS

- 2.1 FIRE ALARM CONTROL PANEL (FACP)
 - A. General: Comply with UL 864, "Control Units and Accessories for Fire Alarm Systems".
 - B. The following FACP hardware shall be provided:
 - 1. Power Limited base panel with red cabinet and door, 120 VAC, 60 HZ, input power.
 - 2. 200 Addressable point capacity inclusive of inputs and outputs in any combination.
 - 3. Two (2) Class B, Style Y Notification Appliance Circuits (NAC; rated 2A @ 24VDC, resistive).
 - 4. Two form "C" Auxiliary Output Circuits (rated 2A @ 24VDC, resistive), operation is programmable for trouble, alarm, supervisory or other selective control operations. Provide capability for switching up to ½ A @ 120VAC, inductive loads.
 - 5. Battery Meter Module, provides ammeter and voltmeter for power supply monitoring at front panel display.
 - C. The FACP shall support one (1) RS-232-C ports.
 - D. Supervised serial communication channel for control and monitoring of remotely located LCD/LED annunciators.
 - E. Common Event DACT.
 - F. Cabinet: Lockable steel enclosure. Arrange panel so all operations required for testing or for normal care and maintenance of the system are performed from the front of the enclosure. If more than a single panel is required to form a complete control panel,

provide exactly matching modular panel enclosures.

G. Alphanumeric Display and System Controls: Panel shall include a 40 character LCD display to indicate alarm, supervisory, and component status messages and shall include a keypad for use in entering and executing control commands.

2.2 REMOTE LCD ANNUNCIATOR

- A. Provide Remote LCD Annunciator(s) as required with the same "look and feel" as the FACP operator interface. The Remote LCD Annunciator shall use the same Primary Acknowledge, Silence, and Reset Keys, Status LEDs and LCD Display as the FACP.
- B. Annunciator shall have super-twist LCD display with two lines of 40 characters each. Annunciator shall be provided with three (3) programmable LEDs (two selectable as red or yellow; one selectable as green or yellow).
- C. Under normal conditions the LCD shall display a "SYSTEM IS NORMAL" message and the current time and date.
- D. Should an abnormal condition be detected the appropriate LED (Alarm, Supervisory or Trouble) shall flash. The unit audible signal shall pulse for alarm conditions and sound steady for trouble and supervisory conditions.
- E. The LCD shall display the following information relative to the abnormal condition of a point in the system:
 - 1. 40 character custom location label.
 - 2. Type of device (e.g., smoke, pull station, waterflow).
 - 3. Point status (e.g., alarm, trouble).
- F. Operator keys shall be key switch enabled to prevent unauthorized use. The key shall only be removable in the disabled position. Acknowledge, Silence and Reset operation shall be the same as the FACP.

2.3 EMERGENCY POWER SUPPLY

- A. General: Components include battery, charger, and an automatic transfer switch.
- B. Battery: Sealed lead-acid type. Provide sufficient capacity to operate the complete alarm system in normal or supervisory (non-alarm) mode for a period of 4 hours. Following this period of operation on battery power, the battery shall have sufficient capacity to operate all components of the system, including all notification appliances in alarm or supervisory mode for a period of 5 minutes.

2.4 ADDRESSABLE MANUAL PULL STATIONS

A. Description: Addressable single- or double-action type, red LEXAN, with molded, raised-letter operating instructions of contrasting color. Station will mechanically latch

upon operation and remain so until manually reset by opening with a key common with the control units.

- 2.5 SMOKE SENSORS
 - A. General: Comply with UL 268, "Smoke Detectors for Fire Protective Signaling Systems." Include the following features:
 - 1. Factory Nameplate: Serial number and type identification.
 - 2. Operating Voltage: 24 VDC, nominal.
 - 3. Self-Restoring: Detectors do not require resetting or readjustment after actuation to restore normal operation.
 - 4. Plug-In Arrangement: Sensor and associated electronic components are mounted in a module that connects to a fixed base with a twist-locking plug connection. Base shall provide break-off plastic tab that can be removed to engage the head/base locking mechanism. No special tools shall be required to remove head once it has been locked. Removal of the detector head shall interrupt the supervisory circuit of the fire alarm detection loop and cause a trouble signal at the control unit.
 - 5. Each sensor base shall contain an LED that will flash each time it is scanned by the Control Unit (once every 4 seconds). In alarm condition, the sensor base LED shall be on steady.
 - 6. Each sensor base shall contain a magnetically actuated test switch to provide for easy alarm testing at the sensor location.
 - Each sensor shall be scanned by the Control Unit for its type identification to prevent inadvertent substitution of another sensor type. Upon detection of a "wrong device", the control unit shall operate with the installed device at the default alarm settings for that sensor; 2.5% obscuration for photoelectric sensor, 135-deg F and 15-deg F rate-of-rise for the heat sensor, but shall indicate a "Wrong Device" trouble condition.
 - 8. The sensor's electronics shall be immune from nuisance alarms caused by EMI and RFI.
 - 9. Sensors include a communication transmitter and receiver in the mounting base having a unique identification and capability for status reporting to the FACP. Sensor address shall be located in base to eliminate false addressing when replacing sensors.
 - 10. Removal of the sensor head for cleaning shall not require the setting of addresses.
 - B. Type: Smoke sensors shall be photoelectric or combination photoelectric / heat type.
 - C. Bases: Relay output, sounder and isolator bases shall be supported alternatives to the standard base.
 - D. Duct Smoke Sensor: The detector is to be Photoelectric type.
 - 1. If possible the detector and housing will be a one-piece design. The housing and detector separate is allowed if a one-piece unit is not available.
 - a. The duct detector housing shall be supplied with a clear cover so the presence of smoke can be monitored.
 - b. Shall be supplied with either a magnetic test feature or an injection tube for

device testing.

- c. Designed to operate with air velocity in the range of 300-4000fpm.
- d. Coordinate with mechanical plans for duct size and provide the appropriate length of sampling tubes.
- e. For maintenance purposes, it shall be possible to clean the duct housing sampling tubes by accessing them through the duct housing front cover.
- 2. Detectors of either design will be provided with relays to connect to the fire alarm panel and DDC panel, as well as connect to a remote status LED.
- 3. Remote status LED will display the detector status exactly the same as the detector. The remote status LED is to indicate the detector is operational, in trouble mode, or in alarm.
 - a. The remote status LED is required if the duct detector is over 10' off the finished floor or is not visible because of a drop ceiling.
 - b. Verify exact location to mount the remote status LED with the local AHJ prior to installation.

2.6 HEAT SENSORS

- A. Thermal Sensor: Combination fixed-temperature and rate-of-rise unit with plug-in base and alarm indication lamp; 135-deg F fixed-temperature setting except as indicated.
- B. Thermal sensor shall be of the epoxy encapsulated electronic design. It shall be thermistor-based, rate-compensated, self-restoring and shall not be affected by thermal lag.
- C. Sensor fixed temperature sensing shall be independent of rate-of-rise sensing to operate at 135-deg F. Sensor rate-of-rise temperature detection shall operate 15-deg F per minute.

2.7 ADDRESSABLE CIRCUIT INTERFACE MODULES

- A. Addressable Circuit Interface Modules: Arrange to monitor or control one or more system components that are not otherwise equipped for addressable communication. Modules shall be used for monitoring of waterflow, valve tamper, non-addressable devices, and for control of AHU systems.
- B. Addressable Circuit Interface Modules will be capable of mounting in a standard electric outlet box. Modules will include cover plates to allow surface or flush mounting. Modules will receive their operating power from the signaling line circuit or a separate two wire pair running from an appropriate power supply, as required.
- C. All Circuit Interface Modules shall be supervised and uniquely identified by the control unit. Module identification shall be transmitted to the control unit for processing according to the program instructions. Modules shall have an on-board LED to provide an indication that the module is powered and communicating with the FACP. The LEDs shall provide a troubleshooting aid since the LED blinks on poll whenever the peripheral is powered and communicating.

2.8 STANDARD ALARM NOTIFICATION APPLIANCES

- A. Horn: Piezoelectric type horn shall be listed to UL 464. The horn shall have a minimum sound pressure level of 85 dBA @ 24VDC. The horn shall mount directly to a standard single gang, double gang or 4" square electrical box, without the use of special adapter or trim rings.
- B. Visible/Only: Strobe shall be listed to UL 1971. The V/O shall consist of a xenon flash tube and associated lens/reflector system. The V/O enclosure shall mount directly to standard single gang, double gang or 4" square electrical box, without the use of special adapters or trim rings. V/O appliance shall be provided with selective minimum flash intensities of 15cd, 30cd, 75cd and 110cd. Provide a visible indication inside the strobe lens to indicate the listed candela rating of the specific Visible/Only appliance.
- C. Audible/Visible: Combination Audible/Visible (A/V) Notification Appliances shall be listed to UL 1971 and UL 464. The strobe light shall consist of a xenon flash tube and associated lens/reflector system. The A/V appliance shall be provided with selective minimum flash intensities of 15cd, 30cd, 75cd and 110cd. Provide a visible indication inside the strobe lens to indicate the candela rating of the specific strobe. The horn shall have a minimum sound pressure level of 85 dBA @ 24VDC. The audible/visible enclosure shall mount directly to standard single gang, double gang or 4" square electrical box, without the use of special adapters or trim rings.
- D. Notification Appliance Circuit provides synchronization of strobes at a rate of 1Hz and operates horns with a Temporal Code Pattern operation. The circuit shall provide the capability to silence the audible signals, while the strobes continue to flash, over a single pair of wires. The capability to synchronize multiple notification appliance circuits shall be provided.
- E. Accessories: The contractor shall furnish any necessary accessories.

2.9 NAC POWER EXTENDER

- A. The NAC Power Extender panel shall be a stand-alone panel capable of powering a minimum of 4 notification appliance circuits. Notification appliance circuits shall be [Class B, Style Y] [Class A, Style Z] rated at 2 amps each. Panel shall provide capability to be expanded to 8 notification appliance circuits.
- B. The internal power supply & battery charger shall be capable of charging up 12.7 Ah batteries internally mounted or 18Ah batteries mounted in an external cabinet.
- C. The NAC extender panel may be mounted close to the host control panel or can be remotely located.
- D. When connected to a fire alarm control panel one or two standard notification appliance circuits from the main control panel may be used to activate all the circuits on the NAC power extender panel.

E. Alarms from the host fire alarm control panel shall signal the NAC power extender panel to activate. The panel shall monitor itself and each of its NACs for trouble conditions and shall report trouble conditions to the host panel.

PART 3 - EXECUTION

3.1 INSTALLATION, GENERAL

- A. Install system components and all associated devices in accordance with applicable NFPA Standards and manufacturer's recommendations.
- B. Installation personnel shall be supervised by persons who are qualified and experienced in the installation, inspection, and testing of fire alarm systems. Examples of qualified personnel shall include, but not be limited to, the following:
 - 1. Factory trained and certified personnel.
 - 2. National Institute of Certification in Engineering Technologies (NICET) fire alarm level II certified personnel.
 - 3. Personnel licensed or certified by state or local authority.

3.2 WIRING INSTALLATION

- A. System Wiring: Wire and cable shall be a type listed for its intended use by an approval agency acceptable to the Authority Having Jurisdiction (and shall be installed in accordance with the appropriate articles from the current approved edition of NFPA 70: National Electric Code (NEC).
- B. Contractor shall obtain from the Fire Alarm System Manufacturer written instruction regarding the appropriate wire/cable to be used for this installation. No deviation from the written instruction shall be made by the Contractor without the prior written approval of the Fire Alarm System Manufacturer.
- C. Color Coding: Color-code fire alarm conductors differently from the normal building power wiring. Use one color code for alarm initiating device circuits wiring and a different color code for supervisory circuits. Color-code notification appliance circuits differently from alarm-initiating circuits. Paint fire alarm system junction boxes and covers red.

3.3 FIELD QUALITY CONTROL

- A. Certificate of Compliance: Complete and submit to the project engineer in accordance with NFPA 72.
- B. Field-Testing General:
 - 1. Prior to any testing or programming verify numbering scheme, room names, and other means of identifying addressable devices prior to testing and labeling. The

owner will be given a minimum of one week notice prior to the contractor requiring to have the numbering scheme requested by the owner.

- 2. Each addressable analog smoke detector shall be individually field tested prior to installing the device at its designated location to ensure reliability after shipment and storage conditions. A dated log indicating correct address, type of device, sensitivity and initials of the technician performing test using test equipment specifically designed for that purpose shall be prepared and kept for final acceptance documentation. After testing, the detection devices and base shall be labeled with the system address, date and initials of installing technician. Labeling shall not be visible after installation is complete.
- 3. Wiring runs shall be tested for continuity, short circuits and grounds before system is energized. Tests shall check for stray voltage not to exceed 1 volt AC/DC unless otherwise specified by the manufacturer. Resistance, current and voltage readings shall be made as work progresses.
- 4. All test equipment, instruments, tools and labor required to conduct the system tests shall be made available by the installing contractor.
- 5. In addition to the testing specified to be performed by the installing contractor, the installation shall be subject to test by the acceptance inspector.
- C. Final Acceptance Testing:
 - 1. Testing shall be in accordance with NFPA72 and this specification.
 - 2. A final As-built Function Matrix shall be prepared by the installing contractor referencing each alarm input to every output function affected as a result of an alarm, trouble or supervisory condition on that input. In the case of outputs programmed using more complex logic functions involving "any," "or," "not," "count," "time," and "timer" statements; the complete output equation shall be referenced in the matrix.
 - 3. The installing contractor prior to testing shall prepare a complete listing of all device labels for alphanumeric annunciator displays and logging printers.
 - 4. The acceptance inspector shall use the system record drawings during the testing procedure to verify operation as programmed. In conducting the tests, the acceptance inspector shall request demonstration of any or all input and output functions. The items tested shall include but not be limited to the following:
 - a. System wiring shall be tested to demonstrate correct system response and correct subsequent system operation in the event of:
 - 1. Open, shorted and grounded intelligent analog signaling line circuit.
 - 2. Open, shorted and grounded network signaling line circuit.
 - 3. Open, shorted and grounded conventional initiating device circuits.
 - 4. Intelligent device removal.
 - 5. Primary power or battery disconnected.
 - 6. Incorrect device address.
 - 7. Printer trouble, off line or out of paper.
 - 8. Loss of data communications between system control panels.
 - 9. Loss of data communications between system annunciators.
 - b. System evacuation alarm indicating appliances shall be demonstrated as follows:
 - 1. All alarm notification appliances actuate as programmed.
 - 2. Audibility and visibility at required levels.
 - c. System indications shall be demonstrated as follows:

- 1. Correct message display for each alarm input, at the control panel, each remote alphanumeric LCD display.
- 2. Correct annunciator light for each alarm input, at each annunciator and color graphic terminal.
- 3. Correct printer logging for all system activity.
- d. System on-site and/or off-site reporting functions shall be demonstrated as follows:
 - 1. Correct alarm custom message display, address, device type, date and time transmitted for each alarm input.
 - 2. Correct trouble custom message display, address, device type, date and time transmitted for each alarm input.
 - 3. Trouble signals received for disconnect.
- e. Secondary power capabilities shall be demonstrated as follows:
 - 1. System primary power shall be disconnected for a period of time as specified herein. At the end of that period, an alarm condition shall be created and the system shall perform as specified for a period as specified.
 - 2. System primary power shall be restored for forty-eight hours and system-charging current shall be normal trickle charge for a fully charged battery bank.
 - 3. System battery voltages and charging currents shall be checked at the fire alarm control panel using the test codes and displayed on the LCD display.
- 5. In the event of system failure to perform as specified and programmed at the discretion of the acceptance inspector, the test shall be terminated.
 - a. The installing contractor shall retest the system, correcting all deficiencies and providing test documentation to the acceptance inspector.
 - b. In the event that software changes are required during the testing, the system manufacturer to compare the edited program with the original shall furnish a utility program. This utility shall yield a printed list of the changes and all system functions, inputs and outputs affected by the changes. The items listed by this program shall be the minimum acceptable to be retested before calling for resumption of the testing. The printed list and the printer log of the retesting shall be submitted before scheduling of the testing.
 - c. The acceptance inspector may elect to require the complete testing to be performed again if modifications to the system hardware or software warrant complete retesting.
- D. Notify owner representative one week prior to all system testing days so they may witness tests.
- E. Documentation:
 - 1. System documentation shall be furnished to the owner and shall include but not be limited to the following:
 - a. Provide cut sheets for all equipment installed during construction. If multiple items are shown on one page indicate exactly which item was installed. Provide this information in hard copy and on CD with the record drawings.
 - b. System record drawings and wiring details including one set of

reproducible hard copy, as well as, drawings on CD (compact disks) in a both CAD (or compatible program) and PDF.

- c. System operation, installation and maintenance manuals.
- d. Written documentation for all logic modules as programmed for system operation with a matrix showing interaction of all input signals with output commands.
- e. Documentation of system voltage, current and resistance readings taken during the installation and testing.
- f. System program "hard copy" showing system functions, controls and labeling of equipment and devices. Also provide a CD with system file.
- F. Test Equipment: The contractor shall furnish to the owner all test equipment as required to program the field analog devices, specifically an intelligent device programmer-tester or a calibrated smoke generator with power source.
- G. Warranty/Services: The contractor shall warrant the entire system against system hardware and electrical defects including programming software defects for a period described in the contract general conditions, but not less than one year. This period shall begin upon satisfactory completion and certification of final acceptance testing of the system. Contractor shall provide to owner a letter stating the start-date and enddate of warranty period. In addition, the contractor shall also provide an updated list of name(s) and phone number(s) for normal and off-hours contacts necessary to respond to warranty issues. Response to warranty notification shall require a reply within 24 hours of initial contact.

3.4 TRAINING

- A. Provide the services of a factory-authorized service representative to demonstrate the system and train Owner's maintenance personnel as specified below.
 - 1. Train Owner's maintenance personnel in the procedures and schedules involved in operating, troubleshooting, servicing, and preventive maintaining of the system. Provide a minimum of 8 hours' training.
 - 2. Schedule training with the Owner at least seven days in advance.

END OF SECTION 28 31 00