



PLAN NOTES

- 1 DIMMING FUNCTION TO BE INTERGRATED INTO PATIENT BED CONTROLLER. COORDINATE CONTROL AND WIRING REQUIREMENTS WITH EQUIPMENT SUPPLIER (HILL-ROM).
- 2 EXTERIOR SIGNAGE CONNECTION. COORDINATE MOUNTING HEIGHT AND ROUGH-IN REQUIREMENTS WITH SIGNAGE SUPPLIER.
- 3 ROUTE VIA LIGHTING CONTROL PANEL.  
SEE 1 E6.10
- 4 POWER CONNECTION FOR PROCEDURE LIGHT.

GENERAL NOTES

- A. DAISY CHAIN CAT-5 DATA CABLE FROM "N-LIGHT" CONTROL DEVICES TO ALL "N-LIGHT" ENABLED LIGHTING FIXTURES IN CONTROL ZONES INDICATED ON PLANS. INSTALL DATA CABLE IN CONDUIT WHERE LOCATED IN INACCESSIBLE LOCATIONS.
- B. DAISY CHAIN 0-10V CONTROL CABLE FROM DIMMING MODULES TO LIGHTING FIXTURE DRIVERS IN CONTROL ZONES INDICATED ON PLANS. INSTALL CABLE IN CONDUIT WHERE LOCATED IN INACCESSIBLE LOCATIONS.

1 PARTIAL FLOORPLAN - LIGHTING  
E2.14 SCALE: 1/4" = 1'-0"

M Consulting Engineers  
2007 S.E. Ash St.  
Portland, OR 97214  
PHN: (503) 224-0548  
FAX: (503) 224-0877  
INC. WWW.MPE-ENG.COM  
CONTACT: CHRIS WINER

PARTIAL  
FLOORPLAN -  
LIGHTING

E2.14

SLCH - ED and Surgery  
Samaritan Health Services: Lebanon Community Hospital  
525 N. Santiam Highway, Lebanon, OR 97355



ISSUE DATE: 06.05.21

REVISIONS:

- |               |         |
|---------------|---------|
| 120V LTG.     | 9-4-15  |
| SAME DAY REV. | 10-     |
| ASI #7        | 2-25-16 |
| CCD #1        | 6-2-16  |



CLARK KLOS ARCHITECTS, LLC

333 NW 5th Ave.  
Portland, OR 97209