



1 PARTIAL FLOORPLAN - LIGHTING
E2.11 SCALE: 1/4" = 1'-0"

PLAN NOTES

- EXISTING LIGHTING AND LIGHTING CONTROLS IN THIS AREA TO REMAIN.
- FIXTURE REPLACEMENT, DIMMING CONTROL, AND REVISED BRANCH CIRCUIT WIRING IN THIS AREA TO BE ALTERNATE BID ITEM.
- REPLACE EXISTING SWITCHES IN THIS LOCATION WITH SINGLE DIMMER SWITCH AS SHOWN. REWIRE LIGHTING BRANCH CIRCUITING FOR FULL DIMMING CONTROL.
- LIGHTING FIXTURE INSTALLED BEHIND DECORATIVE GLASS PANEL. SEE ARCHITECTURAL DRAWINGS.
- CONNECT TO NEAREST CORRIDOR EMERGENCY FIXTURE.

GENERAL NOTES

- DAISY CHAIN CAT-5 DATA CABLE FROM "N-LIGHT" CONTROL DEVICES TO ALL "N-LIGHT" ENABLED LIGHTING FIXTURES IN CONTROL ZONES INDICATED ON PLANS. INSTALL DATA CABLE IN CONDUIT WHERE LOCATED IN INACCESSIBLE LOCATIONS.
- DAISY CHAIN 0-10V CONTROL CABLE FROM DIMMING MODULES TO LIGHTING FIXTURE DRIVERS IN CONTROL ZONES INDICATED ON PLANS. INSTALL CABLE IN CONDUIT WHERE LOCATED IN INACCESSIBLE LOCATIONS.



ISSUE DATE: 06.05.2015

REVISIONS:

120V LTC.	9-4-15
CCD #06	5-1-17
CCD #09	9-27-17
CCD #10	1-12-18