

PLAN NOTES


- ① GREEN / WHITE LIGHT SELECTOR SWITCH. PROVIDE WITH ENGRAVED LABEL. SEE (3) E6.10
- ② JUNCTION BOX FOR MEDICAL LIGHTING ROOM POWER. SEE VENDOR INSTALLATION DRAWINGS FOR ADDITIONAL ELECTRICAL REQUIREMENTS.
- ③ ROUTE VIA LIGHTING CONTROL PANEL. SEE (1) E6.10
- ④ LIGHTING FIXTURE INSTALLED BEHIND DECORATIVE GLASS PANEL. SEE ARCHITECTURAL DRAWINGS.

GENERAL NOTES

- A. DAISY CHAIN CAT-5 DATA CABLE FROM "N-LIGHT" CONTROL DEVICES TO ALL "N-LIGHT" ENABLED LIGHTING FIXTURES IN CONTROL ZONES INDICATED ON PLANS. INSTALL DATA CABLE IN CONDUIT WHERE LOCATED IN INACCESSIBLE LOCATIONS.
- B. DAISY CHAIN 0-10V CONTROL CABLE FROM DIMMING MODULES TO LIGHTING FIXTURE DRIVERS IN CONTROL ZONES INDICATED ON PLANS. INSTALL CABLE IN CONDUIT WHERE LOCATED IN INACCESSIBLE LOCATIONS.

1 PARTIAL FLOORPLAN - LIGHTING
E2.13 SCALE: 1/4" = 1'-0"

Consulting Engineers
2007 S.E. Ash St.
Portland, OR 97214
PHN: (503) 234-0548
FAX: (503) 234-0677
CONTACT: CHRIS WINER



SLCH - ED and Surgery
Samaritan Health Services: Lebanon Community Hospital
525 N. Santiam Highway, Lebanon, OR 97355


ISSUE DATE: 06.05.21

REVISIONS:

- △ 120V LTG. 9-4-15
△ ASI #7 2-25-16
△ CCD #1 6-2-16

PARTIAL
FLOORPLAN -
LIGHTING

E2.13



CLARK KLOS ARCHITECTS, LLC
Portland, OR 97209
333 NW 5th Ave.