


1 PARTIAL FLOORPLAN - POWER  
E3.12 SCALE: 1/4" = 1'-0"

### PLAN NOTES

- ① EXISTING PANEL TO REMAIN.
- ② MOTOIZED DOOR CONNECTION. COORDAINTE ROUGH-IN AND CONTROL REQUIREMENTS WITH MANUFACTURER.
- ③ CONNECT TO SPARE CIRCUIT BREAKER MADE AVAILABLE FROM DEMOLITION.
- ④ POWER FROM CIRCUIT 2LS-15. VERIFY WIRING AND CONTROL REQUIREMENTS WITH DESIGN/BUILD FIRE ALARM DRAWINGS.
- ⑤ POWER FROM CIRCUIT 2LS-17. VERIFY WIRING AND CONTROL REQUIREMENTS WITH DESIGN/BUILD FIRE ALARM DRAWINGS.
- ⑥ POWER FROM CIRCUIT 2LS-19. VERIFY WIRING AND CONTROL REQUIREMENTS WITH DESIGN/BUILD FIRE ALARM DRAWINGS.



ISSUE DATE: 06.05.2015

REVISIONS:

- | NO.           | DATE    | DESCRIPTION |
|---------------|---------|-------------|
| 6-18-15       |         |             |
| OAR REV.      | 9-14-15 |             |
| SAME DAY REV. | 10-5-15 |             |
| ASI #7        | 2-25-16 |             |
| CCD #05       | 5/01/17 |             |