


**DEMO NOTES:**  
1. REMOVE ALL THE HVAC EQUIPMENT, DUCTWORK, PIPING, PLUMBING FIXTURES, MEDICAL GAS PIPING AND ETC. IN THIS AREA FOR NEW HVAC AND PLUMBING SYSTEMS INSTALLATION.  
2. VERIFY IF ANY HVAC OR PLUMBING EQUIPMENT TO BE DEMOLISHED IS SERVING OUTSIDE OF DEMO AREA AND CONSULT WITH ENGINEER PRIOR TO DEMO WORK.



1 PARTIAL HVAC AND PLUMBING FIXTURES DEMO PLAN  
SCALE: 1/4" = 1'-0"

- DEMO NOTES:**
1. SEE ARCHITECTURAL CONSTRUCTION DOCUMENTS FOR AREA OF WORK.
  2. SEE M6.00 FOR MECHANICAL LEGEND AND P6.00 FOR PLUMBING LEGEND.
  3. ALL SHOWN EXISTING DUCTWORK, DIFFUSERS, EQUIPMENT AND CAPACITIES ARE GATHERED FROM VARIOUS AS BUILTS AND SHOWN FOR REFERENCE ONLY. CONTRACTOR SHALL VERIFY SIZE AND LOCATION PRIOR TO COMMENCING WORK.
  4. VERIFY IF ANY HVAC OR PLUMBING EQUIPMENT TO BE DEMOLISHED IS SERVING OUTSIDE OF DEMO AREA AND CONSULT WITH ENGINEER PRIOR TO DEMO WORK.
  5. SEE PLUMBING FLOOR PLANS P2.XX SERIES FOR DEMO PIPING.
  6. VERIFY IF EXISTING TO STAY DUCTWORK HAVE REQUIRED FIRE/SMOKE DAMPERS AT 2 HOUR WALL. IF NOT, PROVIDE ONE AS REQUIRED BY CODE. COORDINATE ELECTRICAL CONNECTION WITH ELECTRICAL CONTRACTOR.

- KEYED NOTES:**
- ① - REMOVE EXISTING FIXTURE AND CAP CW, HW, V AND W IN CEILING/ FLOOR/ WALL.
  - ② - REMOVE EXISTING FIXTURE AND RECONNECT PIPING TO A NEW ONE.
  - ③ - EXISTING FIXTURE TO REMAIN.
  - ④ - EXISTING TEMPERATURE SENSOR/THERMOSTAT TO BE RELOCATED. SEE HVAC FLOOR PLAN (M2.XX SERIES) FOR NEW LOCATION.

