
A
D
E
G
J
K
L
O
P
R
1
2
3
4
5
6
7
8
9
SIM
NORTH STAIR
265
STUDIO
201A
STUDIO
201
STUDIO
203
STUDIO
205
STUDIO
207
STUDIO
211
ONE BEDROOM
209
ONE BEDROOM
213
ONE BEDROOM
215
SITTING
250
IAC 5A
IAC 5B
PTHP 1
VTHP 1
VTHP 2
300CFM 10X10SA BELOW SOFFIT
135CFM 8X4SA
6"øEA 50CFM
8"ø EXH
10"ø EXH
12"ø EXH
6"ø EXH
6"ø SA
6"øSA 70CFM
6"øSA 100CFM
STAND ALONE SPLIT SYSTEM
6"ø SA
6"øSA 60CFM
TV ROOM
249
IAC 6
6"øEA 75CFM
10"ø SA
ELEV
255
ELEV
254
12"ø OSA UP THRU ROOF.
6"øSA 100CFM
8"øEA 150CFM
6"øSA 50CFM
RR
247
RR
248
6"øSA 50CFM
BATHING
246
8"ø SA
10"ø EXH
8"ø EXH
ERV 1
CLOSET
245
IAC 2.1
LIVING
253
12"ø EXH UP THRU ROOF.
4"øSA 25CFM
CONNECT FROM CASSETTE BELOW. DUCTLESS SPLIT
IAC 1.1A
ACTIVITY
244
6"øSA 85CFM
8"ø SA
IAC 1.1B
2T
0.5T
ACTIVITY DIR.
IAC 1.2T
6"øSA 50CFM
STORAGE
242
4"øSA 15CFM
8"ø SA DN THRU FLOOR TO 1ST FLOOR.
6"øSA 80CFM
UP TO RTU-4
EXERCISE
262
IAC 2.2
UP TO RTU-5
NEED A LOW RA CHASE
20X10 RA DN TO LOW RA
20x10 RA
30x18 SA
30x18 RA
18x12 SA
12x10 SA
8x8 SA
OPEN TO BISTRO BELOW
8X8 SA 300CFM (TYP. OF 4)
12x10 SA
15"ø TAR 8X4SA
8"øSA 200CFM SITTING
50X10 RA DN
8"øEA 200CFM
OPEN TO DINING BELOW
SIDEWALL?
6"øSA 75CFM
BEAUTY
240
8"øSA 200CFM
14"ø SA
18x12 RA
ONE BEDROOM
238
STUDIO
236
STUDIO
234
16x16 EXH
6x14 EXH
ONE BEDROOM (CORNER)
232
SITTING
230
14X14 RA 625CFM
14X14 RA 600CFM
6"øSA 100CFM
8"øSA 200CFM
6"øEA 50CFM
10x8 EXH
DN
10X6 EXH FROM BELOW
STUDIO
231
STUDIO
229
VTHP 2
300CFM 10X10SA BELOW SOFFIT
PTHP 1
135CFM 8X4SA
SA/RA UP TO RTU-6
SA/RA UP TO RTU-2
SA/RA UP TO RTU-1
DOWNSPUT
14X14 RA 400CFM
6"øSA 100CFM
10X10 SA/R DN TO 1ST FLOOR
LINEN
256
12"ø SA
12"ø RA
8"øSA 200CFM
NORTH LAUNDRY
258
8"øRA 200CFM
ONE BEDROOM (CORNER)
216
ONE BEDROOM (CORNER)
210
8"ø RA
SA/RA UP TO RTU-3
10"ø SA
12"ø RA
10"ø EXH
12"ø EXH
8X4SA 135CFM
10X10SA 300CFM BELOW SOFFIT
DOWNSPUT
EAST CORRIDOR
263
ONE BEDROOM
217
ONE BEDROOM
219
ONE BEDROOM
221
ONE BEDROOM
225
ONE BEDROOM
227
EAST STAIRS
266
STUDIO
220
STUDIO
222
STUDIO
223
8"ø EXH
6"ø EXH
8X4SA 135CFM
10X10SA 300CFM BELOW SOFFIT
6"øSA 100CFM
18"ø RA
18x14 SA
18x14 RA
6"ø SA
6"ø EXH
8"øSA 200CFM
SITTING
260
10"ø EXH
12"ø SA
12"ø EXH
6"øSA 100CFM
6"øSA 100CFM
6"ø SA
8"ø EXH
10"ø EXH
12"ø EXH
6"øEA 50CFM
8X4SA 135CFM
10X10SA 300CFM BELOW SOFFIT
135CFM 8X4SA
6"øEA 50CFM
8X4SA 135CFM
10X10SA 300CFM BELOW SOFFIT