


110 SE 8TH AVE.
PORTLAND, OR
97214

HOLSTARC.COM

9035 SE FOSTER RD
PORTLAND, OR 97266

JOB NO. 17001



V.L. — VENTED LINE
* HARD WIRED

MARK NUMBER	
FUEL	ELECTRIC
CAPACITY (GAL)	80
INPUT RATE (KW)	80 KW
RECOVERY CAP. @ 140F TR (GPH)	74 GPH
DESIGN WEIGHT (LBS)	1750
BASIS OF DESIGN: BRADFORD WHITE	E32-80R-3

ARCH		ABOVE FINISHED FLOOR	-----	(CW)	COLD WATER
B.G.		ARCHITECTURAL	-----	(HW)	HOT WATER
BTU		BELOW GRADE	-----	(HWR)	HOT WATER RECIRC
CAP.		BRITISH THERMAL UNIT	-----	(HT)	HOT WATER HEAT TRACED
C.I.		CAPACITY	-----	(W)	BELOW GRADE WASTE
COMP.		CAST IRON	-----	(W)	ABOVE GRADE WASTE
CONT.		COMPARTMENT	-----	(V)	VENT
CU		CONTINUATION	-----	RD	(RD) RAIN DRAIN
DF		CUBIC	-----	OD	(OD) OVERFLOW RAIN DRAIN
DI		DRINKING FOUNTAIN	-----	FDC	(FDC) FIRE DEPARTMENT CONNECTION
DIA.		DEIONIZED (WATER)	-----	A	(A) COMPRESSED AIR
ELEV.		DIAMETER	-----	PHW	(PHW) PROCESS HOT WATER
EW		ELEVATION	-----	PCW	(PCW) PROCESS COLD WATER
FD		ELECTRIC WATER COOLER	-----	VAC	VACUUM
FDC		FLOOR DRAIN	-----	G	(G) NATURAL GAS
F.F.		FIRE DEPARTMENT CONNECTION	-----	F	(F) FIRE WATER
FLG.		FINISH FLOOR	-----		
FT		FLANGE	-----		
G		FOOT / FEET	-----		
GA.		GAS	-----		
GALV.		GAUGE	-----		
GPM		GALVANIZED	-----		
G.V.		GALLONS PER MINUTE	-----		
HP		GATE VALVE	-----		
HR.		HORSEPOWER	-----		
I.E.		HOUR	-----		
kW		INVERT ELEVATION	-----		
LAV		KILOWATT	-----		
LBS		LAVATORY	-----		
MAX.		POUNDS	-----		
MBH		MAXIMUM	-----		
MIN.		THOUSANDS OF BTUs PER HOUR	-----		
M.J.		MINIMUM	-----		
N.I.M.		MECHANICAL JOINT	-----		
OS&Y		NOT IN MECHANICAL	-----		
PROT.		OUTSIDE STEM & YOKE	-----		
PRV		PROTECTION	-----		
PSI, PSIG		PRESSURE REDUCING VALVE	-----		
P/T		POUNDS PER SQUARE INCH	-----		
REQ'D		PRESSURE / TEMPERATURE	-----		
RBP		REQUIRED	-----		
RPM		REDUCED PRESSURE BACKFLOW PREVENTER	-----		
TYP.		REVOLUTIONS PER MINUTE	-----		
UR		TYPICAL	-----		
VTR		URINAL	-----		
WC		VENT THROUGH ROOF	-----		
		WATER CLOSET	-----		

**PERMIT SET**

05.30.2017

issue: date:

△ # revision: date:

title:
PLUMBING
LEGENDS,
DETAILS
AND
SCHEDULES.

sheet:

P6.0

© 2016 HOLST ARCHITECTURE pc

MFIA
INC. Consulting Engineers
2007 S.E. Ash St.
Portland, OR 97214
PHN: (503) 234-0548
FAX: (503) 234-0677
WWW.MFIA-ENG.COM
CONTACT: TAKAKO BAKER