



M Consulting Engineers  
2007 S.E. Ash St.  
Portland, OR 97214  
PH: (503) 234-0548  
FAX: (503) 234-0677  
INC. WWW.MFIA-ENG.COM  
CONTACT: Robert Connell

PERMIT SET

09.17.2018

issue:	date:
50% DD	04.30.2018
100% DD	06.18.2018
50% CD	08.03.2018
PERMIT	09.17.2018

revision:	date:
-----------	-------

title:

LIGHTING PLAN  
LEVEL 2

sheet:

E2.02

KEYED NOTES:

- PROVIDE BATTERY INVERTER FOR TENANT EMERGENCY LIGHTING. LOCATE ABOVE ACCESSIBLE CEILING.
- PROVIDE 120V PHOTOCELL MOUNTED ON ROOF FACING NORTH FOR TENANT EXTERIOR LIGHTING CONTROL. PROVIDE BYPASS "TEST" SWITCH BESIDE PANELBOARD TO TEST FIXTURES DURING DAYLIGHT HOURS - LABEL SWITCH "EXTERIOR LIGHTS TEST SWITCH".



1 LIGHTING PLAN - LEVEL 2  
E2.02 1/8" = 1'-0"

- GENERAL NOTES:
- PROVIDE DIGITAL LIGHTING CONTROLS FOR EACH ROOM/SPACE, CONSISTING OF MULTI-BUTTON SWITCHES, OCC SENSORS, POWER PACKS, DAYLIGHT SENSORS, DIMMERS, INTERCONNECTING WIRING, ETC.
  - EXTERIOR LIGHTING TO BE CONTROLLED BY A LIGHTING CONTROL RELAY PANEL WITH ASTRONOMICAL CLOCK.
  - HOUSE EMERGENCY LIGHTING TO BE CONNECTED TO HOUSE EMERGENCY POWER SYSTEM (GENERATOR) WITH EMERGENCY BYPASS POWER PACK/RELAYS CONNECTED TO DIGITAL LIGHTING CONTROL SYSTEM.
  - TENANT EMERGENCY LIGHTING TO HAVE EMERGENCY BATTERY BACKUP OR INVERTER.