

Dream Smart Thermostat

*Residential & Hospitality
Application Guide*



**Smart.
Connected.
Bold.**

Energex



Energex Dream Thermostat, smarts, simplicity and looks.

Welcome to to the dream of smart, connected devices, Intelligent control and intuitive design. The Dream Suite of Commercial and Residential Thermostats is cloud-connected and powered by unlimited wired and wireless sensors designed to provide the ultimate comfort and ease of use.



*Wired & Wireless
PIR Sensors*



*Wired & Wireless
Temp. & Hum. Sensors*




*Wired & Wireless
Door/Window Sensors*



*Local, simple WIFI
Connectivity*



*AI and Machine
learning*



*App and Dashboard
experience*

Important Safety Information and Installation Precautions

Please read all instructions

Failure to follow all instructions may result in equipment damage or a hazardous condition. Read all instructions carefully before installing equipment. Local codes and practices Always install equipment in accordance with the National Electric Code and in a manner acceptable to the local authority having jurisdiction. Please ensure that the thermostat is precisely matched to the type of system it is connected to both in physical connection and thermostat programming. Refer to Energex Dream Thermostat Programming manual for system programming, connectivity and addressing.

Electrostatic sensitivity

This product and its components may be susceptible to electrostatic discharge (ESD). Use appropriate ESD grounding techniques while handling the product. When possible, always handle the product by its non-electrical components.

High voltage safety test

Experienced electricians, at first contact, always assume that hazardous voltages may exist in any wiring system. A safety check using a known, reliable voltage measurement or detection device should be made immediately before starting work and when work resumes.

Lightning and high-voltage danger

Most electrical injuries involving low-voltage wiring result from sudden, unexpected high voltages on normally low voltage wiring. Low-voltage wiring can carry hazardous high voltages under unsafe conditions. Never install or connect wiring or equipment during electrical storms. Improperly protected wiring can carry a fatal lightning surge for many miles. All outdoor wiring must be equipped with properly grounded and listed signal circuit protectors, which must be installed in compliance with local, applicable codes. Never install wiring or equipment while standing in water.


Wiring and equipment separations

All wiring and controllers must be installed to minimize the possibility of accidental contact with other potentially hazardous and disruptive power and lighting wiring. Never place 24VAC or communications wiring near other bare power wires, lightning rods, antennas, transformers, or steam or hot water pipes. Never place wire in any conduit, box, channel, duct or other enclosure containing power or lighting circuits of any type. Always provide adequate separation of communications wiring and other electrical wiring according to code. Keep wiring and controllers at least six feet from large inductive loads (power distribution panels, lighting ballasts, motors, etc.). Failure to follow these guidelines can introduce electrical interference and cause the system to operate erratically.


Warning

This equipment has been tested and found to comply with the limits for a class A digital device, pursuant to part 15 of the FCC rules. These limits are designed to provide reasonable protection against harmful interference when the equipment is operated in a commercial environment. This equipment generates, uses, and can radiate radio frequency energy and, if not installed and used in accordance with the instruction manual, may cause harmful interference to radio communications. Operation of this equipment in a residential area is likely to cause harmful interference, in which case the user will be required to correct the interference at his own expense.

Wireless System Architecture



Second and Third Party Platform Integration



Technical Specifications



Dimensions	4.78" (122mm) wide x 4.78" (122mm) tall x 1.25" (28mm) deep
Heat/Cool Terminals	R, B, W, W1, O, Y1, GL, GH, C, Y2
Electrical Ratings	1.5 Amps per terminal @ 24 Volts
Temperature Control Range	<ul style="list-style-type: none"> ▪Temp control 45°F to 90°F (7°C to 32°C) ▪Display range: 32°F to 99°F (0°C to 37°C) ▪Temperature Differential: adjustable from $\pm 0.25^\circ\text{F}$ to $\pm 2.25^\circ\text{F}$ <i>Accuracy $\pm 1^\circ\text{F}$ over a range of 45°F to 90°F</i>
Environmental Limits	<ul style="list-style-type: none"> ▪Moisture and Dust: meets IP20 ▪Operating Humidity: 20% to 90% (non-condensing) ▪Operating temperature: +14°F to 122°F (+10°C to 50°C) ▪Storage temperature: +40°F to 140°F (-20°C to +60°C)
Wifi Specifications	<ul style="list-style-type: none"> ③ 2.4GHz: 802.11b/g/n ▪SHA256RSA data encryption ▪Network commissioning through iOS/Android app or WPS ▪Program and system settings stored on the device for set up and function - with or without WiFi
Compatible With	<ul style="list-style-type: none"> ▪Universal compatibility for conventional heat & A/Cup to 2-stage heat/2-stage cool, Fan Coil Units, PTHP, PTAC ▪Universal compatibility for heat pumps 2-stage heat/2-stage cool (including AUX/EMERG heat) ▪2& 3-wire heat only hydronic systems (hot water base board & radiator) <p>Up to 6-way Valve Compatibility</p>
Available Voltages	▪24/120V/208V/230V/265V line voltage systems - 0-10V Systems.
Packaging	▪ Master Carton: 36 Units
Remote sensor options:	PIR, Door, Window, Humidity, Temperature

Available Sensors



Wired PIR Sensor - EN-IS215

Simple to install and economical, the EN-IS215 is ideal for new builds and retrofit. Providing 170°Degree views and 40'X40' Coverage. Up to 4 PIR Sensors can be linked in any topography.



Remote Humidity Sensor- EN-IS116

Remote, wireless humidity Humidity Sensor for Improved reading from a secondary location. Operates in the ISM Band 433.3 MHz Range. The Sensor is powered by a 9V Lithium Battery (2 years)



Wireless PIR Sensor - EN-IS215W

Ideal where wiring is a challenge, the EN-IS215W operates in the ISM Band 433.3 MHz Range. The Sensors is powered by a 9V Lithium Battery (2 years). Up to 3 PIR's per Thermostat.



Wireless Door Sensor - EN-AMS101W

Control or signal of Doors and Windows with multiple logic, the EN-AMS101W operates in the ISM Band 433.3 MHz Range. The Sensors is powered by a 9V Lithium Battery (2 years)



Remote Temperature Sensor EN-115RP

Ideal where wiring is a challenge, the EN-IS215W operates in the ISM Band 433.3 MHz Range. The Sensor is powered by a 9V Lithium Battery (2 years)




Wired Door Sensor - EN-AMS101

Ideal where wiring is a challenge, the EN-AMS101 wires directly between Doors, Windows and the thermostat for a variety of setback logic and options.




Front of your Dream Thermostat




Energex Dream Thermostat EN118A-24

Side of your Dream Thermostat



Energex Dream Thermostat EN118A-24

Back of your Dream Thermostat



Energex Dream Thermostat EN118A-24

Thermostats and Devices Placement and mounting.


Please place and mount Thermostats and devices in dry location, free of direct sunlight, heat sources and furniture.

Mount Thermostats directly into drywall or electrical junction box at 48" AFF. In accessible, disability and healthcare, Install thermostat at 42" AFF.


Mount PIR Sensors at 72" – 76" AFF using The provided screws and wall anchors.

Use 4X22AWG Non-Shielded, Non-Stranded Station cable for all wired sensors.


Refer to Programming manual about adding, removing Addressing and commissioning sensor and device.



EN-118A Dream Thermostat Wiring Diagram 24V Systems



EN-118A-3 Dream Thermostat Wiring Diagram 110/208V Systems




- **Please note:** In Heat Pump mode – allow 3-4 minutes delay for compressor protection.
- Terminate Power before Connections.
- In Single Speed systems – Use G, GL Terminal only

Select Fan
Speed Function
1 Speed G
Or 2 speed (GH, GL)
Via 'Settings' > 'System'


Select Function
O=Energize Cool
Or
B=Energize / Heat
via 'Settings' > 'System'

Select System Function Heat
Pump or Std. Heat-Cool via
'Settings' > 'System'

EN-118A Dream Thermostat Wiring Diagram 24V Systems




EN-118A Dream Thermostat Wiring Diagram 110V* Systems



*Use the same wiring diagram for 208/230/277V Models.



Multiple PIR Sensors Wiring Diagram



System Logic and output – Standard Heat / Cool Systems / FCU's

A	<u>Standard Heat-Cool, 1 speed fan w/ Terminal 'B'</u>	System term:	W1	Y1	G	-	B/O
		Stat wire color:	Wht	Yel	Grn	Gry	Brn
						*	
		Norm Cool				-	
		no heat; no cool				-	
		Norm Heat				-	



* Gray is not used
 Rm Temp higher than Set Pt by 2°F
 Rm Temp within 2°F of Set Pt
 Rm Temp lower than Set Pt by 2°F

Volts measured to 24v com (C):  = 24v;  = 0v

System Term R (24v feed) = Stat Red; System Term C (24v Com.) = Stat Blk

B	<u>Standard Heat-Cool, 1 speed fan w/ Terminal 'O'</u>	System term:	W1	Y1	G	-	B/O
		Stat wire color:	Wht	Yel	Grn	Gry	Brn
						*	
		Norm Cool				-	
		no heat; no cool				-	
		Norm Heat				-	



* Gray is not used
 Rm Temp higher than Set Pt by 2°F
 Rm Temp within 2°F of Set Pt
 Rm Temp lower than Set Pt by 2°F

Volts measured to 24v com (C):  = 24v;  = 0v

System Term R (24v feed) = Stat Red; System Term C (24v Com.) = Stat Blk

C	<u>Standard Heat-Cool, 2 speed fan w/ Terminal 'B'</u>	System term:	W1	Y1	GL	GH	B/O
		Stat wire color:	Wht	Yel	Grn	Gry	Brn
		Hi Fan Cool					
		Norm Cool					
		no heat; no cool					
		Norm Heat					
		Hi Fan Heat					



Rm Temp higher than Set Pt by 4°F
 Rm Temp higher than Set Pt by 2°F
 Rm Temp within 2°F of Set Pt
 Rm Temp lower than Set Pt by 2°F
 Rm Temp lower than Set Pt by 4°F

Volts measured to 24v com (C):  = 24v;  = 0v

System Term R (24v feed) = Stat Red; System Term C (24v Com.) = Stat Blk

D	<u>Standard Heat-Cool, 2 speed fan w/ Terminal 'O'</u>	System term:	W1	Y1	GL	GH	B/O
		Stat wire color:	Wht	Yel	Grn	Gry	Brn
		Hi Fan Cool					
		Norm Cool					
		no heat; no cool					
		Norm Heat					
		Hi Fan Heat					

Rm Temp higher than Set Pt by 4°F
 Rm Temp higher than Set Pt by 2°F
 Rm Temp within 2°F of Set Pt
 Rm Temp lower than Set Pt by 2°F
 Rm Temp lower than Set Pt by 4°F

Volts measured to 24v com (C):  = 24v;  = 0v



System Term R (24v feed) = Stat Red; System Term C (24v Com.) = Stat Blk

System Logic and output – Heat Pump Systems

E	<u>Standard Heat Pump, 1 speed fan w/ Terminal 'B'</u>	System term:	W2	Y1/W1	GL	-	B/O
		Stat wire color:	Wht	Yel	Grn	Gry	Brn
						*	
		Norm Cool				-	
		no heat; no cool				-	
		Norm Heat				-	
		Elec Heat				-	

* Gray is not used

Rm Temp higher than Set Pt by 2°F
 Rm Temp within 2°F of Set Pt
 Rm Temp lower than Set Pt by 2°F
 Rm Temp lower than Set Pt by 4°F



Volts measured to 24v com (C):  = 24v;  = 0v

System Term R (24v feed) = Stat Red; System Term C (24v Com.) = Stat Blk

F	<u>Standard Heat Pump, 1 speed fan w/ Terminal 'O'</u>	System term:	W2	Y1/W1	GL	-	B/O
		Stat wire color:	Wht	Yel	Grn	Gry	Brn
						*	
		Norm Cool				-	
		no heat; no cool				-	
		Norm Heat				-	
		Elec Heat				-	

* Gray is not used



Rm Temp higher than Set Pt by 2°F
 Rm Temp within 2°F of Set Pt
 Rm Temp lower than Set Pt by 2°F
 Rm Temp lower than Set Pt by 4°F

Volts measured to 24v com (C):  = 24v;  = 0v

System Term R (24v feed) = Stat Red; System Term C (24v Com.) = Stat Blk

G	<u>Standard Heat Pump, 2 speed fan w/ Terminal 'B'</u>	System term:	W1	Y1/W1	GL	GH	B/O
		Stat wire color:	Wht	Yel	Grn	Gry	Brn
		Hi Fan Cool					
		Norm Cool					
		no heat; no cool					
		Norm Heat					
		Elec Heat + Hi Fan					



Rm Temp higher than Set Pt by 4°F
 Rm Temp higher than Set Pt by 2°F
 Rm Temp within 2°F of Set Pt
 Rm Temp lower than Set Pt by 2°F
 Rm Temp lower than Set Pt by 4°F

Volts measured to 24v com (C):  = 24v;  = 0v

System Term R (24v feed) = Stat Red; System Term C (24v Com.) = Stat Blk

H	<u>Standard Heat Pump, 2 speed fan w/ Terminal 'O'</u>	System term:	W1	Y1/W1	GL	GH	B/O
		Stat wire color:	Wht	Yel	Grn	Gry	Brn
		Hi Fan Cool					
		Norm Cool					
		no heat; no cool					
		Norm Heat					
		Hi Fan Heat					

Rm Temp higher than Set Pt by 4°F
 Rm Temp higher than Set Pt by 2°F
 Rm Temp within 2°F of Set Pt
 Rm Temp lower than Set Pt by 2°F
 Rm Temp lower than Set Pt by 4°F

Volts measured to 24v com (C):  = 24v;  = 0v


System Term R (24v feed) = Stat Red; System Term C (24v Com.) = Stat Blk

EN-118A Dream Thermostat Wiring 0 - 10V Systems

Modulating ECM Fan Coil Unit 6 Ports


Fan Controls:

- (1) Fan Output Adjustment: Fan output requires minimum adjustment (AO2 Low) from 0-5 Vdc and maximum adjustment (AO2 High) from 5 to 10 Vdc. These two output voltages can be gauged by multimeter lively during setting to reflect the setting change effects. These two values are adjusted by balancing contractor that will measure minimum and maximum CFM the fan will supply and set these two values.
- (2) Fan Control: Fan should have option to run continuously at low speed (Fan Low) (say 25-30% of max design airflow) during occupied and dead band for delivery outside air from suite HRV or OA vent duct. If there is a call for 1st. stage heating or cooling the fan would ramp up to medium speed (Fan Med) (50-60% of max design airflow). These two output voltages can be gauged by multimeter lively during setting to reflect the setting change effects. On a 2nd. stage call for heating or cooling (after the heating or cooling modulated fully open) then the Thermostat should be programmed to start ramping the fan airflow from medium to maximum design airflow for the FCU on the project.
- (3) Fan Mode: By pressing FAN button to toggle AUTO icon on and off to represent Auto Mode ("AUTO" show on screen) and Continuous Mode ("AUTO" icon no show). Continuous Mode will keep fan running at low speed in the least while Auto Mode will run from 0%. E.g., during dead band, Auto Mode will stop fan speed while Continuous Mode will run fan at low speed.



6 Port Control Valve sequence:

The control output AO1 to the 6 port control valve is 0-10Vdc modulating to control over 90° rotation. At 0 Vdc the ball valve is in 0° position and 100% heating. At 0–4.5 Vdc the valve modulates heating over 30° rotation. At 5 Vdc the valve is in 45° position and both Heating and Cooling is closed. At 5.5-10Vdc the valve modulates cooling over 30° rotation. At 10 Vdc the valve is in 90° position and 100% cooling. 1 Vdc dead band insures no heating and no cooling when set point is satisfied, there is no possibility of water infiltration from hot water to chilled water system.



Ordering and specification Information

<input type="text"/>	ENE-118A	-	<input type="text"/>	-	<input type="text"/>	-	<input type="text"/>	-	<input type="text"/>	-	<input type="text"/>	-	<input type="text"/>	-	<input type="text"/>	-	<input type="text"/>		
10	ENE-118A	-	A	-	1	-	F	-	P	-	10	-	Y	-	D	-	10	-	Y
Quantity	Energex Dream Thermostat		<u>Color</u> A. White B. Black		<u>Voltage</u> 1. 24VAC 2. 24VDC 3. 110V 4. 208V		<u>Frequency</u> F. 60 Hz. N. 50 Hz.		<u>PIR Sensor</u> P. PIR N. No PIR		<u>No. of PIR's</u> No. of PIR Sensors		<u>Wired</u> Y Yes N No		<u>Door Sensor</u> D. Door Sensor N. No Door Sensor		<u>Door</u> No. of Door Sensors		<u>Wired</u> Y Yes N No

Please consult our sales support team at 1 866 787 1836 for help in ordering, scheduling and specifications.

System Warranty

All parts, components and the workmanship are guaranteed for a period of one year. The warranty period begins at the date of installation and covers against any defects or performance faults.

Energex Inc. will provide with 24 hours a day service hot line and the typical turn-around time for repair is under 48 hours.

The maintenance staff of the hotel will be fully trained in the workings of the system and should be able to troubleshoot any problem in house. As well, several spare systems will be left at the hotel for immediate repairs by the staff if necessary.

Additional warranty can be purchased after the warranty period is over for a cost of \$1.50 per room, per month.

Energex Power Saver Systems Inc. and/or its subsidiaries and its affiliates ("The manufacturer") warrants its products hereinafter referred to as "the product" or "products" to be in conformance with its own plans and specifications and to be free of defects in materials and workmanship under normal use and service for a period of twelve (12) months from the date of installation by a manufacturer authorized personnel. The manufacturer obligations shall be limited within the warranty period, at its option, to repair or replace the product or any part thereof.

Intellectual Property Warranty. Energex Inc. represents and warrants that the products sold and serviced by its authorized distributors, the Equipment and the Documentation, or any part of any of the foregoing, will not infringe or constitute a misappropriation of any right of any third party, including any copyrights, mask work rights, patent rights, trademark rights, trade secret rights or confidentiality rights. All patents, rights, control logic and AI functions are exclusively owned by Energex Inc.

This warranty does not apply in the following cases: misuse, failure to follow operating and maintenance instructions, alterations, abuse, accident or tampering and repair by anyone other than the manufacturer. Any use with 3rd. Party or unauthorized components by Energex Nulls and voids all warranties implied.

This warranty is exclusively and expressly in lieu of all other warranties, obligations or liabilities whether written, oral, expressed or implied, including any warranties of merchantability or fitness for a particular purpose, or otherwise. In no case shall the manufacturer be liable to anyone for any consequential or incidental damages for breach of this warranty or any other warranty.

About Energex – Contact us.

About Energex

Established in 1992 in Vancouver, British Columbia, **Energex** was formed with the mission to develop cost effective energy solutions to help improve comfort prevent energy waste. We are experts at designing and building smart controls, **Energex** identified the potential for an autonomous and networked system which would regulate HVAC run time as well as various other inputs based on occupancy. Energex is an approved vendor to key hospitality brands and has over 350,000 installed rooms worldwide!

Contact us

Energex Inc.

Address: 138 West 8th Avenue
Vancouver BC V5Y 1N2

US Sales: 1460 Broadway,
New York NY 10036

Telephone: 604 448 1899
Toll free: 1 866 787 1836

Website: www.energexinc.com



USA & Caribbean

Hotel Service Corp.
Web: <http://www.hotelservicecorp.com/>
Phone: (800) 523-1829 ext 101

Eastern Canada

Sustainable Resources Management
Phone: (416) 493-9232

Middle East

MAGENTA FZCO
Dubai Silicon Oasis Authority
F - Wing, HQ Building
P.O. Box : 341011
Dubai, UAE.

Email: info@magenta.ae
Web: www.magenta.ae

Mexico & Latin America

Utility Savings Solutions
Web: www.utilityss.com
Phone: (202) 241-5475 (US) MX Phone: 322-192-8041