

BUILDING TEMPERATURE PROFILES

By MFIA Inc.

All hours - Alternative 1

System/Room Description	Unmet	--- Number of Hours at each Temp Range (°F) ---																--- Minimum---				Unmet
	Clg Load	--- Maximum---																				Htg Load
	Hours	Temp	Mo	Hr	Day	>100°	100-95	95-90	90-85	85-80	80-75	75-70	70-65	65-60	60-55	55-50	< 50°	Temp	Mo	Hr	Day	Hours
Chilled Beams-First																						
100 MULTI FAMILY VISITATION	0	75	1	18	Fri	0	0	0	0	0	0	8,760	0	0	0	0	0	70	1	1	Hol	0
101 ADMIN	0	75	7	10	Hol	0	0	0	0	0	24	8,689	47	0	0	0	0	68	2	7	Mon	0
101A MENS	0	75	3	17	Thur	0	0	0	0	0	0	8,753	7	0	0	0	0	70	1	1	Hol	0
101B WOMENS	0	75	3	17	Thur	0	0	0	0	0	0	8,753	7	0	0	0	0	70	1	1	Hol	0
103 SMALL GROUP	0	75	1	22	Thur	0	0	0	0	0	0	8,753	7	0	0	0	0	69	1	3	Hol	0
104 CONSULT	0	75	1	13	Mon	0	0	0	0	0	0	8,708	52	0	0	0	0	69	1	7	Sat	0
105 CONSULT	0	75	1	24	Hol	0	0	0	0	0	0	8,753	7	0	0	0	0	69	1	5	Hol	0
106 TEACHING KITCHEN	0	75	1	22	Wed	0	0	0	0	0	0	8,753	7	0	0	0	0	69	1	7	Hol	0
108 SMALL GROUP	0	75	1	22	Wed	0	0	0	0	0	0	8,753	7	0	0	0	0	70	1	1	Hol	0
109 LARGE GROUP	0	75	1	23	Hol	0	0	0	0	0	0	8,753	7	0	0	0	0	70	1	1	Hol	0
111 MENS	0	75	9	17	Sun	0	0	0	0	0	7	8,745	8	0	0	0	0	70	1	1	Hol	0
112 WAITING	0	75	1	23	Hol	0	0	0	0	0	0	8,753	7	0	0	0	0	69	1	2	Hol	0
113 SMALL GROUP	0	75	1	22	Wed	0	0	0	0	0	0	8,753	7	0	0	0	0	70	1	1	Hol	0
114 SMALL GROUP	0	75	1	22	Wed	0	0	0	0	0	0	8,753	7	0	0	0	0	70	1	1	Hol	0
115 STORAGE	0	75	5	14	Wed	0	0	0	0	0	0	8,753	7	0	0	0	0	69	1	2	Hol	0
116 SMALL GROUP	0	75	1	22	Wed	0	0	0	0	0	0	8,753	7	0	0	0	0	69	1	4	Hol	0
117 LARGE GROUP	0	75	1	22	Hol	0	0	0	0	0	0	8,753	7	0	0	0	0	69	1	5	Hol	0
118 BREAK	0	75	9	17	Sun	0	0	0	0	0	1	8,751	8	0	0	0	0	70	1	1	Hol	0
118A STAFF RR	0	75	3	20	Fri	0	0	0	0	0	41	8,717	2	0	0	0	0	69	1	2	Hol	0
119 TEAMWORK	0	75	1	20	Hol	0	0	0	0	0	0	8,752	8	0	0	0	0	69	1	1	Hol	0
120 CONSULT	0	75	7	10	Thur	0	0	0	0	0	38	8,144	578	0	0	0	0	69	1	6	Hol	0
121 CONSULT	0	75	1	23	Hol	0	0	0	0	0	0	8,753	7	0	0	0	0	69	1	2	Hol	0
122 PRINT	0	75	4	16	Fri	0	0	0	0	0	0	8,753	7	0	0	0	0	69	1	2	Hol	0
123 MEDIUM GROUP	0	75	1	10	Mon	0	0	0	0	0	0	8,753	7	0	0	0	0	69	1	7	Hol	0
124 LARGE GROUP	0	75	1	22	Hol	0	0	0	0	0	0	8,753	7	0	0	0	0	69	1	2	Hol	0
125 RECEPTION	0	75	6	9	Fri	0	0	0	0	0	9	8,751	0	0	0	0	0	70	1	1	Hol	0
125A WOMENS	0	75	7	9	Hol	0	0	0	0	0	29	8,462	269	0	0	0	0	69	1	7	Wed	0
125B MENS	0	75	6	10	Fri	0	0	0	0	0	38	8,452	270	0	0	0	0	69	11	7	Sat	0
126 WOMENS	0	75	7	10	Thur	0	0	0	0	0	41	8,707	12	0	0	0	0	69	2	7	Sun	0
C1 CORRIDOR	0	75	3	15	Tues	0	0	0	0	0	0	8,760	0	0	0	0	0	70	1	1	Hol	0
C1N CORRIDOR	0	75	4	17	Tues	0	0	0	0	0	0	8,760	0	0	0	0	0	70	1	2	Hol	0
C1S CORRIDOR	0	75	5	15	Mon	0	0	0	0	0	0	8,760	0	0	0	0	0	70	1	1	Hol	0
Chilled Beams-second																						
200 WOMENS	0	75	4	18	Fri	0	0	0	0	0	0	8,753	7	0	0	0	0	69	1	1	Hol	0
201 MENS	0	75	4	18	Fri	0	0	0	0	0	0	8,753	7	0	0	0	0	69	1	1	Hol	0
202 SMALL GROUP	0	75	1	14	Hol	0	0	0	0	0	0	8,753	7	0	0	0	0	70	1	1	Hol	0
203 MEDIUM GROUP	0	75	1	22	Hol	0	0	0	0	0	0	8,753	7	0	0	0	0	70	1	1	Hol	0
204 MEDIUM GROUP	0	75	1	22	Hol	0	0	0	0	0	0	8,753	7	0	0	0	0	69	1	1	Hol	0
205 PRINT	0	75	3	19	Thur	0	0	0	0	0	0	8,752	8	0	0	0	0	69	1	2	Hol	0
206 CONSULT	0	75	7	11	Thur	0	0	0	0	0	12	8,221	527	0	0	0	0	69	1	8	Hol	0
207 CONSULT	0	75	1	22	Hol	0	0	0	0	0	0	8,753	7	0	0	0	0	70	1	1	Hol	0
208 TEAMWORK	0	75	8	18	Sun	0	0	0	0	0	9	8,733	18	0	0	0	0	69	1	5	Hol	0
209 OFFICE	0	75	3	1	Tues	0	0	0	0	0	0	8,215	545	0	0	0	0	69	1	24	Fri	0
210 STOR	0	75	3	20	Thur	0	0	0	0	0	0	8,753	7	0	0	0	0	69	1	1	Hol	0
211 CONFERENCE	0	75	1	21	Hol	0	0	0	0	0	0	8,752	8	0	0	0	0	70	1	1	Hol	0

BUILDING TEMPERATURE PROFILES

By MFIA Inc.

All hours - Alternative 1

System/Room Description	Unmet	--- Number of Hours at each Temp Range (°F) ---																--- Minimum---				Unmet
	Clg Load	--- Maximum---																				Htg Load
	Hours	Temp	Mo	Hr	Day	>100°	100-95	95-90	90-85	85-80	80-75	75-70	70-65	65-60	60-55	55-50	< 50°	Temp	Mo	Hr	Day	Hours
212 STAFF RR	0	75	4	18	Fri	0	0	0	0	0	0	8,753	7	0	0	0	0	69	1	1	Hol	0
213 SMALL GROUP	0	75	1	21	Wed	0	0	0	0	0	0	8,753	7	0	0	0	0	70	1	1	Hol	0
214 LARGE GROUP	0	75	1	22	Hol	0	0	0	0	0	0	8,753	7	0	0	0	0	69	1	3	Hol	0
215 SMALL GROUP	0	75	1	21	Wed	0	0	0	0	0	0	8,753	7	0	0	0	0	70	1	1	Hol	0
216 STOR	0	75	5	2	Wed	0	0	0	0	0	0	8,753	7	0	0	0	0	69	1	1	Hol	0
217 LARGE GROUP	0	75	1	23	Hol	0	0	0	0	0	0	8,753	7	0	0	0	0	70	1	1	Hol	0
219 IT	0	75	4	13	Wed	0	0	0	0	0	392	8,361	7	0	0	0	0	68	1	7	Hol	0
220 RECEPTION	0	75	1	22	Hol	0	0	0	0	0	0	8,753	7	0	0	0	0	70	1	1	Hol	0
220A WOMENS	0	75	9	17	Sun	0	0	0	0	0	7	8,500	253	0	0	0	0	68	12	7	Hol	0
220B MENS	0	75	9	18	Sun	0	0	0	0	0	6	8,687	67	0	0	0	0	70	1	1	Hol	0
221 LARGE GROUP	0	75	1	23	Hol	0	0	0	0	0	0	8,753	7	0	0	0	0	69	1	1	Hol	0
222 STOR	0	75	1	23	Fri	0	0	0	0	0	0	8,753	7	0	0	0	0	70	1	1	Hol	0
223 SMALL GROUP	0	75	1	22	Wed	0	0	0	0	0	0	8,753	7	0	0	0	0	69	1	7	Hol	0
224 CONFERENCE	0	75	1	23	Hol	0	0	0	0	0	0	8,753	7	0	0	0	0	69	1	2	Hol	0
225 BREAK	0	75	1	16	Tues	0	0	0	0	0	0	8,752	8	0	0	0	0	69	1	1	Hol	0
225C STAFF RR	0	75	1	17	Tues	0	0	0	0	0	0	8,753	7	0	0	0	0	70	1	1	Hol	0
226 OFFICE	0	75	4	12	Thur	0	0	0	0	0	0	7,365	1,395	0	0	0	0	69	1	23	Sat	0
227 TEAMWORK	0	75	1	22	Mon	0	0	0	0	0	0	8,752	8	0	0	0	0	69	1	4	Hol	0
228 CONSULT	0	75	7	11	Thur	0	0	0	0	0	12	8,220	528	0	0	0	0	69	1	1	Sat	0
229 CONSULT	0	75	1	22	Hol	0	0	0	0	0	0	8,753	7	0	0	0	0	70	1	1	Hol	0
230 PRINT	0	75	3	19	Tues	0	0	0	0	0	0	8,752	8	0	0	0	0	70	1	1	Hol	0
231 MEDIUM GROUP	0	75	1	22	Hol	0	0	0	0	0	0	8,753	7	0	0	0	0	70	1	1	Hol	0
232 LARGE GROUP	0	75	1	23	Hol	0	0	0	0	0	0	8,753	7	0	0	0	0	70	1	1	Hol	0
233 SMALL GROUP	0	75	1	14	Hol	0	0	0	0	0	0	8,753	7	0	0	0	0	70	1	1	Hol	0
234 WAITING	0	75	1	19	Tues	0	0	0	0	0	0	8,747	13	0	0	0	0	70	1	2	Hol	0
235 STOR	0	79	4	17	Wed	0	0	0	0	0	2,485	6,212	63	0	0	0	0	67	1	8	Sat	0
C2 CORRIDOR	0	75	1	18	Tues	0	0	0	0	0	168	8,586	6	0	0	0	0	69	1	7	Hol	0
C2N CORRIDOR	0	75	3	20	Thur	0	0	0	0	0	0	8,753	7	0	0	0	0	69	1	1	Hol	0
C2S CORRIDOR	0	75	4	18	Mon	0	0	0	0	0	0	8,753	7	0	0	0	0	70	1	1	Hol	0
Unconditioned - phantom system																						
001 TUNNEL	0	75	1	11	Hol	0	0	0	0	0	0	8,753	7	0	0	0	0	70	1	1	Hol	0
002 STAIR	0	75	1	11	Hol	0	0	0	0	0	0	8,753	7	0	0	0	0	70	1	1	Hol	0
003 MECHANICAL	0	75	1	11	Hol	0	0	0	0	0	0	8,753	7	0	0	0	0	70	1	1	Hol	0
107 ELECT	0	75	1	11	Hol	0	0	0	0	0	0	8,724	36	0	0	0	0	70	1	1	Hol	0
218 ELECT	0	75	1	13	Hol	0	0	0	0	0	0	8,753	7	0	0	0	0	70	1	1	Hol	0
ST1N STAIR	0	75	1	15	Sun	0	0	0	0	0	0	7,989	771	0	0	0	0	70	1	1	Hol	0
ST1S STAIR	0	75	3	20	Tues	0	0	0	0	0	0	7,015	1,745	0	0	0	0	70	1	1	Hol	0
ST1W STAIR	0	75	3	17	Sun	0	0	0	0	0	0	7,915	845	0	0	0	0	70	1	1	Hol	0
ST2E STAIR	0	75	1	21	Hol	0	0	0	0	0	0	8,753	7	0	0	0	0	70	1	1	Hol	0
ST2N STAIR	0	75	2	21	Wed	0	0	0	0	0	0	8,589	171	0	0	0	0	70	1	1	Hol	0
ST2S STAIR	0	75	2	21	Wed	0	0	0	0	0	0	8,673	87	0	0	0	0	70	1	1	Hol	0
ST2W STAIR	0	75	1	15	Sat	0	0	0	0	0	0	8,519	241	0	0	0	0	70	1	1	Hol	0
ST3C STAIR	0	75	1	12	Hol	0	0	0	0	0	0	8,753	7	0	0	0	0	70	1	1	Hol	0

BUILDING TEMPERATURE PROFILES

By MFIA Inc.

Occupied hours only - Alternative 1

System/Room Description	Unmet	--- Number of Hours at each Temp Range (°F) ---																--- Minimum---				Unmet
	Clg Load Hours	Temp	Mo	Hr	Day	>100°	100-95	95-90	90-85	85-80	80-75	75-70	70-65	65-60	60-55	55-50	< 50°	Temp	Mo	Hr	Day	Htg Load Hours
Chilled Beams-First																						
100 MULTI FAMILY VISITATION	0	75	1	18	Fri	0	0	0	0	0	0	5,110	0	0	0	0	0	70	1	8	Hol	0
101 ADMIN	0	75	7	10	Hol	0	0	0	0	0	24	5,085	1	0	0	0	0	70	1	8	Hol	0
101A MENS	0	75	3	17	Thur	0	0	0	0	0	0	5,110	0	0	0	0	0	70	1	8	Hol	0
101B WOMENS	0	75	3	17	Thur	0	0	0	0	0	0	5,110	0	0	0	0	0	70	1	8	Hol	0
103 SMALL GROUP	0	75	1	10	Sun	0	0	0	0	0	0	5,110	0	0	0	0	0	70	1	8	Hol	0
104 CONSULT	0	75	1	13	Mon	0	0	0	0	0	0	5,090	20	0	0	0	0	70	1	8	Hol	0
105 CONSULT	0	75	1	21	Fri	0	0	0	0	0	0	5,110	0	0	0	0	0	73	1	8	Hol	0
106 TEACHING KITCHEN	0	75	1	20	Thur	0	0	0	0	0	0	5,110	0	0	0	0	0	70	1	8	Hol	0
108 SMALL GROUP	0	75	1	10	Fri	0	0	0	0	0	0	5,110	0	0	0	0	0	70	1	8	Hol	0
109 LARGE GROUP	0	75	1	20	Fri	0	0	0	0	0	0	5,110	0	0	0	0	0	70	1	8	Hol	0
111 MENS	0	75	9	17	Sun	0	0	0	0	0	7	5,102	1	0	0	0	0	70	1	8	Hol	0
112 WAITING	0	75	2	10	Sat	0	0	0	0	0	0	5,110	0	0	0	0	0	70	1	8	Hol	0
113 SMALL GROUP	0	75	1	20	Fri	0	0	0	0	0	0	5,110	0	0	0	0	0	70	1	8	Hol	0
114 SMALL GROUP	0	75	1	10	Fri	0	0	0	0	0	0	5,110	0	0	0	0	0	70	1	8	Hol	0
115 STORAGE	0	75	5	14	Wed	0	0	0	0	0	0	5,110	0	0	0	0	0	70	1	8	Hol	0
116 SMALL GROUP	0	75	1	10	Fri	0	0	0	0	0	0	5,110	0	0	0	0	0	70	1	8	Hol	0
117 LARGE GROUP	0	75	1	10	Mon	0	0	0	0	0	0	5,110	0	0	0	0	0	70	1	8	Hol	0
118 BREAK	0	75	9	17	Sun	0	0	0	0	0	1	5,108	1	0	0	0	0	70	1	8	Hol	0
118A STAFF RR	0	75	3	20	Fri	0	0	0	0	0	18	5,092	0	0	0	0	0	71	1	8	Hol	0
119 TEAMWORK	0	75	1	20	Hol	0	0	0	0	0	0	5,109	1	0	0	0	0	70	1	8	Hol	0
120 CONSULT	0	75	7	10	Thur	0	0	0	0	0	38	4,900	172	0	0	0	0	69	1	8	Thur	0
121 CONSULT	0	75	1	20	Mon	0	0	0	0	0	0	5,110	0	0	0	0	0	71	1	8	Hol	0
122 PRINT	0	75	4	16	Fri	0	0	0	0	0	0	5,110	0	0	0	0	0	70	1	8	Hol	0
123 MEDIUM GROUP	0	75	1	10	Mon	0	0	0	0	0	0	5,110	0	0	0	0	0	70	1	8	Hol	0
124 LARGE GROUP	0	75	1	10	Mon	0	0	0	0	0	0	5,110	0	0	0	0	0	70	1	8	Hol	0
125 RECEPTION	0	75	6	9	Fri	0	0	0	0	0	9	5,101	0	0	0	0	0	70	1	8	Hol	0
125A WOMENS	0	75	7	9	Hol	0	0	0	0	0	29	5,048	33	0	0	0	0	70	1	8	Hol	0
125B MENS	0	75	6	10	Fri	0	0	0	0	0	38	5,002	70	0	0	0	0	70	1	8	Hol	0
126 WOMENS	0	75	7	10	Thur	0	0	0	0	0	41	5,068	1	0	0	0	0	70	1	8	Hol	0
C1 CORRIDOR	0	75	3	15	Tues	0	0	0	0	0	0	5,110	0	0	0	0	0	70	1	8	Hol	0
C1N CORRIDOR	0	75	4	17	Tues	0	0	0	0	0	0	5,110	0	0	0	0	0	71	1	8	Hol	0
C1S CORRIDOR	0	75	5	15	Mon	0	0	0	0	0	0	5,110	0	0	0	0	0	71	1	8	Hol	0
Chilled Beams-second																						
200 WOMENS	0	75	4	18	Fri	0	0	0	0	0	0	5,110	0	0	0	0	0	70	1	8	Hol	0
201 MENS	0	75	4	18	Fri	0	0	0	0	0	0	5,110	0	0	0	0	0	70	1	8	Hol	0
202 SMALL GROUP	0	75	1	14	Hol	0	0	0	0	0	0	5,110	0	0	0	0	0	70	1	8	Hol	0
203 MEDIUM GROUP	0	75	1	10	Mon	0	0	0	0	0	0	5,110	0	0	0	0	0	70	1	8	Hol	0
204 MEDIUM GROUP	0	75	1	10	Mon	0	0	0	0	0	0	5,110	0	0	0	0	0	70	1	8	Hol	0
205 PRINT	0	75	3	19	Thur	0	0	0	0	0	0	5,109	1	0	0	0	0	70	1	8	Hol	0
206 CONSULT	0	75	7	11	Thur	0	0	0	0	0	12	4,902	196	0	0	0	0	69	1	8	Hol	0
207 CONSULT	0	75	1	9	Mon	0	0	0	0	0	0	5,110	0	0	0	0	0	70	1	8	Hol	0
208 TEAMWORK	0	75	8	18	Sun	0	0	0	0	0	9	5,094	7	0	0	0	0	70	1	8	Hol	0
209 OFFICE	0	75	3	16	Tues	0	0	0	0	0	0	4,794	316	0	0	0	0	69	1	9	Wed	0
210 STOR	0	75	3	20	Thur	0	0	0	0	0	0	5,110	0	0	0	0	0	70	1	8	Hol	0
211 CONFERENCE	0	75	1	21	Hol	0	0	0	0	0	0	5,109	1	0	0	0	0	70	1	8	Hol	0

BUILDING TEMPERATURE PROFILES

By MFIA Inc.

Occupied hours only - Alternative 1

System/Room Description	Unmet	--- Number of Hours at each Temp Range (°F) ---																--- Minimum---				Unmet
	Clg Load	--- Maximum---																				Htg Load
	Hours	Temp	Mo	Hr	Day	>100°	100-95	95-90	90-85	85-80	80-75	75-70	70-65	65-60	60-55	55-50	< 50°	Temp	Mo	Hr	Day	Hours
212 STAFF RR	0	75	4	18	Fri	0	0	0	0	0	0	5,110	0	0	0	0	0	70	1	8	Hol	0
213 SMALL GROUP	0	75	1	21	Wed	0	0	0	0	0	0	5,110	0	0	0	0	0	70	1	8	Hol	0
214 LARGE GROUP	0	75	1	9	Fri	0	0	0	0	0	0	5,110	0	0	0	0	0	70	1	8	Hol	0
215 SMALL GROUP	0	75	1	21	Wed	0	0	0	0	0	0	5,110	0	0	0	0	0	70	1	8	Hol	0
216 STOR	0	74	1	19	Hol	0	0	0	0	0	0	5,110	0	0	0	0	0	70	1	8	Hol	0
217 LARGE GROUP	0	75	1	20	Fri	0	0	0	0	0	0	5,110	0	0	0	0	0	70	1	8	Hol	0
219 IT	0	75	4	13	Wed	0	0	0	0	0	389	4,721	0	0	0	0	0	70	1	8	Hol	0
220 RECEPTION	0	75	1	21	Mon	0	0	0	0	0	0	5,110	0	0	0	0	0	70	1	8	Hol	0
220A WOMENS	0	75	9	17	Sun	0	0	0	0	0	7	5,057	46	0	0	0	0	70	1	8	Hol	0
220B MENS	0	75	9	18	Sun	0	0	0	0	0	6	5,070	34	0	0	0	0	70	1	8	Hol	0
221 LARGE GROUP	0	75	1	11	Sat	0	0	0	0	0	0	5,110	0	0	0	0	0	70	1	8	Hol	0
222 STOR	0	75	5	14	Mon	0	0	0	0	0	0	5,110	0	0	0	0	0	70	1	8	Hol	0
223 SMALL GROUP	0	75	1	20	Fri	0	0	0	0	0	0	5,110	0	0	0	0	0	70	1	8	Hol	0
224 CONFERENCE	0	75	1	20	Fri	0	0	0	0	0	0	5,110	0	0	0	0	0	70	1	8	Hol	0
225 BREAK	0	75	1	16	Tues	0	0	0	0	0	0	5,109	1	0	0	0	0	70	1	8	Hol	0
225C STAFF RR	0	75	1	17	Tues	0	0	0	0	0	0	5,110	0	0	0	0	0	70	1	8	Hol	0
226 OFFICE	0	75	4	12	Thur	0	0	0	0	0	0	4,286	824	0	0	0	0	69	1	9	Thur	0
227 TEAMWORK	0	75	1	17	Thur	0	0	0	0	0	0	5,109	1	0	0	0	0	70	1	8	Hol	0
228 CONSULT	0	75	7	11	Thur	0	0	0	0	0	12	4,901	197	0	0	0	0	69	1	8	Wed	0
229 CONSULT	0	75	1	9	Mon	0	0	0	0	0	0	5,110	0	0	0	0	0	70	1	8	Hol	0
230 PRINT	0	75	3	19	Tues	0	0	0	0	0	0	5,109	1	0	0	0	0	70	1	8	Hol	0
231 MEDIUM GROUP	0	75	1	10	Sun	0	0	0	0	0	0	5,110	0	0	0	0	0	70	1	8	Hol	0
232 LARGE GROUP	0	75	1	10	Mon	0	0	0	0	0	0	5,110	0	0	0	0	0	70	1	8	Hol	0
233 SMALL GROUP	0	75	1	14	Hol	0	0	0	0	0	0	5,110	0	0	0	0	0	70	1	8	Hol	0
234 WAITING	0	75	1	19	Tues	0	0	0	0	0	0	5,110	0	0	0	0	0	70	1	8	Hol	0
235 STOR	0	79	4	17	Wed	0	0	0	0	0	2,039	3,023	48	0	0	0	0	67	1	8	Sat	0
C2 CORRIDOR	0	75	1	18	Tues	0	0	0	0	0	151	4,959	0	0	0	0	0	70	1	8	Hol	0
C2N CORRIDOR	0	75	3	20	Thur	0	0	0	0	0	0	5,110	0	0	0	0	0	70	1	8	Hol	0
C2S CORRIDOR	0	75	4	18	Mon	0	0	0	0	0	0	5,110	0	0	0	0	0	70	1	8	Hol	0
Unconditioned - phantom system																						
001 TUNNEL	0	75	1	11	Hol	0	0	0	0	0	0	5,110	0	0	0	0	0	71	1	8	Hol	0
002 STAIR	0	75	1	11	Hol	0	0	0	0	0	0	5,110	0	0	0	0	0	71	1	8	Hol	0
003 MECHANICAL	0	75	1	11	Hol	0	0	0	0	0	0	5,110	0	0	0	0	0	71	1	8	Hol	0
107 ELECT	0	75	1	11	Hol	0	0	0	0	0	0	5,110	0	0	0	0	0	71	1	8	Hol	0
218 ELECT	0	75	1	13	Hol	0	0	0	0	0	0	5,110	0	0	0	0	0	70	1	8	Hol	0
ST1N STAIR	0	75	1	15	Sun	0	0	0	0	0	0	4,804	306	0	0	0	0	70	1	8	Hol	0
ST1S STAIR	0	75	3	20	Tues	0	0	0	0	0	0	4,259	851	0	0	0	0	70	1	8	Hol	0
ST1W STAIR	0	75	3	17	Sun	0	0	0	0	0	0	4,807	303	0	0	0	0	70	1	8	Hol	0
ST2E STAIR	0	75	1	21	Hol	0	0	0	0	0	0	5,110	0	0	0	0	0	70	1	8	Hol	0
ST2N STAIR	0	75	2	21	Wed	0	0	0	0	0	0	5,015	95	0	0	0	0	70	1	8	Hol	0
ST2S STAIR	0	75	2	21	Wed	0	0	0	0	0	0	5,073	37	0	0	0	0	70	1	8	Hol	0
ST2W STAIR	0	75	1	15	Sat	0	0	0	0	0	0	5,017	93	0	0	0	0	70	1	8	Hol	0
ST3C STAIR	0	75	1	12	Hol	0	0	0	0	0	0	5,110	0	0	0	0	0	70	1	8	Hol	0

BUILDING TEMPERATURE PROFILES

By MFIA Inc.

All hours - Alternative 2

System/Room Description	Unmet	--- Number of Hours at each Temp Range (°F) ---																--- Minimum---				Unmet	
	Clg Load	--- Maximum---																				Htg Load	
	Hours	Temp	Mo	Hr	Day	>100°	100-95	95-90	90-85	85-80	80-75	75-70	70-65	65-60	60-55	55-50	< 50°	Temp	Mo	Hr	Day	Hours	
System - 001 1st South-West																							
119 TEAMWORK	0	78	5	11	Sat	0	0	0	0	0	14	7,185	1,561	0	0	0	0	68	12	21	Tues	0	
120 CONSULT	0	81	6	9	Sat	0	0	0	0	2	62	5,514	2,552	630	0	0	0	63	2	1	Sun	0	
121 CONSULT	0	79	11	17	Fri	0	0	0	0	0	6,084	2,676	0	0	0	0	0	70	1	1	Hol	0	
122 PRINT	0	76	8	21	Mon	0	0	0	0	0	370	7,663	727	0	0	0	0	67	2	9	Sun	0	
123 MEDIUM GROUP	0	84	5	11	Sat	0	0	0	0	4	4,211	3,450	1,095	0	0	0	0	68	1	8	Mon	0	
124 LARGE GROUP	0	84	5	11	Sat	0	0	0	0	3	4,668	3,649	440	0	0	0	0	69	2	8	Hol	0	
125 RECEPTION	0	79	5	11	Sat	0	0	0	0	0	5,698	3,062	0	0	0	0	0	70	1	1	Hol	0	
125A WOMENS	0	87	6	9	Sat	0	0	0	1	15	191	3,370	3,268	1,688	227	0	0	58	2	7	Mon	0	
125B MENS	0	82	6	9	Sat	0	0	0	0	3	109	4,561	2,813	1,274	0	0	0	62	2	1	Sun	0	
126 WOMENS	0	79	6	9	Sat	0	0	0	0	0	34	5,600	3,009	117	0	0	0	64	12	24	Mon	0	
C1 CORRIDOR	0	79	2	19	Thur	0	0	0	0	0	8,159	601	0	0	0	0	0	70	1	1	Hol	0	
C1S CORRIDOR	0	80	12	18	Sun	0	0	0	0	242	8,302	216	0	0	0	0	0	71	1	1	Hol	0	
System - 002 1st South-East																							
111 MENS	0	76	9	16	Thur	0	0	0	0	0	290	5,393	3,065	12	0	0	0	62	11	1	Sat	0	
112 WAITING	0	77	1	17	Sat	0	0	0	0	0	5,149	3,594	17	0	0	0	0	66	11	1	Sat	0	
113 SMALL GROUP	0	76	2	11	Sun	0	0	0	0	0	2,701	4,457	1,600	2	0	0	0	64	11	1	Sat	0	
114 SMALL GROUP	0	76	2	11	Sun	0	0	0	0	0	2,718	4,442	1,598	2	0	0	0	64	11	1	Sat	0	
115 STORAGE	1	78	10	18	Thur	0	0	0	0	0	5,112	3,639	9	0	0	0	0	69	1	6	Hol	0	
116 SMALL GROUP	0	76	1	11	Fri	0	0	0	0	0	3,067	4,138	1,554	1	0	0	0	64	11	1	Sat	0	
117 LARGE GROUP	0	77	12	17	Tues	0	0	0	0	0	4,916	3,795	49	0	0	0	0	66	11	1	Sat	0	
118 BREAK	0	76	9	18	Sun	0	0	0	0	0	371	5,687	2,692	10	0	0	0	62	11	1	Sat	0	
118A STAFF RR	2	80	11	18	Sat	0	0	0	0	62	6,355	2,343	0	0	0	0	0	70	1	1	Hol	0	
System - 003 1st North West																							
101 ADMIN	0	77	6	8	Fri	0	0	0	0	0	197	4,411	3,448	704	0	0	0	61	1	1	Mon	0	
101A MENS	0	76	8	21	Sun	0	0	0	0	0	923	7,616	221	0	0	0	0	68	1	3	Wed	0	
101B WOMENS	0	76	8	21	Sun	0	0	0	0	0	923	7,616	221	0	0	0	0	68	1	3	Wed	0	
103 SMALL GROUP	0	78	12	12	Thur	0	0	0	0	0	2,392	4,868	1,500	0	0	0	0	65	3	2	Fri	0	
104 CONSULT	0	77	5	8	Tues	0	0	0	0	0	287	5,937	2,324	212	0	0	0	62	11	2	Tues	0	
105 CONSULT	0	82	11	17	Wed	0	0	0	0	534	5,867	2,295	64	0	0	0	0	69	3	3	Thur	0	
C1N CORRIDOR	0	78	2	22	Mon	0	0	0	0	0	5,547	3,210	3	0	0	0	0	70	10	4	Thur	0	
System - 004 1st North East																							
100 MULTI FAMILY VISITATION	0	76	9	13	Sun	0	0	0	0	0	2,216	6,539	5	0	0	0	0	69	1	1	Hol	0	
108 SMALL GROUP	0	75	12	13	Hol	0	0	0	0	0	30	6,996	1,734	0	0	0	0	68	2	7	Mon	0	
109 LARGE GROUP	0	76	1	17	Wed	0	0	0	0	0	380	7,045	1,335	0	0	0	0	69	2	6	Mon	0	
System - 005 Teaching Kitchen																							
106 TEACHING KITCHEN	0	75	8	17	Sun	0	0	0	0	0	27	7,629	1,104	0	0	0	0	69	1	5	Sat	0	
System - 006 2nd South-West																							
227 TEAMWORK	0	75	7	9	Thur	0	0	0	0	0	157	6,897	1,706	0	0	0	0	67	1	23	Wed	0	
228 CONSULT	0	77	6	8	Fri	0	0	0	0	0	203	4,287	3,200	1,070	0	0	0	62	2	24	Sun	0	
229 CONSULT	0	78	12	18	Sat	0	0	0	0	0	6,332	2,428	0	0	0	0	0	70	1	1	Hol	0	
230 PRINT	0	76	8	21	Mon	0	0	0	0	0	248	6,455	2,057	0	0	0	0	67	2	10	Mon	0	
231 MEDIUM GROUP	0	76	11	11	Thur	0	0	0	0	0	2,882	4,752	1,126	0	0	0	0	68	2	1	Mon	0	
232 LARGE GROUP	0	76	1	17	Tues	0	0	0	0	0	3,450	4,414	896	0	0	0	0	69	3	8	Fri	0	
233 SMALL GROUP	0	76	5	9	Sun	0	0	0	0	0	1,194	6,035	1,531	0	0	0	0	67	2	1	Mon	0	
234 WAITING	0	76	4	10	Wed	0	0	0	0	0	1,786	5,638	1,336	0	0	0	0	68	2	24	Sun	0	

BUILDING TEMPERATURE PROFILES

By MFIA Inc.

All hours - Alternative 2

System/Room Description	Unmet	--- Number of Hours at each Temp Range (°F) ---																--- Minimum---				Unmet
	Clg Load	--- Maximum---																				Htg Load
	Hours	Temp	Mo	Hr	Day	>100°	100-95	95-90	90-85	85-80	80-75	75-70	70-65	65-60	60-55	55-50	< 50°	Temp	Mo	Hr	Day	Hours
235 STOR	0	78	1	19	Mon	0	0	0	0	0	6,287	2,473	0	0	0	0	0	70	1	1	Hol	0
C2 CORRIDOR	0	77	2	19	Thur	0	0	0	0	0	5,130	3,630	0	0	0	0	0	70	1	1	Hol	0
C2S CORRIDOR	0	78	1	19	Mon	0	0	0	0	0	6,288	2,472	0	0	0	0	0	70	1	1	Hol	0
System - 007 2nd South-East																						
220 RECEPTION	4	80	11	18	Sat	0	0	0	0	0	6,466	2,294	0	0	0	0	0	70	1	1	Hol	0
220A WOMENS	0	76	3	18	Mon	0	0	0	0	0	57	4,283	2,714	1,706	0	0	0	60	2	7	Mon	0
220B MENS	0	75	9	19	Sun	0	0	0	0	0	20	5,544	3,174	22	0	0	0	64	1	10	Fri	0
221 LARGE GROUP	0	77	2	11	Mon	0	0	0	0	0	3,021	4,672	1,067	0	0	0	0	69	11	8	Fri	0
222 STOR	0	78	11	19	Sat	0	0	0	0	0	5,298	3,462	0	0	0	0	0	70	1	1	Hol	0
223 SMALL GROUP	0	77	2	11	Mon	0	0	0	0	0	2,756	4,697	1,307	0	0	0	0	69	1	21	Sat	0
224 CONFERENCE	0	77	1	11	Mon	0	0	0	0	0	3,672	5,085	3	0	0	0	0	70	3	8	Wed	0
225 BREAK	0	75	9	20	Sun	0	0	0	0	0	187	6,521	2,052	0	0	0	0	67	1	11	Fri	0
225C STAFF RR	5	80	11	18	Sat	0	0	0	0	17	6,741	2,002	0	0	0	0	0	70	1	1	Hol	0
226 OFFICE	0	77	8	21	Mon	0	0	0	0	0	941	7,158	661	0	0	0	0	67	1	11	Fri	0
System - 008 2nd North-West																						
200 WOMENS	0	78	11	18	Sat	0	0	0	0	0	6,414	2,346	0	0	0	0	0	70	1	1	Hol	0
201 MENS	0	78	11	18	Sat	0	0	0	0	0	6,414	2,346	0	0	0	0	0	70	1	1	Hol	0
202 SMALL GROUP	0	77	5	10	Mon	0	0	0	0	0	2,092	4,966	1,702	0	0	0	0	66	2	24	Sun	0
203 MEDIUM GROUP	0	77	5	10	Tues	0	0	0	0	0	3,328	4,272	1,160	0	0	0	0	68	2	24	Sun	0
204 MEDIUM GROUP	0	77	5	10	Tues	0	0	0	0	0	3,333	4,265	1,162	0	0	0	0	68	2	24	Sun	0
205 PRINT	0	76	8	20	Mon	0	0	0	0	0	493	6,420	1,847	0	0	0	0	67	2	10	Mon	0
206 CONSULT	0	78	6	8	Fri	0	0	0	0	0	294	4,380	3,098	988	0	0	0	62	2	24	Sun	0
207 CONSULT	0	79	12	18	Sun	0	0	0	0	0	6,434	2,326	0	0	0	0	0	70	1	1	Hol	0
208 TEAMWORK	0	77	8	16	Sun	0	0	0	0	0	1,981	4,797	1,982	0	0	0	0	67	1	2	Sun	0
C2N CORRIDOR	0	78	11	18	Sat	0	0	0	0	0	6,415	2,345	0	0	0	0	0	70	1	1	Hol	0
System - 009 2nd North East																						
209 OFFICE	1	78	8	20	Mon	0	0	0	0	0	1,829	6,084	847	0	0	0	0	68	2	9	Sat	0
210 STOR	1	80	11	18	Sat	0	0	0	0	1	6,657	2,102	0	0	0	0	0	70	1	1	Hol	0
211 CONFERENCE	0	76	9	19	Sun	0	0	0	0	0	1,183	5,859	1,718	0	0	0	0	67	12	24	Tues	0
212 STAFF RR	1	80	11	18	Sat	0	0	0	0	1	6,657	2,102	0	0	0	0	0	70	1	1	Hol	0
213 SMALL GROUP	0	76	2	16	Sun	0	0	0	0	0	2,107	4,997	1,656	0	0	0	0	67	1	24	Thur	0
214 LARGE GROUP	0	77	1	17	Sat	0	0	0	0	0	3,913	4,799	48	0	0	0	0	69	1	23	Fri	0
215 SMALL GROUP	0	76	2	16	Sun	0	0	0	0	0	2,381	4,828	1,551	0	0	0	0	67	1	23	Fri	0
216 STOR	1	80	11	18	Sat	0	0	0	0	1	6,657	2,102	0	0	0	0	0	70	1	1	Hol	0
217 LARGE GROUP	0	76	10	11	Sun	0	0	0	0	0	3,798	4,213	749	0	0	0	0	69	1	23	Fri	0
219 IT	0	76	9	16	Thur	0	0	0	0	0	228	5,183	2,835	514	0	0	0	63	12	1	Mon	0
System - 010 unconditioned																						
001 TUNNEL	0	75	1	10	Hol	0	0	0	0	0	8,753	7	0	0	0	0	0	70	1	1	Hol	0
002 STAIR	0	75	1	10	Hol	0	0	0	0	0	8,753	7	0	0	0	0	0	70	1	1	Hol	0
003 MECHANICAL	0	75	1	10	Hol	0	0	0	0	0	8,753	7	0	0	0	0	0	70	1	1	Hol	0
107 ELECT	0	75	1	10	Hol	0	0	0	0	0	8,566	194	0	0	0	0	0	70	1	1	Hol	0
218 ELECT	0	75	1	11	Hol	0	0	0	0	0	8,753	7	0	0	0	0	0	70	1	1	Hol	0
ST1N STAIR	0	75	1	15	Hol	0	0	0	0	0	5,991	2,769	0	0	0	0	0	70	1	1	Hol	0
ST1S STAIR	0	75	1	17	Fri	0	0	0	0	0	5,333	3,427	0	0	0	0	0	70	1	1	Hol	0
ST1W STAIR	0	75	1	15	Fri	0	0	0	0	0	5,593	3,167	0	0	0	0	0	70	1	1	Hol	0
ST2E STAIR	0	75	1	13	Hol	0	0	0	0	0	8,739	21	0	0	0	0	0	70	1	1	Hol	0

BUILDING TEMPERATURE PROFILES

By MFIA Inc.

All hours - Alternative 2

System/Room Description	Unmet	---- Maximum----				--- Number of Hours at each Temp Range (°F) ---											---- Minimum----				Unmet	
	Clg Load	Temp	Mo	Hr	Day	>100°	100-95	95-90	90-85	85-80	80-75	75-70	70-65	65-60	60-55	55-50	< 50°	Temp	Mo	Hr	Day	Htg Load
ST2N STAIR	0	75	1	18	Tues	0	0	0	0	0	0	8,259	501	0	0	0	0	70	1	1	Hol	0
ST2S STAIR	0	75	1	17	Mon	0	0	0	0	0	0	8,389	371	0	0	0	0	70	1	1	Hol	0
ST2W STAIR	0	75	1	17	Tues	0	0	0	0	0	0	7,347	1,413	0	0	0	0	70	1	1	Hol	0
ST3C STAIR	0	75	1	11	Hol	0	0	0	0	0	0	8,753	7	0	0	0	0	70	1	1	Hol	0

BUILDING TEMPERATURE PROFILES

By MFIA Inc.

Occupied hours only - Alternative 2

System/Room Description	Unmet	--- Number of Hours at each Temp Range (°F) ---																--- Minimum---				Unmet	
	Clg Load Hours	Temp	Mo	Hr	Day	>100°	100-95	95-90	90-85	85-80	80-75	75-70	70-65	65-60	60-55	55-50	< 50°	Temp	Mo	Hr	Day	Htg Load Hours	
System - 001 1st South-West																							
119 TEAMWORK	0	78	5	11	Sat	0	0	0	0	0	12	4,745	353	0	0	0	0	68	12	21	Tues	0	
120 CONSULT	0	81	6	9	Sat	0	0	0	0	2	37	4,199	868	4	0	0	0	64	12	21	Tues	0	
121 CONSULT	0	79	11	17	Fri	0	0	0	0	0	4,229	881	0	0	0	0	0	71	6	8	Fri	0	
122 PRINT	0	76	8	21	Mon	0	0	0	0	0	217	4,551	342	0	0	0	0	67	2	9	Sun	0	
123 MEDIUM GROUP	0	84	5	11	Sat	0	0	0	0	4	3,568	1,456	82	0	0	0	0	68	1	8	Mon	0	
124 LARGE GROUP	0	84	5	11	Sat	0	0	0	0	3	3,818	1,239	50	0	0	0	0	69	2	8	Hol	0	
125 RECEPTION	0	79	5	11	Sat	0	0	0	0	0	4,076	1,034	0	0	0	0	0	71	6	8	Fri	0	
125A WOMENS	0	87	6	9	Sat	0	0	0	1	3	152	2,688	2,038	228	0	0	0	62	2	21	Sun	0	
125B MENS	0	82	6	9	Sat	0	0	0	0	3	74	3,515	1,441	77	0	0	0	63	11	8	Wed	0	
126 WOMENS	0	79	6	9	Sat	0	0	0	0	0	24	4,172	913	1	0	0	0	65	12	21	Tues	0	
C1 CORRIDOR	0	79	2	19	Thur	0	0	0	0	0	4,664	446	0	0	0	0	0	73	7	8	Thur	0	
C1S CORRIDOR	0	80	12	18	Sun	0	0	0	0	192	4,725	193	0	0	0	0	0	73	7	8	Thur	0	
System - 002 1st South-East																							
111 MENS	0	76	9	16	Thur	0	0	0	0	0	290	4,001	819	0	0	0	0	65	2	10	Sun	0	
112 WAITING	0	77	1	17	Sat	0	0	0	0	0	4,299	811	0	0	0	0	0	70	4	8	Tues	0	
113 SMALL GROUP	0	76	2	11	Sun	0	0	0	0	0	2,699	2,193	218	0	0	0	0	68	1	21	Tues	0	
114 SMALL GROUP	0	76	2	11	Sun	0	0	0	0	0	2,715	2,178	217	0	0	0	0	68	1	21	Tues	0	
115 STORAGE	1	78	10	18	Thur	0	0	0	0	0	3,841	1,269	0	0	0	0	0	70	1	8	Hol	0	
116 SMALL GROUP	0	76	1	11	Fri	0	0	0	0	0	3,065	1,836	209	0	0	0	0	68	1	21	Tues	0	
117 LARGE GROUP	0	77	12	17	Tues	0	0	0	0	0	4,220	890	0	0	0	0	0	70	1	21	Tues	0	
118 BREAK	0	76	9	18	Sun	0	0	0	0	0	371	4,036	703	0	0	0	0	66	2	10	Sun	0	
118A STAFF RR	2	80	11	18	Sat	0	0	0	0	62	4,512	536	0	0	0	0	0	72	1	8	Tues	0	
System - 003 1st North West																							
101 ADMIN	0	77	6	8	Fri	0	0	0	0	0	168	3,303	1,621	18	0	0	0	64	2	21	Sun	0	
101A MENS	0	76	8	21	Sun	0	0	0	0	0	647	4,435	28	0	0	0	0	69	2	9	Sun	0	
101B WOMENS	0	76	8	21	Sun	0	0	0	0	0	647	4,435	28	0	0	0	0	69	2	9	Sun	0	
103 SMALL GROUP	0	78	12	12	Thur	0	0	0	0	0	2,346	2,578	186	0	0	0	0	68	2	21	Sun	0	
104 CONSULT	0	77	5	8	Tues	0	0	0	0	0	258	4,397	455	0	0	0	0	66	2	21	Sun	0	
105 CONSULT	0	82	11	17	Wed	0	0	0	0	534	3,989	587	0	0	0	0	0	71	6	8	Fri	0	
C1N CORRIDOR	0	78	1	19	Thur	0	0	0	0	0	3,923	1,187	0	0	0	0	0	72	10	8	Wed	0	
System - 004 1st North East																							
100 MULTI FAMILY VISITATION	0	76	9	13	Sun	0	0	0	0	0	1,649	3,461	0	0	0	0	0	70	2	9	Sun	0	
108 SMALL GROUP	0	75	12	13	Hol	0	0	0	0	0	30	4,828	252	0	0	0	0	68	2	21	Sun	0	
109 LARGE GROUP	0	76	1	17	Wed	0	0	0	0	0	314	4,606	190	0	0	0	0	69	2	21	Sun	0	
System - 005 Teaching Kitchen																							
106 TEACHING KITCHEN	0	75	8	17	Sun	0	0	0	0	0	27	4,937	146	0	0	0	0	69	2	8	Fri	0	
System - 006 2nd South-West																							
227 TEAMWORK	0	75	7	9	Thur	0	0	0	0	0	157	4,457	496	0	0	0	0	68	1	9	Fri	0	
228 CONSULT	0	77	6	8	Fri	0	0	0	0	0	189	3,165	1,627	129	0	0	0	64	12	9	Tues	0	
229 CONSULT	0	78	12	18	Sat	0	0	0	0	0	4,332	778	0	0	0	0	0	72	1	8	Hol	0	
230 PRINT	0	76	8	21	Mon	0	0	0	0	0	213	4,052	845	0	0	0	0	67	2	10	Mon	0	
231 MEDIUM GROUP	0	76	11	11	Thur	0	0	0	0	0	2,878	2,031	201	0	0	0	0	69	3	8	Fri	0	
232 LARGE GROUP	0	76	1	17	Tues	0	0	0	0	0	3,409	1,557	144	0	0	0	0	69	3	8	Fri	0	
233 SMALL GROUP	0	76	5	9	Sun	0	0	0	0	0	1,183	3,651	276	0	0	0	0	68	1	21	Fri	0	
234 WAITING	0	76	4	10	Wed	0	0	0	0	0	1,777	3,098	235	0	0	0	0	68	12	8	Sat	0	

BUILDING TEMPERATURE PROFILES

By MFIA Inc.

Occupied hours only - Alternative 2

System/Room Description	Unmet	--- Number of Hours at each Temp Range (°F) ---																--- Minimum---				Unmet
	Clg Load	--- Maximum---																				Htg Load
	Hours	Temp	Mo	Hr	Day	>100°	100-95	95-90	90-85	85-80	80-75	75-70	70-65	65-60	60-55	55-50	< 50°	Temp	Mo	Hr	Day	Hours
235 STOR	0	78	1	19	Mon	0	0	0	0	0	4,285	825	0	0	0	0	0	72	1	8	Hol	0
C2 CORRIDOR	0	77	2	19	Thur	0	0	0	0	0	3,623	1,487	0	0	0	0	0	71	1	8	Hol	0
C2S CORRIDOR	0	78	1	19	Mon	0	0	0	0	0	4,286	824	0	0	0	0	0	72	1	8	Hol	0
System - 007 2nd South-East																						
220 RECEPTION	4	80	11	18	Sat	0	0	0	0	0	4,518	592	0	0	0	0	0	73	9	8	Fri	0
220A WOMENS	0	76	3	18	Mon	0	0	0	0	0	57	3,419	1,508	126	0	0	0	63	1	10	Fri	0
220B MENS	0	75	9	19	Sun	0	0	0	0	0	20	4,098	979	13	0	0	0	64	1	10	Fri	0
221 LARGE GROUP	0	77	2	11	Mon	0	0	0	0	0	2,993	2,062	55	0	0	0	0	69	11	8	Fri	0
222 STOR	0	78	11	19	Sat	0	0	0	0	0	3,906	1,204	0	0	0	0	0	72	1	8	Hol	0
223 SMALL GROUP	0	77	2	11	Mon	0	0	0	0	0	2,755	2,270	85	0	0	0	0	69	1	21	Sat	0
224 CONFERENCE	0	77	1	11	Mon	0	0	0	0	0	3,441	1,666	3	0	0	0	0	70	3	8	Wed	0
225 BREAK	0	75	9	20	Sun	0	0	0	0	0	187	4,278	645	0	0	0	0	67	1	11	Fri	0
225C STAFF RR	5	80	11	18	Sat	0	0	0	0	17	4,599	494	0	0	0	0	0	73	9	8	Fri	0
226 OFFICE	0	77	8	21	Mon	0	0	0	0	0	548	4,264	298	0	0	0	0	67	1	11	Fri	0
System - 008 2nd North-West																						
200 WOMENS	0	78	11	18	Sat	0	0	0	0	0	4,438	672	0	0	0	0	0	72	1	8	Hol	0
201 MENS	0	78	11	18	Sat	0	0	0	0	0	4,438	672	0	0	0	0	0	72	1	8	Hol	0
202 SMALL GROUP	0	77	5	10	Mon	0	0	0	0	0	2,082	2,734	294	0	0	0	0	67	1	21	Fri	0
203 MEDIUM GROUP	0	77	5	10	Tues	0	0	0	0	0	3,326	1,592	192	0	0	0	0	69	1	21	Fri	0
204 MEDIUM GROUP	0	77	5	10	Tues	0	0	0	0	0	3,331	1,587	192	0	0	0	0	69	1	21	Fri	0
205 PRINT	0	76	8	20	Mon	0	0	0	0	0	461	3,924	725	0	0	0	0	67	2	10	Mon	0
206 CONSULT	0	78	6	8	Fri	0	0	0	0	0	283	3,315	1,454	58	0	0	0	64	1	21	Fri	0
207 CONSULT	0	79	12	18	Sun	0	0	0	0	0	4,467	643	0	0	0	0	0	72	1	8	Hol	0
208 TEAMWORK	0	77	8	16	Sun	0	0	0	0	0	1,925	2,622	563	0	0	0	0	67	12	9	Tues	0
C2N CORRIDOR	0	78	11	18	Sat	0	0	0	0	0	4,438	672	0	0	0	0	0	72	1	8	Hol	0
System - 009 2nd North East																						
209 OFFICE	1	78	8	20	Mon	0	0	0	0	0	1,420	3,335	355	0	0	0	0	68	2	9	Sat	0
210 STOR	1	80	11	18	Sat	0	0	0	0	1	4,570	539	0	0	0	0	0	72	1	8	Hol	0
211 CONFERENCE	0	76	9	19	Sun	0	0	0	0	0	1,179	3,499	432	0	0	0	0	67	1	9	Fri	0
212 STAFF RR	1	80	11	18	Sat	0	0	0	0	1	4,570	539	0	0	0	0	0	72	1	8	Hol	0
213 SMALL GROUP	0	76	2	16	Sun	0	0	0	0	0	2,107	2,721	282	0	0	0	0	68	4	8	Tues	0
214 LARGE GROUP	0	77	1	17	Sat	0	0	0	0	0	3,912	1,196	2	0	0	0	0	70	4	8	Tues	0
215 SMALL GROUP	0	76	2	16	Sun	0	0	0	0	0	2,381	2,463	266	0	0	0	0	68	4	8	Tues	0
216 STOR	1	80	11	18	Sat	0	0	0	0	1	4,570	539	0	0	0	0	0	72	1	8	Hol	0
217 LARGE GROUP	0	76	10	11	Sun	0	0	0	0	0	3,798	1,296	16	0	0	0	0	69	4	8	Tues	0
219 IT	0	76	9	16	Thur	0	0	0	0	0	228	3,930	951	1	0	0	0	65	1	10	Fri	0
System - 010 unconditioned																						
001 TUNNEL	0	75	1	10	Hol	0	0	0	0	0	0	5,110	0	0	0	0	0	71	1	8	Hol	0
002 STAIR	0	75	1	10	Hol	0	0	0	0	0	0	5,110	0	0	0	0	0	71	1	8	Hol	0
003 MECHANICAL	0	75	1	10	Hol	0	0	0	0	0	0	5,110	0	0	0	0	0	71	1	8	Hol	0
107 ELECT	0	75	1	10	Hol	0	0	0	0	0	0	5,110	0	0	0	0	0	71	2	8	Wed	0
218 ELECT	0	75	1	11	Hol	0	0	0	0	0	0	5,110	0	0	0	0	0	71	1	8	Hol	0
ST1N STAIR	0	75	1	15	Hol	0	0	0	0	0	0	4,583	527	0	0	0	0	70	1	8	Hol	0
ST1S STAIR	0	75	1	17	Fri	0	0	0	0	0	0	3,964	1,146	0	0	0	0	70	1	8	Hol	0
ST1W STAIR	0	75	1	15	Fri	0	0	0	0	0	0	4,204	906	0	0	0	0	70	1	8	Hol	0
ST2E STAIR	0	75	1	13	Hol	0	0	0	0	0	0	5,110	0	0	0	0	0	70	2	8	Sun	0

BUILDING TEMPERATURE PROFILES

By MFIA Inc.

Occupied hours only - Alternative 2

System/Room Description	Unmet	---- Maximum----				--- Number of Hours at each Temp Range (°F) ---											---- Minimum----				Unmet	
	Clg Load	Temp	Mo	Hr	Day	>100°	100-95	95-90	90-85	85-80	80-75	75-70	70-65	65-60	60-55	55-50	< 50°	Temp	Mo	Hr	Day	Htg Load
ST2N STAIR	0	75	1	18	Tues	0	0	0	0	0	0	4,948	162	0	0	0	0	70	1	8	Hol	0
ST2S STAIR	0	75	1	17	Mon	0	0	0	0	0	0	5,003	107	0	0	0	0	70	1	8	Hol	0
ST2W STAIR	0	75	1	17	Tues	0	0	0	0	0	0	4,899	211	0	0	0	0	70	1	8	Hol	0
ST3C STAIR	0	75	1	11	Hol	0	0	0	0	0	0	5,110	0	0	0	0	0	71	1	8	Hol	0

BUILDING TEMPERATURE PROFILES

By MFIA Inc.

Unmet Cooling Hours - Alternative 2

System/Room Description	Hr in Day =>	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	Daytype with most Unmet hours	
System - 002 1st South-East																											
115 STORAGE																											
August		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	1	0	0	0	0	0	0	0	0	0	Sat
118A STAFF RR																											
August		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	2	0	0	0	0	0	0	0	0	0	Mon
System - 007 2nd South-East																											
220 RECEPTION																											
August		0	0	0	0	0	0	0	0	0	0	0	0	0	0	1	2	1	0	0	0	0	0	0	0	0	Sat
225C STAFF RR																											
August		0	0	0	0	0	0	0	0	0	0	0	0	0	0	1	3	1	0	0	0	0	0	0	0	0	Mon
System - 009 2nd North East																											
209 OFFICE																											
August		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	1	0	0	0	0	0	0	0	0	0	Sat
210 STOR																											
August		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	1	0	0	0	0	0	0	0	0	0	Sat
212 STAFF RR																											
August		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	1	0	0	0	0	0	0	0	0	0	Sat
216 STOR																											
August		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	1	0	0	0	0	0	0	0	0	0	Sat

*Note: Applying an optimum start schedule of "Available (100%)" may help to reduce the occurrence of unmet loads if they happened during morning pickup or pulldown hours.