



- KEYED NOTES:
1. 4"Ø BA EXH FROM BELOW.
 2. 6"Ø RANGE HOOD EXH FROM BELOW.
 3. 4"Ø BA EXH UP.
 4. LINT TRAPS ON DRYER. SEE 5/M6.4 FOR DETAIL.
 - 4"Ø DRYER EXHAUST DUCT WITH RECESSED DRYER BOX, CONSTRUCTION SOLUTIONS DBX1000, OR APPROVED EQUAL.

- GENERAL NOTES:
1. LIQ & SUCTION REF LINES ARE SHOWN AS A SINGLE PIPE FOR THE PURPOSE OF SHOWING ROUTING OF THE PIPING.
 2. SIDEWALL EXHAUST TERMINATIONS TO BE LOCATED 3'-0" MIN RADIUS FROM ANY OPERABLE WINDOWS. SEE ARCHITECTURAL ELEVATIONS.
 3. TYPICAL DRYER DUCT TO BE CONSTRUCTED AS FOLLOWS: MATERIAL SHALL HAVE A SMOOTH INTERIOR FINISH AND BE 0.016 INCH THICK. RIVET OR SCREW PENETRATIONS TO THE DUCT WALL ARE NOT ACCEPTABLE. DRYER DUCT SHALL BE SUPPORTED EVERY 4 FOOT INTERVALS.
 4. SEE SHEET M6.8 FOR WALL PENETRATION DETAILS. SEE ARCHITECTURAL FOR FLOOR/CEILING PENETRATION DETAIL.
 5. SEE PLUMBING PLANS FOR CONDENSATE DRAIN LINES.
 6. ROUTE EXHAUST DUCT FROM KITCHEN HOOD TO EXTERIOR BETWEEN JOISTS. RATED ASSEMBLIES TO WRAP AROUND EXHAUST DUCT, PER DETAIL A8.11.
 7. BATHROOM CEILING FAN AND DUCTWORK ARE LOCATED IN THE DROPPED CEILING & BELOW RATED ASSEMBLY.



KING+PARKS MULTI-FAMILY RESIDENCES

PROJECT SITE: NE Martin Luther King Jr. Boulevard & N Rosa Parks Way
OWNER: Portland Community Reinvestment Initiatives Inc. (PCRI)
6329 NE Martin Luther King Jr. Blvd. Portland, Oregon 97211



PROJECT NO.	ISSUE DATE
16-0602	11.15.2017
REVISIONS	PLAN CHECK RESPONSE
1	07.15.2018

SHEET
MECHANICAL 2ND
FLOOR PLANS-NORTH
M2.1B
PERMIT SET
© MERRYMAN BARNES ARCHITECTS, INC.

MERRYMAN BARNES ARCHITECTS
Consulting Engineers
2007 S.E. Ash St.
Portland, OR 97214
PHN: (503) 234-0548
FAX: (503) 234-0677
CONTACT: Takako Baker