



STRUCTURAL CALCULATIONS

PROJECT:
**Oregon Convention Center
Chiller Plant Redesign**
777 NE Martin Luther King Jr Blvd
Portland, OR 97232

MFIA, Inc Consulting Engineers
2007 SE Ash St
Portland, OR 97214



EXPIRES: 6-30-19

James G. Pierson, Inc.
Consulting Structural Engineers
610 S.W. ALDER SUITE 918 PORTLAND, OR. 97205
(503) 226-1286 FAX 226-3130

April 30, 2018

Structural Narrative


The four large cooling towers on the lower roof at the east side of the Oregon Convention Center are being replaced with a newer Chiller units that are both smaller and lighter in weight than the existing cooling towers and it will be located in the same area. The existing framing and cooling towers were part of the 1990 construction.

Summary:

The lateral support requirements of the HVAC units can be resisted by the existing beams and posts with a new frame added to these existing posts (frame sized for the smaller unit dimensions). The new cooling tower CT-1 weights 9,500 lbs compared to 14,000 lbs for the old one and the new CT-2, 3, 4 weighs 24,700 lbs compared to 26,000 lbs for the existing units.

The vertical load of the new Cooling Tower is resisted by the existing concrete curb walls on the roof. The curbs act as concrete beams spanning between steel beams that create the roof of the mechanical area. The existing steel beams at the top of the curb will remain with new steel curb located on top of it sized for the footprint of the new, smaller units. Lateral loads are transmitted the exact same as before, just lighter units.

TOPPING
SLAB @ E
OF BM,



James G. Pierson, Inc.

Consulting Structural Engineers
610 S.W. Alder, Suite 918 Portland, Oregon 97205
Tel: (503) 226-1286 Fax: (503) 226-3130

Project

OCC Chillers

Job no.

Location

Portland, OR

Date


4/13/18

Client

MFIA

Sheet no.

Page 3 of 21



COOLING TOWER SUPPORT CURB SECTION

2

3/4" = 1'-0"

11" (4 1/2")

SIB

James G. Pierson, Inc.
 Consulting Structural Engineers
 610 S.W. Alder, Suite 918 Portland, Oregon 97205
 Tel: (503) 226-1286 Fax: (503) 226-3130

Project	OCC Chillers	Job no.
Location	Portland, OR	Date
Client	MFIA	Sheet no.
		Page 4 of 21

Seismic Design Forces on Mechanical Units

Task: Determine the lateral forces (seismic) and required connections for HVAC equipment installed onto a floor or roof of a structure. The vertical adequacy of the structure for the weight of the equipment and other dead and live loads is beyond the scope of this section of the analysis and is by others unless specifically noted herein.

References: 2012 IBC (2014 OSSC) Section 1613.1

ASCE 7-10 Section 13.6 for mechanical components and systems

Criteria:

Seismic Design Category **D**,
Component Importance Factor

$I_p = 1.00$
Latitude = **45.528**
Longitude = **-122.662**
Site class **D**

Risk Category **III**

$W_p = 9500 \text{ lb}$
 $h = 204 \text{ in}$
 $w = 84 \text{ in}$
 $l = 168 \text{ in}$
 $W_{\text{curb}} = 1000 \text{ lb}$
 $h_{\text{curb}} = 48 \text{ in}$

Mapped acceleration parameters (Section 11.4.1)

at short period $S_s = 0.976$
at 1 sec period $S_1 = 0.418$

Site coefficient at short period (Table 11.4-1)

$F_a = 1.110$
at 1 sec period (Table 11.4-2)
 $F_v = 1.582$

Spectral response acceleration parameters

at short period (Eq. 11.4-1)

$S_{MS} = F_a \times S_s = 1.083$

at 1 sec period (Eq. 11.4-2)

$S_{M1} = F_v \times S_1 = 0.661$

Design spectral acceleration parameters (Sect 11.4.4)

at short period (Eq. 11.4-3) $S_{DS} = 2/3 \times S_{MS} = 0.722$

at 1 sec period (Eq. 11.4-4) $S_{D1} = 2/3 \times S_{M1} = 0.441$

4/10/2018 Design Maps Summary Report

USGS Design Maps Summary Report

User-Specified Input


Report Title OCC Chiller
Tue April 10, 2018 21:20:40 UTC

Building Code Reference Document 2012/2015 International Building Code
(which utilizes USGS hazard data available in 2008)

Site Coordinates 45.5282°N, 122.6616°W

Site Soil Classification Site Class D - "Stiff Soil"


Risk Category I/II/III



USGS-Provided Output

$S_s = 0.976 \text{ g}$ $S_{MS} = 1.083 \text{ g}$ $S_{DS} = 0.722 \text{ g}$
 $S_1 = 0.418 \text{ g}$ $S_{M1} = 0.662 \text{ g}$ $S_{D1} = 0.441 \text{ g}$

For information on how the S_s and S_1 values above have been calculated from probabilistic (risk-targeted) and deterministic ground motions in the direction of maximum horizontal response, please return to the application and select the "2009 NEHRP" building code reference document.



Although this information is a product of the U.S. Geological Survey, we provide no warranty, expressed or implied, as to the accuracy of the data contained therein. This tool is not a substitute for technical subject-matter knowledge.

Source: <http://geohazards.usgs.gov/designmaps/us/application.php>

James G. Pierson, Inc. Consulting Structural Engineers 610 S.W. Alder, Suite 918 Portland, Oregon 97205 Tel: (503) 226-1286 Fax: (503) 226-3130	Project	OCC CHILLERS - CT-1	Job no.
	Location	777 NE MLK JR BLVD, Portland, OR	Date
	Client	MFIA Inc, Consulting Engineers	Sheet no.

Application of OSSC and ASCE 7-10 Requirements:

Section 13.3 Attachments for floor or roof mounted equipment greater than 400 lbs in weight need to be designed for seismic forces

Section 13.3-1 - Design for Total Lateral Force

$$F_p = \frac{a_p C_a I_p}{R_p} \left(1 + 3 \frac{h_x}{h_r} \right) W_p$$

Total design lateral force Eq. 13.3-1

Except that: $F_p > 0.7 C_a I_p W_p$ and $F_p \leq 4 C_a I_p W_p$ (32-3)

Table 13.6-1 - Horizontal Force Factors, a_p and R_p

Electrical, mechanical and plumbing equipment and associated conduit and ductwork and piping. - $a_p = 1.0$ and $R_p = 2.5$

Unit on flat roof above mechanical room so $h_x = 16$ ft $h_r = 16$ ft

Load Combinations - Members and the connection design shall use the load combinations and factors specified in Section 2.3.2. The reliability/redundancy factor may be taken as 1.0 and F_p is substituted for Q_e .

Design Lateral Force:

$$F_p = 0.4 * a_p * S_{DS} * I_p / R_p * (1 + 2 * h_x/h_r) * W_p$$

$F_p = 3292.228$ lbs Eq. 13.3-1

F_p need not exceed $F_{p1} = 1.6 * S_{DS} * I_p * W_p = 10974.092$ lbs Eq. 13.3-2

F_p shall not be less than $F_{p2} = 0.3 * S_{DS} * I_p * W_p = 2057.642$ lbs Eq. 13.3-3

The design is controlled by $F_p = 3292.228$ lbs

$$F_{pcurb} = 0.4 * a_p * S_{DS} * I_p / R_p * (1 + 2 * h_x/h_r) * W_{curb}$$

$F_{pcurb} = 346.550$ lbs Eq. 13.3-1

James G. Pierson, Inc. Consulting Structural Engineers 610 S.W. Alder, Suite 918 Portland, Oregon 97205 Tel: (503) 226-1286 Fax: (503) 226-3130	Project	OCC CHILLERS - CT-1	Job no.
	Location	777 NE MLK JR BLVD, Portland, OR	Date
	Client	MFIA Inc, Consulting Engineers	Sheet no.
			5/2/2018

Overtuning:

Overtuning will be controlled by Equation 2.3.2-7 of the Basic Load Combinations for Strength Design which is:

$$0.9 D + E$$


In this equation, according to ASCE 7 the value of E shall include

$$E = pQ_e - 0.2 S_{ds} D = 1.0 Q_e - [0.2 \times S_{DS} \times W_p] = Q_e - 0.144 D$$

Therefore, when substituting Q_e Equation 16-18 becomes $0.756 D + E$

Assume Center of gravity of unit and curb is located at center of height. The following forces apply to allowable stress stability calculations using Equation 16-18 as modified for Q_e

$$\begin{aligned} \text{Unit Mass} &= 0.756 D = 7178.239 \text{ lbs} \\ F_p &= 3292.228 \text{ lbs} \end{aligned}$$



James G. Pierson, Inc. Consulting Structural Engineers 610 S.W. Alder, Suite 918 Portland, Oregon 97205 Tel: (503) 226-1286 Fax: (503) 226-3130	Project	OCC CHILLERS - CT-1	Job no.
	Location	777 NE MLK JR BLVD, Portland, OR	Date
	Client	MFIA Inc, Consulting Engineers	Sheet no.

Compute Stability about bottom of curb

$h = 204.000$ in

$h/2 = 102.000$ in

$h_{\text{curb}} = 48.000$ in

$w = 84.000$ in

$w/2 = 42.000$ in

Overturning_Moment = $F_p \times h/2 + h_{\text{curb}} = 493834.138$ lbs_in

Curb Overturning_Moment_c = $F_{\text{pcurb}} \times h_{\text{curb}} = 16634.413$ lbs_in

Total Overturning Moment = = 510468.551 lbs_in

Restoring_Moment = (UnitMass + UnitMass_c) $\times w/2 = 333221.388$ lbs_in

Safety Factor Against Overturning = Restoring_Moment / TM = 0.653

From this calculation, it is demonstrated that there is some overturning and will need the benefit of hold down anchors. Need to anchor unit for sliding forces also.

James G. Pierson, Inc. Consulting Structural Engineers 610 S.W. Alder, Suite 918 Portland, Oregon 97205 Tel: (503) 226-1286 Fax: (503) 226-3130	Project	OCC CHILLERS - CT-1	Job no.
	Location	777 NE MLK JR BLVD, Portland, OR	Date
	Client	MFIA Inc, Consulting Engineers	Sheet no.




MASON INDUSTRIES, Inc.

Manufacturers of Vibration Control Products
 350 Rabro Drive 2101 W. Crescent Ave., Suite D
 Hauppauge, NY 11788 Anaheim, CA 92801
 631/348-0282 714/535-2727
 FAX 631/348-0279 FAX 714/535-5738
 Info@Mason-Ind.com Info@MasonAnaheim.com
 www.Mason-Ind.com

JOB NAME _____
 CUSTOMER _____
 CUSTOMER P.O. _____
 MASON M.I. _____
 DWG. NO. _____

SLRSO

2" DEFLECTION
 B, B2, C2, 2-C2 & 4-C2
 SERIES SPRING
 MOUNTS



TYPE SLRSO RATINGS

Size	Rated Capacity (lb)	Rated Defl. (in)	Spring Constant (lb/in)	Max. Horiz. Housing G Rating	Spring Color
SLRSO-B-20	20	2.40	8	70.0	Tan
SLRSO-B-26	26	2.18	12	53.9	Wht/Blue
SLRSO-B-35	35	2.20	16	40.0	Purple
SLRSO-B-50	50	2.20	24	28.0	Wht/Red
SLRSO-B-65	65	2.10	31	21.6	Brown
SLRSO-B-85	85	2.10	40	16.5	Wht/Blk
SLRSO-B-115	115	2.00	57	12.2	Silver
SLRSO-B-150	150	2.00	75	9.3	Orange
SLRSO-B2-210	210	2.12	99	6.8	Silver
SLRSO-B2-290	290	2.00	144	4.9	Blue
SLRSO-B2-450#	450	2.00	224	3.2	Tan
SLRSO-B2-680#	680	2.00	340	2.1	Gray
SLRSO-C2-125	125	2.50	50	35.2	Purple
SLRSO-C2-170	170	2.40	70	25.9	Brown
SLRSO-C2-210	210	2.30	90	21.0	Red
SLRSO-C2-260	260	2.20	120	16.9	White
SLRSO-C2-330	330	2.00	165	13.3	Black
SLRSO-C2-460	460	2.00	230	9.6	Blue
SLRSO-C2-610	610	2.00	305	7.2	Green
SLRSO-C2-880#	880	2.00	440	5.0	Gray
SLRSO-C2-1210#	1210	2.00	605	3.6	Silver
SLRSO-C2-1540#	1540	2.00	770	2.9	Gray*
SLRSO-C2-1870#	1870	2.00	935	2.4	Silver*
SLRSO-2-C2-340	340	2.40	140	17.7	Brown
SLRSO-2-C2-420	420	2.30	180	14.3	Red
SLRSO-2-C2-520	520	2.20	240	11.6	White
SLRSO-2-C2-660	660	2.00	330	9.1	Black
SLRSO-2-C2-920	920	2.00	460	6.5	Blue
SLRSO-2-C2-1220	1220	2.00	610	4.9	Green
SLRSO-2-C2-1760#	1760	2.00	880	3.4	Gray
SLRSO-2-C2-2420#	2420	2.00	1210	2.5	Silver
SLRSO-2-C2-3080#	3080	2.00	1540	1.9	Gray*
SLRSO-2-C2-3740#	3740	2.00	1870	1.6	Silver*
SLRSO-4-C2-4840#	4840	2.00	2420	2.2	Silver
SLRSO-4-C2-6160#	6160	2.00	3080	1.7	Gray*
SLRSO-4-C2-7480#	7480	2.00	3740	1.4	Silver*

50% Travel to Solid					
SLRSO Size	Capacity (lbs)	Defl. (in)	SLRSO Size	Capacity (lbs)	Defl. (in)
B2-450	411	1.83	2-C2-2420	2020	1.67
B2-680	565	1.66	2-C2-3080	2570	1.67
C2-880	800	1.82	2-C2-3740	3120	1.67
C2-1210	1010	1.67	4-C2-4840	4040	1.67
C2-1540	1285	1.67	4-C2-6160	5145	1.67
C2-1870	1560	1.67	4-C2-7480	6245	1.67
2-C2-1760	1600	1.82			

SPRING DATA

Size	Spring OD (in)	Free Ht. (in)	Ratio Kx/Ky	Ratio OD/OH
B	2 3/8	4	0.55-0.65	0.95-1.00
B2	2 3/8	4 1/2	0.80-0.90	1.19-1.48
C2	2 7/8	5	0.63-0.85	0.96-1.15

#Published ratings allow minimum 25% additional travel to solid. For 50% minimum specified use the ratings shown above. All springs without "#" have additional travel to solid equal to 50% of the rated deflection.

Illustration shows SLRSO-B housing which contains one (1) B or B2 spring. Not shown is SLRSO-1 housing which contains one (1) C2 spring, SLRSO-2 housing which contains two (2) C2 springs and SLRSO-4 which contains four (4) C2 springs.

Housing load ratings expressed in G's are based on tests with bolted connections to steel top and bottom.

TYPE SLRSO DIMENSIONS (inches)

* with RED inner spring

Size	L	W	H	T	MBD	HCW	HCL	D	E
SLRSO-B, B2	8 1/2	4 1/4	8 3/4	3/8	5/8	2 3/4	7	1/2	1 1/8
SLRSO-C2	9 1/2	5 1/4	8 3/4	3/8	5/8	3 1/2	7 1/2	5/8	1 3/8
SLRSO-2-C2	14	5 1/4	8 3/4	3/8	5/8	3 1/2	12 1/4	5/8	1 3/8
SLRSO-4-C2	13 3/4	8	8 3/4	3/8	3/4	6 1/4	11	7/8	1 3/8

PLAN VIEW OF MOUNT LOCATIONS

TAG : _____
 UNIT : _____



1 :	7 :
2 :	8 :
3 :	9 :
4 :	10 :
5 :	11 :
6 :	12 :
Sets Required :	

Seismic Design Forces on Mechanical Units

Task: Determine the lateral forces (seismic) and required connections for HVAC equipment installed onto a floor or roof of a structure. The vertical adequacy of the structure for the weight of the equipment and other dead and live loads is beyond the scope of this section of the analysis and is by others unless specifically noted herein.

References: 2012 IBC (2014 OSSC) Section 1613.1

ASCE 7-10 Section 13.6 for mechanical components and systems

Criteria:

Seismic Design Category **D**,
Component Importance Factor

$I_p = 1.00$
Latitude = **45.528**
Longitude = **-122.662**
Site class **D**

Risk Category **III**
 $W_p = 24700 \text{ lb}$ $h = 204 \text{ in}$
 $w = 144 \text{ in}$
 $l = 306 \text{ in}$
 $W_{\text{curb}} = 1000 \text{ lb}$
 $h_{\text{curb}} = 48 \text{ in}$

Mapped acceleration parameters (Section 11.4.1)

at short period $S_s = 0.976$
at 1 sec period $S_1 = 0.418$

Site coefficient at short period (Table 11.4-1)

$F_a = 1.110$
at 1 sec period (Table 11.4-2)
 $F_v = 1.582$

Spectral response acceleration parameters

at short period (Eq. 11.4-1)
 $S_{MS} = F_a \times S_s = 1.083$
at 1 sec period (Eq. 11.4-2)
 $S_{M1} = F_v \times S_1 = 0.661$

Design spectral acceleration parameters (Sect 11.4.4)

at short period (Eq. 11.4-3) $S_{DS} = 2/3 \times S_{MS} = 0.722$
at 1 sec period (Eq. 11.4-4) $S_{D1} = 2/3 \times S_{M1} = 0.441$


Application of OSSC and ASCE 7-10 Requirements:

4/10/2018 Design Maps Summary Report

USGS Design Maps Summary Report

User-Specified Input


Report Title OCC Chiller
Tue April 10, 2018 21:20:40 UTC
Building Code Reference Document 2012/2015 International Building Code
(which utilizes USGS hazard data available in 2008)
Site Coordinates 45.5282°N, 122.6616°W
Site Soil Classification Site Class D - "Stiff Soil"
Risk Category I/II/III



USGS-Provided Output

$S_s = 0.976 \text{ g}$ $S_{MS} = 1.083 \text{ g}$ $S_{DS} = 0.722 \text{ g}$
 $S_1 = 0.418 \text{ g}$ $S_{M1} = 0.662 \text{ g}$ $S_{D1} = 0.441 \text{ g}$

For information on how the S_s and S_1 values above have been calculated from probabilistic (risk-targeted) and deterministic ground motions in the direction of maximum horizontal response, please return to the application and select the "2009 NEHRP" building code reference document.



Although this information is a product of the U.S. Geological Survey, we provide no warranty, expressed or implied, as to the accuracy of the data contained therein. This tool is not a substitute for technical subject-matter knowledge.

Source: <http://geohazards.usgs.gov/designmaps/us/application.php>

<p>James G. Pierson, Inc.</p> <p>Consulting Structural Engineers 610 S.W. Alder, Suite 918 Portland, Oregon 97205 Tel: (503) 226-1286 Fax: (503) 226-3130</p>	Project	OCC CHILLERS - CT-2, CT-3, and CT-4	Job no.
	Location	777 NE MLK JR BLVD, Portland, OR	Date
	Client	MFIA Inc, Consulting Engineers	Sheet no.
			Page 10 of 21

Section 13.3 Attachments for floor or roof mounted equipment greater than 400 lbs in weight need to be designed for seismic forces

Section 13.3-1 - Design for Total Lateral Force

$$\text{Total design lateral force } F_p = \frac{a_p C_a I_p}{R_p} \left(1 + 3 \frac{h_x}{h_r} \right) W_p \quad \text{Eq. 13.3-1}$$

Except that: $F_p > 0.7 C_a I_p W_p$ and $F_p \leq 4 C_a I_p W_p$ (32-3)

Table 13.6-1 - Horizontal Force Factors, a_p and R_p

Electrical, mechanical and plumbing equipment and associated conduit and ductwork and piping. - $a_p = 1.0$ and $R_p = 2.5$

Unit on flat roof above mechanical room so $h_x = 16 \text{ ft}$ $h_r = 16 \text{ ft}$

Load Combinations - Members and the connection design shall use the load combinations and factors specified in Section 2.3.2. The reliability/redundancy factor may be taken as 1.0 and F_p is substituted for Q_e .

Design Lateral Force:

$$F_p = 0.4 * a_p * S_{DS} * I_p / R_p * (1 + 2 * h_x/h_r) * W_p \quad F_p = 8559.792 \text{ lbs } \text{Eq. 13.3-1}$$

$$F_p \text{ need not exceed } F_{p1} = 1.6 * S_{DS} * I_p * W_p = 28532.639 \text{ lbs } \text{Eq. 13.3-2}$$

$$F_p \text{ shall not be less than } F_{p2} = 0.3 * S_{DS} * I_p * W_p = 5349.870 \text{ lbs } \text{Eq. 13.3-3}$$

The design is controlled by $F_p = 8559.792 \text{ lbs}$

$$F_{pcurb} = 0.4 * a_p * S_{DS} * I_p / R_p * (1 + 2 * h_x/h_r) * W_{curb} \quad F_{pcurb} = 346.550 \text{ lbs } \text{Eq. 13.3-1}$$

<p>James G. Pierson, Inc.</p> <p>Consulting Structural Engineers 610 S.W. Alder, Suite 918 Portland, Oregon 97205 Tel: (503) 226-1286 Fax: (503) 226-3130</p>	Project	OCC CHILLERS - CT-2, CT-3, and CT-4	Job no.
	Location	777 NE MLK JR BLVD, Portland, OR	Date
	Client	MFIA Inc, Consulting Engineers	Sheet no.
			Page 11 of 21

Overtuning:

Overtuning will be controlled by Equation 2.3.2-7 of the Basic Load Combinations for Strength Design which is:

$$0.9 D + E$$

In this equation, according to ASCE 7 the value of E shall include


$$E = pQ_e - 0.2 S_{ds} D = 1.0 Q_e - [0.2 \times S_{DS} \times W_p] = Q_e - 0.144 D$$

Therefore, when substituting Q_e Equation 16-18 becomes $0.756 D + E$

Assume Center of gravity of unit and curb is located at center of height. The following forces apply to allowable stress stability calculations using Equation 16-18 as modified for Q_e

$$\text{Unit Mass} = \underline{0.756 D} = 18663.420 \text{ lbs}$$

$$F_p = 8559.792 \text{ lbs}$$



<p>James G. Pierson, Inc.</p> <p>Consulting Structural Engineers 610 S.W. Alder, Suite 918 Portland, Oregon 97205 Tel: (503) 226-1286 Fax: (503) 226-3130</p>	Project	OCC CHILLERS - CT-2, CT-3, and CT-4	Job no.
	Location	777 NE MLK JR BLVD, Portland, OR	Date
	Client	MFIA Inc, Consulting Engineers	Sheet no.
			Page 12 of 21

Compute Stability about bottom of curb

$h = 204.000$ in

$h/2 = 102.000$ in

$h_{\text{curb}} = 48.000$ in

$w = 144.000$ in

$w/2 = 72.000$ in

Overturning_Moment = $F_p \times h/2 + h_{\text{curb}} = 1283968.758$ lbs_in

Curb Overturning_Moment_c = $F_{p\text{curb}} \times h_{\text{curb}} = 16634.413$ lbs_in

Total Overturning Moment = = **1300603.171** lbs_in

Restoring_Moment = (UnitMass + UnitMass_c) $\times w/2 = 1398169.740$ lbs_in

Safety Factor Against Overturning = Restoring_Moment / TM = **1.075**

From this calculation, it is demonstrated that there is some overturning and will need the benefit of hold down anchors. Need to anchor unit for sliding forces also.

James G. Pierson, Inc. Consulting Structural Engineers 610 S.W. Alder, Suite 918 Portland, Oregon 97205 Tel: (503) 226-1286 Fax: (503) 226-3130	Project	OCC CHILLERS - CT-2, CT-3, and CT-4	Job no.
	Location	777 NE MLK JR BLVD, Portland, OR	Date 5/1/2018
	Client	MFIA Inc, Consulting Engineers	Sheet no. Page 13 of 21

Wind Loads on Rooftop Structures and Equipment for buildings with $h \leq 60$ ft, ASCE7-10 Sec 29.5.1

Lateral force, $F_h = q_h * GC_r * A_f$ - 29.5-2

$q_h = 0.00256 * K_z * K_d * K_{zt} * V^2$ psf- 29.3-1

The following table shows the calculation for lateral force and net uplift on roof top equipment along long and short directions :

Long Direction :

$OTM = F_{h-long} * Total\ Height/2$; $R.M = Total\ Weight * Width/2$

$T/C(lbs) = (O.T.M - 0.6 R.M)/Width$

Short Direction:

$OTM = F_{h-short} * Total\ Height/2$; $RM = Total\ weight * Length/2$

$T/C(lbs) = (OTM-0.6RM)/length$

ASCE7-10,Sec 29.5.1 Windloads for Roof top Structures, $h \leq 60$ ft

All units in lb,ft

Unit Tag Component Data		Building Dimesnions		Wind Parameters	
Component Weight ,Wp	24600	Building Length ,L	150	Basic Wind Speed,mph (Sec 26.5)	120
Curb Weight, Wc	1000	Building Width. B	150	Wind directionality Factor K_d (Sec 26.6)	0.85
Total Weight, W	25600	Building Height , h	30	Exposure Category (Sec 26.7)	B
Component Height ,H	17			Topographic factor K_{zt} (Sec 26.8)	1
Component Length, l	25			velocity pressure coefficient K_z (Sec 29.3.1)	0.701
Component Width , W	12			velocity pressure q_z or q_h in psf (sec 29.3.2)	21.953
Height of Curb	1				
Total Height	18				

As per section 29.5.1	long	short
Vertically projected Area A_f	450.00	216.00
Guss coefficient GC_r	1.9	1.9
q_z or q_h in psf(ASD)	13.22	13.22
Lateral Force F_h , lbs($q_h * GC_r * A_f$)	11306.91	5427.32
Total OTM ,ft-lb($F_h * Htotal/2$)	101762.21	48845.86
Total RM,ft-lb (Total Weight*(width or length)/2)	153600	320000
T/C,lbs ((OTM - 0.6RM)/(width or length)	800.18	-5726.17

Overturning. Need to bolt to frame

James G. Pierson, Inc. Consulting Structural Engineers 610 S.W. Alder, Suite 918 Portland, Oregon 97205 Tel: (503) 226-1286 Fax: (503) 226-3130	Project	OCC CHILLERS - CT-2, CT-3, and CT-4	Job no.
	Location	777 NE MLK JR BLVD, Portland, OR	Date
	Client	MFIA Inc, Consulting Engineers	Sheet no.
			Page of 21




MASON INDUSTRIES, Inc.

Manufacturers of Vibration Control Products
 350 Rabro Drive 2101 W. Crescent Ave., Suite D
 Hauppauge, NY 11788 Anaheim, CA 92801
 631/348-0282 714/535-2727
 FAX 631/348-0279 FAX 714/535-5738
 Info@Mason-Ind.com Info@MasonAnaheim.com
 www.Mason-Ind.com

JOB NAME _____
 CUSTOMER _____
 CUSTOMER P.O. _____
 MASON M.I. _____
 DWG. NO. _____

SLRSO

2" DEFLECTION
 B, B2, C2, 2-C2 & 4-C2
 SERIES SPRING
 MOUNTS



TYPE SLRSO RATINGS

Size	Rated Capacity (lb)	Rated Defl. (in)	Spring Constant (lb/in)	Max. Horiz. Housing G Rating	Spring Color
SLRSO-B-20	20	2.40	8	70.0	Tan
SLRSO-B-26	26	2.18	12	53.9	Wht/Blue
SLRSO-B-35	35	2.20	16	40.0	Purple
SLRSO-B-50	50	2.20	24	28.0	Wht/Red
SLRSO-B-65	65	2.10	31	21.6	Brown
SLRSO-B-85	85	2.10	40	16.5	Wht/Blk
SLRSO-B-115	115	2.00	57	12.2	Silver
SLRSO-B-150	150	2.00	75	9.3	Orange
SLRSO-B2-210	210	2.12	99	6.8	Silver
SLRSO-B2-290	290	2.00	144	4.9	Blue
SLRSO-B2-450#	450	2.00	224	3.2	Tan
SLRSO-B2-680#	680	2.00	340	2.1	Gray
SLRSO-C2-125	125	2.50	50	35.2	Purple
SLRSO-C2-170	170	2.40	70	25.9	Brown
SLRSO-C2-210	210	2.30	90	21.0	Red
SLRSO-C2-260	260	2.20	120	16.9	White
SLRSO-C2-330	330	2.00	165	13.3	Black
SLRSO-C2-460	460	2.00	230	9.6	Blue
SLRSO-C2-610	610	2.00	305	7.2	Green
SLRSO-C2-880#	880	2.00	440	5.0	Gray
SLRSO-C2-1210#	1210	2.00	605	3.6	Silver
SLRSO-C2-1540#	1540	2.00	770	2.9	Gray*
SLRSO-C2-1870#	1870	2.00	935	2.4	Silver*
SLRSO-2-C2-340	340	2.40	140	17.7	Brown
SLRSO-2-C2-420	420	2.30	180	14.3	Red
SLRSO-2-C2-520	520	2.20	240	11.6	White
SLRSO-2-C2-660	660	2.00	330	9.1	Black
SLRSO-2-C2-920	920	2.00	460	6.5	Blue
SLRSO-2-C2-1220	1220	2.00	610	4.9	Green
SLRSO-2-C2-1760#	1760	2.00	880	3.4	Gray
SLRSO-2-C2-2420#	2420	2.00	1210	2.5	Silver
SLRSO-2-C2-3080#	3080	2.00	1540	1.9	Gray*
SLRSO-2-C2-3740#	3740	2.00	1870	1.6	Silver*
SLRSO-4-C2-4840#	4840	2.00	2420	2.2	Silver
SLRSO-4-C2-6160#	6160	2.00	3080	1.7	Gray*
SLRSO-4-C2-7480#	7480	2.00	3740	1.4	Silver*

50% Travel to Solid					
SLRSO Size	Capacity (lbs)	Defl. (in)	SLRSO Size	Capacity (lbs)	Defl. (in)
B2-450	411	1.83	2-C2-2420	2020	1.67
B2-680	565	1.66	2-C2-3080	2570	1.67
C2-880	800	1.82	2-C2-3740	3120	1.67
C2-1210	1010	1.67	4-C2-4840	4040	1.67
C2-1540	1285	1.67	4-C2-6160	5145	1.67
C2-1870	1560	1.67	4-C2-7480	6245	1.67
2-C2-1760	1600	1.82			

SPRING DATA

Size	Spring OD (in)	Free Ht. (in)	Ratio Kx/Ky	Ratio OD/OH
B	2 3/8	4	0.55-0.65	0.95-1.00
B2	2 3/8	4 1/2	0.80-0.90	1.19-1.48
C2	2 7/8	5	0.63-0.85	0.96-1.15

#Published ratings allow minimum 25% additional travel to solid. For 50% minimum specified use the ratings shown above. All springs without "#" have additional travel to solid equal to 50% of the rated deflection.

Illustration shows SLRSO-B housing which contains one (1) B or B2 spring. Not shown is SLRSO-1 housing which contains one (1) C2 spring, SLRSO-2 housing which contains two (2) C2 springs and SLRSO-4 which contains four (4) C2 springs.

Housing load ratings expressed in G's are based on tests with bolted connections to steel top and bottom.

TYPE SLRSO DIMENSIONS (inches)

* with RED inner spring


Size	L	W	H	T	MBD	HCW	HCL	D	E
SLRSO-B, B2	8 1/2	4 1/4	8 3/4	3/8	5/8	2 3/4	7	1/2	1 1/8
SLRSO-C2	9 1/2	5 1/4	8 3/4	3/8	5/8	3 1/2	7 1/2	5/8	1 3/8
SLRSO-2-C2	14	5 1/4	8 3/4	3/8	5/8	3 1/2	12 1/4	5/8	1 3/8
SLRSO-4-C2	13 3/4	8	8 3/4	3/8	3/4	6 1/4	11	7/8	1 3/8

PLAN VIEW OF MOUNT LOCATIONS

TAG : _____
 UNIT : _____



1 :	7 :
2 :	8 :
3 :	9 :
4 :	10 :
5 :	11 :
6 :	12 :
Sets Required :	





GENERAL NOTES

BASIN DATA (PER MODULE):	
MIN/MAX GPM RANGE	- 200/600
ACTUAL GPM	-
HOT WATER TEMP F°	-
COLD WATER TEMP F°	-
WET BULB TEMP F°	-
MOTOR DATA (PER MODULE):	
BRAND	- BALDOR (OR EQUIV.)
EFFICIENCY	- HIGH
HP	- 3.0 / 5.0 / 7.5
KW	- 2.2 / 3.7 / 5.6
VOLTAGE	- 200 / 230 / 460 / 575
HZ	- 60
PHASE	- 3
NUMBER	- 2
POWER FACTOR	- .61 / .63 / .68

WEIGHTS (PER MODULE):	
DRY SHIPPING WEIGHT	- 4,360lbs, - 1,978 kg
OPERATING WEIGHT	- 9,470 lbs, - 4,305 kg

NOTES:

1. ALL EXTERNAL PIPING PROVIDED BY CUSTOMER.
2. EXTERNAL PIPING TO BE "STAND ALONE" (INDEPENDENTLY SUPPORTED). FINAL CONNECTIONS TO THE COOLING TOWER MODULE MUST BE FIELD FITTED AFTER TOWER INSTALLATION TO PREVENT PIPE STRESS ON TOWER. NO LOAD TO BE APPLIED TO TOWER TECH TOWER OR SUMP.
3. FOR APPROPRIATE WATER LEVEL REFER TO STARTUP SECTION IN TOWER TECH'S DESIGN, INSTALLATION & OPERATION MANUAL.
4. MAKE-UP CONNECTION/FLOAT VALVE CONNECTION FLANGE IS MADE FROM HIGH QUALITY PLASTIC TO ELIMINATE CORROSION.
5. THE MAXIMUM MAKE-UP INLET PRESSURE IS 25 PSIG WHEN USING A MECHANICAL FLOAT VALVE. FLOAT VALVE MAY NOT SHUT OFF AGAINST HIGHER PRESSURES. *THERE ARE NO MAXIMUM PRESSURE REQUIREMENTS WHEN USING AN ELECTRONIC LEVEL CONTROL AND A SOLENOID VALVE.



NOTE:
ALL GIVEN DIMENSIONS
ARE WITHIN ±1/2"

"DRAWING IS FOR REFERENCE PURPOSES ONLY AND NOT TO BE USED FOR CONSTRUCTION"

TOWER TECH, Inc.
THE TECHNOLOGY COMPANY

TELEPHONE: (405) 290-7788
FAX: (405) 979-2131
E-MAIL: cad@towertechinc.com
WEBSITE: <http://www.towertechinc.com>
5400 NW 5th
OKLAHOMA CITY, OKLAHOMA 73127


Modular
Fiberglass
Cooling Tower
Model # TTXL-i219XX

1-Unit Installation
TTXL-i2 Plan & Elevation

© 2001 BY TOWER TECH, INC.
ALL RIGHTS RESERVED

FOR APPROVAL BY	DATE
Tower Tech Design Team	
REVISIONS	
NO.	DATE

DATE:	15 JAN 15
DRAWING#:	XL-i2-2
PROJECT#:	
CUST PO#:	
DRAWN BY:	RFB
CHECKED BY:	
Page 16 of 21	2
ELEVATION	



NOTE: ALL MEASUREMENTS ARE OD TO OD OF FOOTPAD.
 ALL GIVEN DIMENSIONS ARE WITHIN ±1/8".

TELEPHONE: (405) 290-7788
 FAX: (405) 979-2131
 E-MAIL: cad@towertechinc.com
 WEBPAGE: <http://www.towertechinc.com>
 5400 NW 5th
 OKLAHOMA CITY, OKLAHOMA 73127

**Modular
 Fiberglass
 Cooling Tower**
 Model # TTXL-i219XX

1-Unit Installation
TTXL-i2 Anchor Pad Layout

©2001 BY TOWER TECH, INC.
 ALL RIGHTS RESERVED

FOR APPROVAL BY	DATE	REVISIONS	REVISION	DATE
Tower Tech Design Team				

DATE:	15 JAN 15
DRAWING#:	XL-i2-3
PROJECT#:	
CUST PO#:	
DRAWN BY:	RFB
CHECKED BY:	
FOOTPRINT & ANCHOR PAD LAYOUT	3

----- LEG GEOMETRIC PROPERTIES -----

AREA: 17.9141
 PERIMETER: 107.9072
 BOUNDING BOX: X: -6.1274 -- 8.7476
 Y: -6.1274 -- 8.7476
 CENTROID: X: 0.0000
 Y: 0.0000
 MOMENTS OF INERTIA: X: 422.8851
 Y: 422.8847
 PRODUCT OF INERTIA: XY: -229.38880
 RADII OF GYRATION: X: 48586
 Y: 48586
 PRINCIPAL MOMENTS AND X-Y DIRECTIONS ABOUT CENTROID:
 I: 193.4960 ALONG [0.7071 -0.7071]
 J: 652.2729 ALONG [0.7071 0.7071]

FILL POCKET AROUND ANCHOR BOLTS TO TOP OF LEG BOLTS WITH NON-SHRINK GROUT, BEFORE INSTALLING THE SQUARE WASHER PROVIDED WITH THE MODULE. BEFORE THE GROUT SETS INSTALL SQUARE WASHER AND ANCHOR NUT AND TORQUE TO 50 FT.-LBS. SQUARE WASHER SHOULD ENGAGE ON TOP OF THE TWO HORIZONTAL BOLTS SECURING THE FOOTPAD TO THE LEG. RE-TORQUE TO STRUCTURAL ENGINEERS SPECIFICATION AFTER GROUT HAS SET.

ANCHOR NUT PROVIDED BY OTHERS




2 3/4"x2 3/4"x3/4" SQUARE WASHER PROVIDED BY TOWER TECH

ANCHOR NUT PROVIDED BY OTHERS

1 1/8"[28.6mm] HOLE SQUARE WASHER PROVIDED BY TOWER TECH

CONCRETE SLAB OR OTHER MOUNTING STRUCTURE BY OTHERS.

SUBSTRUCTURE LEG & FOOTPAD



TELEPHONE: (405) 290-7788
 FAX: (405) 979-2131
 E-MAIL: cad@towertechinc.com
 WEBSITE: http://www.towertechinc.com
 5400 NW 5th
 OKLAHOMA CITY, OKLAHOMA 73127


Modular Fiberglass Cooling Tower Model # TTXL-i219XX

1-Unit Installation TTXL-i2 Footpad Detail

© 2001 BY TOWER TECH, INC. ALL RIGHTS RESERVED

FOR APPROVAL BY	DATE	REVISIONS
Tower Tech Design Team		
NO.	DATE	REVISION

DATE:	16 JUN 15
DRAWING#:	XL-i2-4
PROJECT#:	
CUST PO#:	
DRAWN BY:	RFB
CHECKED BY:	
DATE:	



GENERAL NOTES

BASIN DATA (PER MODULE):

MIN/MAX GPM RANGE	-	800/2400
ACTUAL GPM	-	
HOT WATER TEMP F°	-	
COLD WATER TEMP F°	-	
WET BULB TEMP F°	-	

MOTOR DATA (PER MODULE):



BRAND	-	BALDOR (OR EQUIV.)
EFFICIENCY	-	HIGH
HP	-	3.0 / 5.0 / 7.5
KW	-	2.2 / 3.7 / 5.6
VOLTAGE	-	200 / 230 / 460 / 575
HZ	-	60
PHASE	-	3
NUMBER	-	8
POWER FACTOR	-	.61 / .63 / .68

WEIGHTS (PER MODULE):

DRY SHIPPING WEIGHT	-	13,750 lbs.	-	6,737 kg
OPERATING WEIGHT	-	24,780 lbs.	-	11,264 kg

NOTES:

1. ALL EXTERNAL PIPING PROVIDED BY CUSTOMER.
2. EXTERNAL PIPING TO BE "STAND ALONE" (INDEPENDENTLY SUPPORTED). FINAL CONNECTIONS TO THE COOLING TOWER MODULE MUST BE FIELD FITTED AFTER TOWER INSTALLATION TO PREVENT PIPE STRESS ON TOWER.
3. NO LOAD TO BE APPLIED TO TOWER TECH TOWER OR SUMP.
4. FOR APPROPRIATE WATER LEVEL REFER TO STARTUP SECTION IN TOWER TECH'S DESIGN, INSTALLATION & OPERATION MANUAL.
5. MAKE-UP CONNECTION/FLOAT VALVE CONNECTION FLANGE IS MADE FROM HIGH QUALITY PLASTIC TO ELIMINATE CORROSION.
6. THE MAXIMUM MAKE-UP INLET PRESSURE IS 25 PSIG WHEN USING A MECHANICAL FLOAT VALVE. FLOAT VALVE MAY NOT SHUT OFF AGAINST HIGHER PRESSURES. *THERE ARE NO MAXIMUM PRESSURE REQUIREMENTS WHEN USING AN ELECTRONIC LEVEL CONTROL AND A SOLENOID VALVE.



NOTE:
ALL GIVEN DIMENSIONS
ARE WITHIN ±1/2"

"DRAWING IS FOR REFERENCE PURPOSES ONLY AND NOT TO BE USED FOR CONSTRUCTION"

TOWER TECH, Inc.
THE TECHNOLOGY COMPANY

TELEPHONE: (405) 290-7788
FAX: (405) 979-2131
E-MAIL: ccd@towertechinc.com
WEBSITE: http://www.towertechinc.com
5400 NW 5th
OKLAHOMA CITY, OKLAHOMA 73127


Modular
Fiberglass
Cooling Tower
Model # TTXL-0819XX

© 2001 BY TOWER TECH, INC.
ALL RIGHTS RESERVED

1-Unit Installation
TTXL-08 Plan & Elevation

FOR APPROVAL BY	DATE
Tower Tech Design Team	
REVISIONS	
NO.	DATE

DATE:	16 NOV 15
DRAWING#:	XL-08-2
PROJECT#:	
CUST PO#:	
DRAWN BY:	RFB
CHECKED BY:	
Page 19 of 21	
ELEVATION	2



NOTE: ALL MEASUREMENTS ARE OD TO OD OF FOOTPAD.
 ALL GIVEN DIMENSIONS ARE WITHIN ±1/8".

"DRAWING IS FOR REFERENCE PURPOSES ONLY AND NOT TO BE USED FOR CONSTRUCTION"

TOWER TECH, Inc.
 THE TECHNOLOGY COMPANY

TELEPHONE: (405) 290-7788
 FAX: (405) 979-2131
 E-MAIL: cad@towertechinc.com
 WEBSITE: <http://www.towertechinc.com>
 5400 NW 5th
 OKLAHOMA CITY, OKLAHOMA 73127

Modular Fiberglass Cooling Tower
 Model # TTXL-0819XX

1-Unit Installation
 TTXL-08 Anchor Pad Layout



©2001 BY TOWER TECH, INC.
 ALL RIGHTS RESERVED

FOR APPROVAL BY	DATE
Tower Tech Design Team	
NO.	DATE



DATE:	15 JAN 15
DRAWING#:	XL-08-3
PROJECT#:	
CUST PO#:	
DRAWN BY:	RFB
CHECKED BY:	
Page 20 of 21	3
ANCHOR PAD LAYOUT	

----- LEG GEOMETRIC PROPERTIES -----

AREA: 17.9141
 PERIMETER: 107.9072
 BOUNDING BOX: X: -6.1274 -- 8.7476
 Y: -6.1274 -- 8.7476
 CENTROID: X: 0.0000
 Y: 0.0000
 MOMENTS OF INERTIA: X: 422.8851
 Y: 422.8847
 PRODUCT OF INERTIA: XY: -229.38880
 RADII OF GYRATION: X: 48586
 Y: 48586
 PRINCIPAL MOMENTS AND X-Y DIRECTIONS ABOUT CENTROID:
 I: 193.4960 ALONG [0.7071 -0.7071]
 J: 652.2729 ALONG [0.7071 0.7071]



FILL POCKET AROUND ANCHOR BOLTS TO TOP OF LEG BOLTS WITH NON-SHRINK GROUT, BEFORE INSTALLING THE SQUARE WASHER PROVIDED WITH THE MODULE. BEFORE THE GROUT SETS INSTALL SQUARE WASHER AND ANCHOR NUT AND TORQUE TO 50 FT.-LBS. SQUARE WASHER SHOULD ENGAGE ON TOP OF THE TWO HORIZONTAL BOLTS SECURING THE FOOTPAD TO THE LEG. RE-TORQUE TO STRUCTURAL ENGINEERS SPECIFICATION AFTER GROUT HAS SET.



FOR APPROVAL BY	DATE	REVISIONS
Tower Tech Design Team		
NO.	DATE	REVISION

DATE:	16 JUN 15
DRAWING#:	XL-08-4
PROJECT#:	
CUST PO#:	
DRAWN BY:	RFB
CHECKED BY:	
DATE:	