


ODOC SALEM - HVAC

3405 Deerpark Dr SE
Salem, OR 97310

STRUCTURAL CALCULATIONS

VLMK Project Number: 20210146

MFIA Inc. Consulting Engineers
2007 SE Ash St
Portland, OR 97214



EXPIRES: 12/31/2022

Prepared By: Ryan Kelly, P.E.

July 12, 2021



Project: ODOC Salem - HVAC
Project Address: 3405 Deerpark Dr SE
 Salem, OR 97310

Project Number: 20210146
Document: Structural Calculations for
 Building Permit

TABLE OF CONTENTS

Design Outline and Criteria	DC-1	thru	DC-2
Structural Calculations	C-1	thru	C-17
References	R-1	thru	R-3

DESCRIPTION OF PROJECT

This 'ODOC Salem - HVAC' consists of the design of a new concrete pad to support (1) new HVAC unit at the site located at 3405 Deerpark Dr SE, Salem, OR 97310. Anchorage calculations are provided for the equipment to be secured to the concrete pad to withstand wind and seismic forces.

LIMITATIONS

VLMK Engineering + Design was retained in a limited capacity for this project. No responsibility and/or liability is assumed by, nor is any to be assigned to, VLMK Engineering + Design for items beyond that shown in this Structural Calculation Package.

CODES

2019 Oregon Structural Specialty Code (Based on the 2018 International Building Code)

DESIGN LOADS

Dead Loads*Additional Loads*

Valent Mechanical Unit	4,550 lbs
------------------------	-----------

Wind

Basic Design Wind Speed, V (3-sec gust)	104 mph
Nominal Design Wind Speed, V_{asd}	81 mph
Risk Category	III
Wind Exposure	B
Internal Pressure Coefficient	$GC_{pi} = +/- 0.18$

Seismic

Location	Latitude	44.896887
	Longitude	-122.948908
Seismic Importance Factor, I_e		1.25
Risk Category		III
Mapped Spectral Response Accelerations		$S_s = 0.787$
		$S_1 = 0.396$
Site Class		D (Default)
Spectral Response Coefficients		$S_{ds} = 0.630$
		$S_{d1} = 0.503$
Seismic Design Category		D

Component Anchorage Factors	a_p	R_p	I_p	Ω_o
HVAC Equip	2.5	6.0	1.0	2.0

Search Information

Coordinates:	44.896887, -122.948908
Elevation:	259 ft
Timestamp:	2021-05-21T00:34:54.557Z
Hazard Type:	Seismic
Reference Document:	ASCE7-16
Risk Category:	II
Site Class:	D-default



Basic Parameters

Name	Value	Description
S_S	0.787	MCE_R ground motion (period=0.2s)
S_1	0.396	MCE_R ground motion (period=1.0s)
S_{MS}	0.945	Site-modified spectral acceleration value
S_{M1}	* null	Site-modified spectral acceleration value
S_{DS}	0.63	Numeric seismic design value at 0.2s SA
S_{D1}	* null	Numeric seismic design value at 1.0s SA

* See Section 11.4.8

*

$$S_{D1} = 2/3 S_{M1} = 0.503$$

$$S_{M1} = F_v S_1 = 0.754$$

$$F_v = 1.904 \text{ Table 11.4-2}$$

Additional Information

Name	Value	Description
SDC	* null	Seismic design category
F_a	1.2	Site amplification factor at 0.2s
F_v	* null	Site amplification factor at 1.0s
CR_S	0.88	Coefficient of risk (0.2s)
CR_1	0.862	Coefficient of risk (1.0s)
PGA	0.364	MCE_G peak ground acceleration
F_{PGA}	1.236	Site amplification factor at PGA
PGA_M	0.45	Site modified peak ground acceleration
T_L	16	Long-period transition period (s)

Seismic Design Category: D

ATC Hazards by Location

Search Information

Coordinates: 44.896887, -122.948908
Elevation: 259 ft
Timestamp: 2021-05-21T00:36:42.246Z
Hazard Type: Wind



ASCE 7-16

MRI 10-Year 66 mph
 MRI 25-Year 72 mph
 MRI 50-Year 76 mph
 MRI 100-Year 81 mph
 Risk Category I 90 mph
 Risk Category II 96 mph
 Risk Category III 102 mph
 Risk Category IV 107 mph

ASCE 7-10

MRI 10-Year 72 mph
 MRI 25-Year 79 mph
 MRI 50-Year 85 mph
 MRI 100-Year 91 mph
 Risk Category I 100 mph
 Risk Category II 110 mph
 Risk Category III-IV 115 mph

ASCE 7-05

ASCE 7-05 Wind Speed 85 mph

104 mph per 2019 OSSC

The results indicated here DO NOT reflect any state or local amendments to the values or any delineation lines made during the building code adoption process. Users should confirm any output obtained from this tool with the local Authority Having Jurisdiction before proceeding with design.

Disclaimer

Hazard loads are interpolated from data provided in ASCE 7 and rounded up to the nearest whole integer. Per ASCE 7, islands and coastal areas outside the last contour should use the last wind speed contour of the coastal area – in some cases, this website will extrapolate past the last wind speed contour and therefore, provide a wind speed that is slightly higher. NOTE: For queries near wind-borne debris region boundaries, the resulting determination is sensitive to rounding which may affect whether or not it is considered to be within a wind-borne debris region.


Mountainous terrain, gorges, ocean promontories, and special wind regions shall be examined for unusual wind conditions.

While the information presented on this website is believed to be correct, ATC and its sponsors and contributors assume no responsibility or liability for its accuracy. The material presented in the report should not be used or relied upon for any specific application without competent examination and verification of its accuracy, suitability and applicability by engineers or other licensed professionals. ATC does not intend that the use of this information replace the sound judgment of such competent professionals, having experience and knowledge in the field of practice, nor to substitute for the standard of care required of such professionals in interpreting and applying the results of the report provided by this website. Users of the information from this website assume all liability arising from such use. Use of the output of this website does not imply approval by the governing building code bodies responsible for building code approval and interpretation for the <https://hazards.atcouncil.org/#/wind?lat=44.896887&lng=-122.948908&address=>

v4.01 - Software Copyright 2017 VLMK Consulting Engineers. All Rights Reserved.

Wind Loads on Solid Freestanding Walls and Solid Signs

Based on the 2018 International Building Code and ASCE 7-16 Section 29.3.1



DESIGN INPUT

Exposure	B	Exposure category	[Section 26.7.3]
K_{zt}	1.00	Topographic factor	[Section 26.8]
V	104 mph	Ultimate wind speed (3-second gust)	[Figures 26.5-1A, B, and C]
h	6.5 ft	Height from ground level to top of sign or wall	[Figure 29.3-1]
s	6.5 ft	Vertical dimension of sign	[Figure 29.3-1]
B	13.67 ft	Horizontal dimension of sign or wall	[Figure 29.3-1]
L_r	0 ft	Horizontal dimension of return corner or wall	[Figure 29.3-1]
A_o	0 ft	Total area of openings	[Figure 29.3-1]
	Side Support	If $h \leq 3$ feet, use Components and Cladding design provisions.	
B_{post}	1 in	NA, no supporting posts for walls or side supported signs	
Load Factor	1.0	Ultimate = 1.0W loads, ASD = 0.6W loads	

ANALYSIS

A_{sign}	88.855 ft	gross area of wall or sign normal to wind direction	
A_{post}	0 ft	area of post(s)	
ϵ	1.00	ratio of solid area to gross area	[Figure 29.3-1]
R.F.	1.00	reduction factor for openings	$Reduction\ Factor = 1 - (1 - \epsilon)^{1.5}$ [Figure 29.3-1]
K_h	0.57	velocity pressure exposure coefficient	[Section 26.10]
K_d	0.85	wind directionality factor	[Table 26.6-1]
K_e	1.00	ground elevation factor	[Table 26.9-1]
q_h	16.0 psf	velocity pressure	$q_h = 0.00256K_hK_{zt}K_dK_eV^2$ (Equation 26.10-1)
G	0.85	gust effect factor, 0.85 for rigid structure	[Section 26.11.1]
C_f	1.40	sign force coefficient for Cases A & B	[Figure 29.3-1]
C_f	1.49	average sign force coefficient for Case C	[Figure 29.3-1]

(1.0W ULTIMATE LEVEL)

	Cases A & B	Case C Max.	Case C Avg.	NOTE: Cases A, B, and C shall be considered
p	19.0 psf	24.87 psf	20.31 psf	$p = q_h G C_f$
F	1689 lbs	1804 lbs	1804 lbs	$F = q_h G C_f A_s$ (Equation 29.3-1)
F_{max}	1804 lbs			maximum total lateral force at supported edge
M_{max}	16159 lb-ft			maximum total moment at supported side
T_{max}	0 lb-ft			no torsion for side support condition, see moment above

Mechanical Unit Anchorage Design

Based on the 2018 International Building Code and ASCE 7-16

DESIGN INPUT

Seismic Parameters:


$S_{DS} = 0.630$ g	Design Spectral Response Acceleration
$\Omega = 2.0$	Overstrength Factor [ASCE Table 13.5-1 or 13.6-1]
$a_p = 2.5$	[ASCE Table 13.5-1 or 13.6-1]
$R_p = 6.0$	[ASCE Table 13.5-1 or 13.6-1]
$I_p = 1.00$	[ASCE 13.1.3]
$z = 1$ ft	Attachment height from base of structure
$h = 1$ ft	Average roof height of structure from base

Wind Parameters:


$P_{HORIZ.} = 24.9$ psf	Design Wind Pressure (psf), 1.0W
$P_{UPLIFT} = 16.0$ psf	Design Wind Pressure (psf), 1.0W

Mechanical Unit Parameters:

$W_p = 4,550$ lbs	Total Weight
$X = 164.0$ in	Base Dimension (max)
$Y = 69.0$ in	Base Dimension (min)
$Z = 78.0$ in	Height of Unit
$Z_{curb} = 14.0$ in	Height of Curb, where occurs
$X_{cg} = 76.0$ in	Center of Gravity
$Y_{cg} = 46.6$ in	Center of Gravity
$Z_{cg} = 39.0$ in	Center of Gravity (excluding curb)



PLAN VIEW



SIDE VIEW

Load Combinations:

<u>Seismic:</u>	<u>Wind:</u>
$(0.9-0.2S_{DS})D + \Omega E$	$0.9D + 1.0W$
$(0.6-0.14S_{DS})D + 0.7E$	$0.6D + 0.6W$

ANALYSIS

Base Shear: (Load applied to all (4) anchors/corners together)

Seismic:

$$F_p = \frac{0.4a_p S_{DS} W_p}{R_p / I_p} \left(1 + 2 \frac{z}{h} \right) = 1433 \text{ lbs} \quad \leq 1.6 S_{DS} I_p W_p = 4586 \text{ lbs} \quad \text{OK}$$

$$\geq 0.3 S_{DS} I_p W_p = 860 \text{ lbs} \quad \text{OK}$$

Base Shear, $\Omega V_{uE} = 2867$ lbs Seismic, ΩE

Wind:

$V_{uW} = 2609$ lbs Wind, 1.0W

$V_{u, \text{BASE}} = 2867$ lbs Seismic, ΩE
 = 1565 lbs (ASD, 0.6W)

Anchor Shear: (Load applied to each anchor/corner)

Seismic:

Anchor:	dx	dx ²	dy	dy ²
1	76	5776	46.6	2171.6
2	88	7744	46.6	2171.6
3	76	5776	22.4	501.76
4	88	7744	22.4	501.76
		27040		5346.64

Wind: $V_{1,2,3,4} = 652$ lbs

Design Eccentricity = 5%

$e_x = 14.2$ in	$e_y = 15.55$ in
$M_{x-x} = 40704$ in-lbs	$M_{y-y} = 44574$ in-lbs
Y-Direction	X-Direction
$V_{1,3} = 831$ lbs	$V_{1,2} = 1105$ lbs
$V_{2,4} = 849$ lbs	$V_{3,4} = 903$ lbs

Max $V_{u, \text{ANCHOR}} = 1105$ lbs Seismic, ΩE
 = 391 lbs (ASD, 0.6W)

Overtuning/Uplift: (Load applied to each anchor/corner)

Seismic:

$M_{ot} = 75962$ lb-in	Seismic, ΩE
$M_{res,x} = 267649$ lb-in	Seismic, ΩE
$M_{res,y} = 78886$ lb-in	Seismic, ΩE

Net Tension: $T_x^* = -269$ lbs Wind, 1.0W
 $T_y^* = 519$ lbs Wind, 1.0W

Wind:

$M_{ot} = 120012$ lb-in	Wind, 1.0W
$M_{res,x} = 311220$ lb-in	Wind, 1.0W
$M_{res,y} = 91728$ lb-in	Wind, 1.0W

Max $T_{u, \text{ANCHOR}}^* = 519$ lbs Wind, 1.0W
 = 267 lbs (ASD, 0.6W)

*Negative (-) values indicate there is no net uplift

LWA Box Bolts

LOADS:

$$\left. \begin{aligned} V_u / \text{CORNER} &= 1105 \text{ lbs} \\ T_u / \text{CORNER} &= 519 \text{ lbs} \end{aligned} \right\} \text{SEE C-4}$$

ANALYSIS:

TENSION IN LWA BOLT = SHEAR FROM EXCEL


$$(2) \text{ BOLTS } (2.96 \text{ K}) = 5.92 \text{ K} \geq V_u / \text{CORNER} = 1105 \text{ LBS} \quad \text{OK//}$$

FROM ESR 3217, TABLE 2
@ BRIGALIC

SHEAR IN LWA BOLT = TENSION FROM EXCEL

$$(2) \text{ BOLTS } (4.32 \text{ K}) = 8.64 \text{ K} \geq T_u / \text{CORNER} = 519 \text{ LBS} \quad \text{OK//}$$

FROM ESR 3217, TABLE 2
@ BRIGALIC




INTERACTION: $\left(\frac{T_u}{T_a}\right)^2 + \left(\frac{V_u}{V_a}\right)^2 < 1.0$

$$\left(\frac{1.105 \text{ K}}{5.92 \text{ K}}\right)^2 + \left(\frac{0.519 \text{ K}}{8.64 \text{ K}}\right)^2 = 0.03 + 0.004$$

$$0.04 < 1.0 \quad \text{OK//}$$

RESULTS:

SECURE HUAC TO ANGLE USING (2) 1/2" DIA LWA
BOX BOLTS SIZE 1





Company:	VLMK	Date:	7/8/2021
Engineer:	Ryan Kelly	Page:	1/6
Project:	ODOC HVAC		
Address:			
Phone:			
E-mail:			

1. Project information

Customer company:
Customer contact name:
Customer e-mail:
Comment:

Project description: 20210146
Anchorage of angles to restrain HVAC on pad
Location:
Fastening description:

2. Input Data & Anchor Parameters

General

Design method: ACI 318-14
Units: Imperial units

Anchor Information:

Anchor type: Concrete screw
Material: Stainless Steel
Diameter (inch): 0.500
Nominal Embedment depth (inch): 3.250
Effective Embedment depth, h_{ef} (inch): 1.860
Code report: IAPMO UES ER-493
Anchor category: 1
Anchor ductility: Yes
 h_{min} (inch): 5.00
 c_{ac} (inch): 6.00
 C_{min} (inch): 2.25
 S_{min} (inch): 3.00

Base Material

Concrete: Normal-weight
Concrete thickness, h (inch): 8.00
State: Cracked
Compressive strength, f'_c (psi): 3500
 $\Psi_{c,v}$: 1.0
Reinforcement condition: B tension, B shear
Supplemental reinforcement: Not applicable
Reinforcement provided at corners: No
Ignore concrete breakout in tension: No
Ignore concrete breakout in shear: No
Ignore 6do requirement: Not applicable
Build-up grout pad: No

Base Plate

Length x Width x Thickness (inch): 3.00 x 6.00 x 0.25

Recommended Anchor

Anchor Name: Titen HD® Stainless Steel - 1/2"Ø SS Titen HD, h_{nom} : 3.25" (83mm)
Code Report: IAPMO UES ER-493



Input data and results must be checked for agreement with the existing circumstances, the standards and guidelines must be checked for plausibility.



Anchor Designer™
Software
Version 2.9.7376.1

Company:	VLMK	Date:	7/8/2021
Engineer:	Ryan Kelly	Page:	2/6
Project:	ODOC HVAC		
Address:			
Phone:			
E-mail:			


Load and Geometry

Load factor source: ACI 318 Section 5.3
 Load combination: not set
 Seismic design: Yes
 Anchors subjected to sustained tension: Not applicable
 Ductility section for tension: 17.2.3.4.3 (d) is satisfied
 Ductility section for shear: 17.2.3.5.3 (c) is satisfied
 Ω_0 factor: not set
 Apply entire shear load at front row: No
 Anchors only resisting wind and/or seismic loads: Yes

Strength level loads:

N_{ua} [lb]: 520
 V_{uax} [lb]: 0
 V_{uay} [lb]: 1300
 M_{ux} [ft-lb]: 0
 M_{uy} [ft-lb]: 0
 M_{uz} [ft-lb]: 0


<Figure 1>



Input data and results must be checked for agreement with the existing circumstances, the standards and guidelines must be checked for plausibility.

Company:	VLMK	Date:	7/8/2021
Engineer:	Ryan Kelly	Page:	3/6
Project:	ODOC HVAC		
Address:			
Phone:			
E-mail:			

<Figure 2>




Company:	VLMK	Date:	7/8/2021
Engineer:	Ryan Kelly	Page:	4/6
Project:	ODOC HVAC		
Address:			
Phone:			
E-mail:			

3. Resulting Anchor Forces

Anchor	Tension load, N _{ua} (lb)	Shear load x, V _{uax} (lb)	Shear load y, V _{uay} (lb)	Shear load combined, $\sqrt{(V_{uax})^2 + (V_{uay})^2}$ (lb)
1	564.1	650.0	650.0	919.2
2	564.1	-650.0	650.0	919.2
Sum	1128.2	0.0	1300.0	1838.5

Maximum concrete compression strain (%): 0.07
 Maximum concrete compression stress (psi): 298
 Resultant tension force (lb): 1128
 Resultant compression force (lb): 608
 Eccentricity of resultant tension forces in x-axis, e'_{Nx} (inch): 0.00
 Eccentricity of resultant tension forces in y-axis, e'_{Ny} (inch): 0.00
 Eccentricity of resultant shear forces in x-axis, e'_{Vx} (inch): 0.00
 Eccentricity of resultant shear forces in y-axis, e'_{Vy} (inch): 0.00

<Figure 3>



4. Steel Strength of Anchor in Tension (Sec. 17.4.1)

N _{sa} (lb)	φ	φN _{sa} (lb)
20885	0.75	15664

5. Concrete Breakout Strength of Anchor in Tension (Sec. 17.4.2)

$N_b = k_c \lambda_a \sqrt{f'_c} h_{ef}^{1.5}$ (Eq. 17.4.2.2a)

k _c	λ _a	f' _c (psi)	h _{ef} (in)	N _b (lb)
17.0	1.00	3500	1.860	2551

$0.75 \phi N_{cbg} = 0.75 \phi (A_{Nc} / A_{Nco}) \psi_{ec,N} \psi_{ed,N} \psi_{c,N} \psi_{cp,N} N_b$ (Sec. 17.3.1 & Eq. 17.4.2.1b)

A _{Nc} (in ²)	A _{Nco} (in ²)	C _{a,min} (in)	ψ _{ec,N}	ψ _{ed,N}	ψ _{c,N}	ψ _{cp,N}	N _b (lb)	φ	0.75 φN _{cbg} (lb)
47.88	31.14	6.00	1.000	1.000	1.00	1.000	2551	0.65	1912

6. Pullout Strength of Anchor in Tension (Sec. 17.4.3)

$0.75 \phi N_{pn} = 0.75 \phi \psi_{c,P} \lambda_a N_p (f'_c / 2,500)^n$ (Sec. 17.3.1, Eq. 17.4.3.1 & Code Report)

ψ _{c,P}	λ _a	N _p (lb)	f' _c (psi)	n	φ	0.75 φN _{pn} (lb)
1.0	1.00	1995	3500	0.50	0.65	1151

Input data and results must be checked for agreement with the existing circumstances, the standards and guidelines must be checked for plausibility.



Anchor Designer™
Software
 Version 2.9.7376.1

Company:	VLMK	Date:	7/8/2021
Engineer:	Ryan Kelly	Page:	5/6
Project:	ODOC HVAC		
Address:			
Phone:			
E-mail:			

8. Steel Strength of Anchor in Shear (Sec. 17.5.1)

V_{sa} (lb)	ϕ_{grout}	ϕ	$\phi_{grout}\phi V_{sa}$ (lb)
5345	1.0	0.65	3474

9. Concrete Breakout Strength of Anchor in Shear (Sec. 17.5.2)

Shear perpendicular to edge in x-direction:

$V_{bx} = \min[7(l_e / d_a)^{0.2} \sqrt{d_a \lambda_a} \sqrt{f_c c_{a1}^{1.5}}; 9 \lambda_a \sqrt{f_c c_{a1}^{1.5}}]$ (Eq. 17.5.2.2a & Eq. 17.5.2.2b)

l_e (in)	d_a (in)	λ_a	f_c (psi)	c_{a1} (in)	V_{bx} (lb)
1.86	0.500	1.00	3500	6.00	5597

$\phi V_{cbgx} = \phi (A_{Vc} / A_{Vco}) \Psi_{ec,V} \Psi_{ed,V} \Psi_{c,V} \Psi_{h,V} V_{bx}$ (Sec. 17.3.1 & Eq. 17.5.2.1b)

A_{Vc} (in ²)	A_{Vco} (in ²)	$\Psi_{ec,V}$	$\Psi_{ed,V}$	$\Psi_{c,V}$	$\Psi_{h,V}$	V_{bx} (lb)	ϕ	ϕV_{cbgx} (lb)
120.00	162.00	1.000	0.900	1.000	1.061	5597	0.70	2770

Shear perpendicular to edge in y-direction:

$V_{by} = \min[7(l_e / d_a)^{0.2} \sqrt{d_a \lambda_a} \sqrt{f_c c_{a1}^{1.5}}; 9 \lambda_a \sqrt{f_c c_{a1}^{1.5}}]$ (Eq. 17.5.2.2a & Eq. 17.5.2.2b)

l_e (in)	d_a (in)	λ_a	f_c (psi)	c_{a1} (in)	V_{by} (lb)
1.86	0.500	1.00	3500	5.33	4691

$\phi V_{cby} = \phi (A_{Vc} / A_{Vco}) \Psi_{ec,V} \Psi_{ed,V} \Psi_{c,V} \Psi_{h,V} V_{by}$ (Sec. 17.3.1 & Eq. 17.5.2.1a)

A_{Vc} (in ²)	A_{Vco} (in ²)	$\Psi_{ec,V}$	$\Psi_{ed,V}$	$\Psi_{c,V}$	$\Psi_{h,V}$	V_{by} (lb)	ϕ	ϕV_{cby} (lb)
96.00	128.00	0.925	1.000	1.000	1.000	4691	0.70	2278

Shear parallel to edge in x-direction:

$V_{by} = \min[7(l_e / d_a)^{0.2} \sqrt{d_a \lambda_a} \sqrt{f_c c_{a1}^{1.5}}; 9 \lambda_a \sqrt{f_c c_{a1}^{1.5}}]$ (Eq. 17.5.2.2a & Eq. 17.5.2.2b)

l_e (in)	d_a (in)	λ_a	f_c (psi)	c_{a1} (in)	V_{by} (lb)
1.86	0.500	1.00	3500	5.33	4691

$\phi V_{cbx} = \phi (2)(A_{Vc} / A_{Vco}) \Psi_{ec,V} \Psi_{ed,V} \Psi_{c,V} \Psi_{h,V} V_{by}$ (Sec. 17.3.1, 17.5.2.1(c) & Eq. 17.5.2.1a)

A_{Vc} (in ²)	A_{Vco} (in ²)	$\Psi_{ec,V}$	$\Psi_{ed,V}$	$\Psi_{c,V}$	$\Psi_{h,V}$	V_{by} (lb)	ϕ	ϕV_{cbx} (lb)
96.00	128.00	1.000	1.000	1.000	1.000	4691	0.70	4925

Shear parallel to edge in y-direction:

$V_{bx} = \min[7(l_e / d_a)^{0.2} \sqrt{d_a \lambda_a} \sqrt{f_c c_{a1}^{1.5}}; 9 \lambda_a \sqrt{f_c c_{a1}^{1.5}}]$ (Eq. 17.5.2.2a & Eq. 17.5.2.2b)

l_e (in)	d_a (in)	λ_a	f_c (psi)	c_{a1} (in)	V_{bx} (lb)
1.86	0.500	1.00	3500	5.33	4691

$\phi V_{cbgy} = \phi (2)(A_{Vc} / A_{Vco}) \Psi_{ec,V} \Psi_{ed,V} \Psi_{c,V} \Psi_{h,V} V_{bx}$ (Sec. 17.3.1, 17.5.2.1(c) & Eq. 17.5.2.1b)

A_{Vc} (in ²)	A_{Vco} (in ²)	$\Psi_{ec,V}$	$\Psi_{ed,V}$	$\Psi_{c,V}$	$\Psi_{h,V}$	V_{bx} (lb)	ϕ	ϕV_{cbgy} (lb)
120.00	128.00	1.000	1.000	1.000	1.000	4691	0.70	6156

10. Concrete Pryout Strength of Anchor in Shear (Sec. 17.5.3)

$\phi V_{cp} = \phi k_{cp} N_{cb} = \phi k_{cp} (A_{Nc} / A_{Nco}) \Psi_{ed,N} \Psi_{c,N} \Psi_{cp,NNb}$ (Sec. 17.3.1 & Eq. 17.5.3.1a)

k_{cp}	A_{Nc} (in ²)	A_{Nco} (in ²)	$\Psi_{ed,N}$	$\Psi_{c,N}$	$\Psi_{cp,NNb}$	N_b (lb)	ϕ	ϕV_{cp} (lb)
1.0	23.94	31.14	1.000	1.000	1.000	2551	0.70	1373

11. Results

Interaction of Tensile and Shear Forces (Sec. R17.6)

Input data and results must be checked for agreement with the existing circumstances, the standards and guidelines must be checked for plausibility.



Company:	VLMK	Date:	7/8/2021
Engineer:	Ryan Kelly	Page:	6/6
Project:	ODOC HVAC		
Address:			
Phone:			
E-mail:			

Tension	Factored Load, N_{ua} (lb)	Design Strength, ϕN_n (lb)	Ratio	Status	
Steel	564	15664	0.04	Pass	
Concrete breakout	1128	1912	0.59	Pass (Governs)	
Pullout	564	1151	0.49	Pass	
Shear	Factored Load, V_{ua} (lb)	Design Strength, ϕV_n (lb)	Ratio	Status	
Steel	919	3474	0.26	Pass	
T Concrete breakout x-	650	2770	0.23	Pass	
T Concrete breakout y+	1300	2278	0.57	Pass	
Concrete breakout y-	650	4925	0.13	Pass	
Concrete breakout x-	1300	6156	0.21	Pass	
Concrete breakout, combined	-	-	0.62	Pass	
Pryout	919	1373	0.67	Pass (Governs)	
Interaction check	$(N_{ua}/\phi N_{ua})^{5/3}$	$(V_{ua}/\phi V_{ua})^{5/3}$	Combined Ratio	Permissible	Status
Sec. R17.6	0.41	0.51	92.7%	1.0	Pass

1/2"Ø SS Titen HD, hnom:3.25" (83mm) meets the selected design criteria.

12. Warnings

- Per designer input, ductility requirements for tension have been determined to be satisfied – designer to verify.
- Per designer input, ductility requirements for shear have been determined to be satisfied – designer to verify.
- Designer must exercise own judgement to determine if this design is suitable.
- Refer to manufacturer's product literature for hole cleaning and installation instructions.

Company:	VLMK	Date:	7/8/2021
Engineer:	Ryan Kelly	Page:	1/6
Project:	ODOC HVAC		
Address:			
Phone:			
E-mail:			

1. Project information

Customer company:
 Customer contact name:
 Customer e-mail:
 Comment:

Project description: 20210146
 Anchorage of angles to restrain HVAC on pad
 Location:
 Fastening description:

2. Input Data & Anchor Parameters

General

Design method: ACI 318-14
 Units: Imperial units

Anchor Information:

Anchor type: Concrete screw
 Material: Stainless Steel
 Diameter (inch): 0.500
 Nominal Embedment depth (inch): 3.250
 Effective Embedment depth, h_{ef} (inch): 1.860
 Code report: IAPMO UES ER-493
 Anchor category: 1
 Anchor ductility: Yes
 h_{min} (inch): 5.00
 c_{ac} (inch): 6.00
 C_{min} (inch): 2.25
 S_{min} (inch): 3.00

Base Material

Concrete: Normal-weight
 Concrete thickness, h (inch): 8.00
 State: Cracked
 Compressive strength, f'_c (psi): 3500
 $\Psi_{c,v}$: 1.0
 Reinforcement condition: B tension, B shear
 Supplemental reinforcement: Not applicable
 Reinforcement provided at corners: No
 Ignore concrete breakout in tension: No
 Ignore concrete breakout in shear: No
 Ignore 6do requirement: Not applicable
 Build-up grout pad: No

Base Plate

Length x Width x Thickness (inch): 3.00 x 6.00 x 0.25

Recommended Anchor

Anchor Name: Titen HD® Stainless Steel - 1/2"Ø SS Titen HD, h_{nom} : 3.25" (83mm)
 Code Report: IAPMO UES ER-493





Anchor Designer™
Software
Version 2.9.7376.1

Company:	VLMK	Date:	7/8/2021
Engineer:	Ryan Kelly	Page:	2/6
Project:	ODOC HVAC		
Address:			
Phone:			
E-mail:			


Load and Geometry

Load factor source: ACI 318 Section 5.3
 Load combination: not set
 Seismic design: Yes
 Anchors subjected to sustained tension: Not applicable
 Ductility section for tension: 17.2.3.4.3 (d) is satisfied
 Ductility section for shear: 17.2.3.5.3 (c) is satisfied
 Ω₀ factor: not set
 Apply entire shear load at front row: No
 Anchors only resisting wind and/or seismic loads: Yes

Strength level loads:

N_{ua} [lb]: 520
 V_{uax} [lb]: 1300
 V_{uay} [lb]: 0
 M_{ux} [ft-lb]: 0
 M_{uy} [ft-lb]: 0
 M_{uz} [ft-lb]: 0

<Figure 1>




Input data and results must be checked for agreement with the existing circumstances, the standards and guidelines must be checked for plausibility.



Anchor Designer™
 Software
 Version 2.9.7376.1

Company:	VLMK	Date:	7/8/2021
Engineer:	Ryan Kelly	Page:	3/6
Project:	ODOC HVAC		
Address:			
Phone:			
E-mail:			

<Figure 2>



Input data and results must be checked for agreement with the existing circumstances, the standards and guidelines must be checked for plausibility.


Company:	VLMK	Date:	7/8/2021
Engineer:	Ryan Kelly	Page:	4/6
Project:	ODOC HVAC		
Address:			
Phone:			
E-mail:			

3. Resulting Anchor Forces

Anchor	Tension load, N _{ua} (lb)	Shear load x, V _{uax} (lb)	Shear load y, V _{uay} (lb)	Shear load combined, $\sqrt{(V_{uax})^2 + (V_{uay})^2}$ (lb)
1	564.1	650.0	0.0	650.0
2	564.1	650.0	0.0	650.0
Sum	1128.2	1300.0	0.0	1300.0

Maximum concrete compression strain (%): 0.07
 Maximum concrete compression stress (psi): 298
 Resultant tension force (lb): 1128
 Resultant compression force (lb): 608
 Eccentricity of resultant tension forces in x-axis, e'_{Nx} (inch): 0.00
 Eccentricity of resultant tension forces in y-axis, e'_{Ny} (inch): 0.00
 Eccentricity of resultant shear forces in x-axis, e'_{Vx} (inch): 0.00
 Eccentricity of resultant shear forces in y-axis, e'_{Vy} (inch): 0.00

<Figure 3>



4. Steel Strength of Anchor in Tension (Sec. 17.4.1)

N _{sa} (lb)	φ	φN _{sa} (lb)
20885	0.75	15664

5. Concrete Breakout Strength of Anchor in Tension (Sec. 17.4.2)

$N_b = k_c \lambda_a \sqrt{f'_c} h_{ef}^{1.5}$ (Eq. 17.4.2.2a)

k _c	λ _a	f' _c (psi)	h _{ef} (in)	N _b (lb)
17.0	1.00	3500	1.860	2551

$0.75 \phi N_{cbg} = 0.75 \phi (A_{Nc} / A_{Nco}) \psi_{ec,N} \psi_{ed,N} \psi_{c,N} \psi_{cp,N} N_b$ (Sec. 17.3.1 & Eq. 17.4.2.1b)

A _{Nc} (in ²)	A _{Nco} (in ²)	C _{a,min} (in)	ψ _{ec,N}	ψ _{ed,N}	ψ _{c,N}	ψ _{cp,N}	N _b (lb)	φ	0.75 φN _{cbg} (lb)
47.88	31.14	6.00	1.000	1.000	1.00	1.000	2551	0.65	1912

6. Pullout Strength of Anchor in Tension (Sec. 17.4.3)

$0.75 \phi N_{pn} = 0.75 \phi \psi_{c,P} \lambda_a N_p (f'_c / 2,500)^n$ (Sec. 17.3.1, Eq. 17.4.3.1 & Code Report)

ψ _{c,P}	λ _a	N _p (lb)	f' _c (psi)	n	φ	0.75 φN _{pn} (lb)
1.0	1.00	1995	3500	0.50	0.65	1151

Input data and results must be checked for agreement with the existing circumstances, the standards and guidelines must be checked for plausibility.



Anchor Designer™
Software
Version 2.9.7376.1

Company:	VLMK	Date:	7/8/2021
Engineer:	Ryan Kelly	Page:	5/6
Project:	ODOC HVAC		
Address:			
Phone:			
E-mail:			

8. Steel Strength of Anchor in Shear (Sec. 17.5.1)

V_{sa} (lb)	ϕ_{grout}	ϕ	$\phi_{grout}\phi V_{sa}$ (lb)
5345	1.0	0.65	3474

9. Concrete Breakout Strength of Anchor in Shear (Sec. 17.5.2)

Shear perpendicular to edge in x-direction:

$$V_{bx} = \min[7(l_e/d_a)^{0.2}\sqrt{d_a\lambda_a}f_c c_{a1}^{1.5}; 9\lambda_a\sqrt{f_c c_{a1}^{1.5}}] \text{ (Eq. 17.5.2.2a \& Eq. 17.5.2.2b)}$$

l_e (in)	d_a (in)	λ_a	f_c (psi)	c_{a1} (in)	V_{bx} (lb)
1.86	0.500	1.00	3500	5.33	4691

$$\phi V_{cbgx} = \phi (A_{Vc}/A_{Vco})\Psi_{ec,V}\Psi_{ed,V}\Psi_{c,V}\Psi_{h,V}V_{bx} \text{ (Sec. 17.3.1 \& Eq. 17.5.2.1b)}$$

A_{Vc} (in ²)	A_{Vco} (in ²)	$\Psi_{ec,V}$	$\Psi_{ed,V}$	$\Psi_{c,V}$	$\Psi_{h,V}$	V_{bx} (lb)	ϕ	ϕV_{cbgx} (lb)
120.00	128.00	1.000	0.925	1.000	1.000	4691	0.70	2847

Shear parallel to edge in x-direction:

$$V_{by} = \min[7(l_e/d_a)^{0.2}\sqrt{d_a\lambda_a}f_c c_{a1}^{1.5}; 9\lambda_a\sqrt{f_c c_{a1}^{1.5}}] \text{ (Eq. 17.5.2.2a \& Eq. 17.5.2.2b)}$$

l_e (in)	d_a (in)	λ_a	f_c (psi)	c_{a1} (in)	V_{by} (lb)
1.86	0.500	1.00	3500	5.33	4691

$$\phi V_{cbx} = \phi (2)(A_{Vc}/A_{Vco})\Psi_{ec,V}\Psi_{c,V}\Psi_{h,V}V_{by} \text{ (Sec. 17.3.1, 17.5.2.1(c) \& Eq. 17.5.2.1a)}$$

A_{Vc} (in ²)	A_{Vco} (in ²)	$\Psi_{ec,V}$	$\Psi_{c,V}$	$\Psi_{h,V}$	V_{by} (lb)	ϕ	ϕV_{cbx} (lb)
96.00	128.00	1.000	1.000	1.000	4691	0.70	4925

10. Concrete Pryout Strength of Anchor in Shear (Sec. 17.5.3)

$$\phi V_{cpq} = \phi K_{cp}N_{cbg} = \phi K_{cp}(A_{Nc}/A_{Nco})\Psi_{ec,N}\Psi_{ed,N}\Psi_{c,N}\Psi_{cp,N}N_b \text{ (Sec. 17.3.1 \& Eq. 17.5.3.1b)}$$

K_{cp}	A_{Nc} (in ²)	A_{Nco} (in ²)	$\Psi_{ec,N}$	$\Psi_{ed,N}$	$\Psi_{c,N}$	$\Psi_{cp,N}$	N_b (lb)	ϕ	ϕV_{cpq} (lb)
1.0	47.88	31.14	1.000	1.000	1.000	1.000	2551	0.70	2746

11. Results

Interaction of Tensile and Shear Forces (Sec. R17.6)

Tension	Factored Load, N_{ua} (lb)	Design Strength, ϕN_n (lb)	Ratio	Status	
Steel	564	15664	0.04	Pass	
Concrete breakout	1128	1912	0.59	Pass (Governs)	
Pullout	564	1151	0.49	Pass	
Shear	Factored Load, V_{ua} (lb)	Design Strength, ϕV_n (lb)	Ratio	Status	
Steel	650	3474	0.19	Pass	
T Concrete breakout x+	1300	2847	0.46	Pass	
Concrete breakout y-	650	4925	0.13	Pass	
Pryout	1300	2746	0.47	Pass (Governs)	
Interaction check	$(N_{ua}/\phi N_{ua})^{5/3}$	$(V_{ua}/\phi V_{ua})^{5/3}$	Combined Ratio	Permissible	Status
Sec. R17.6	0.41	0.29	70.3%	1.0	Pass

1/2"Ø SS Titen HD, hnom:3.25" (83mm) meets the selected design criteria.

Input data and results must be checked for agreement with the existing circumstances, the standards and guidelines must be checked for plausibility.

Simpson Strong-Tie Company Inc. 5956 W. Las Positas Boulevard Pleasanton, CA 94588 Phone: 925.560.9000 Fax: 925.847.3871 www.strongtie.com




Company:	VLMK	Date:	7/8/2021
Engineer:	Ryan Kelly	Page:	6/6
Project:	ODOC HVAC		
Address:			
Phone:			
E-mail:			

12. Warnings

- Per designer input, ductility requirements for tension have been determined to be satisfied – designer to verify.
- Per designer input, ductility requirements for shear have been determined to be satisfied – designer to verify.
- Designer must exercise own judgement to determine if this design is suitable.
- Refer to manufacturer's product literature for hole cleaning and installation instructions.

Unit Corner Weights




Note


Estimated corner weights are shown looking down on unit and the outside air intake will be on the right. Weights are applied at the base of the unit. Images not drawn to scale.




Overview Drawings




Plan



Right End



Elevation



Left End



Date:	7-13-20
Drawn By:	MD
Check By:	MD
Design:	MD
Project No.:	10039
Acad File:	10039-M10



PACKAGED HEAT PUMP

MARK NO.	SYSTEM	NOMINAL SIZE - TONS	TYPE	INSTALLATION	CONTROL
1	OFFICES	175	PACKAGED	RETIRED	DDC
2	VISITORS	150	PACKAGED	RETIRED	DDC
3	WAITING	120	PACKAGED	RETIRED	DDC
4	INTERVIEW	120	PACKAGED	RETIRED	DDC
5	SPARE	120	PACKAGED	RETIRED	DDC


STEAM EXHAUST COILS

MARK NO.	ROOM	COIL SIZE	VALVE TYPE	VALVE SIZE	TEMP
1	EXISTING OFFICES	3500	9"x1/2"	1/2	118
2	VISITORS ROOM	4500	9"x1/2"	1/2	118
3	WAITING ROOM	1000	15"x1/4"	1/4	118
4	INTERVIEW ROOM	475	9"x1/2"	1/4	118
5	SPARE EXHAUST ROOM				

EXISTING RE-HEAT STEAM COILS

REPLACE STEAM CONTROL VALVES AND ACTUATORS (TYPICAL OF 3) FOR EACH STEAM COIL. VERIFY/FURNISH CONDENSATE TRAPS/TRAP OPERATION. VERIFY/FURNISH CONDENSATE TRAPS/TRAP OPERATION. STEAM VALVES ARE ACCESSIBLE FROM CAT WALK IN FAN ROOM.


- 1 - PACKAGED VAV HEAT PUMP UNIT - GROUND MOUNTED WITH HORIZONTAL DUCTWORK. WHILE TRYING TO KEEP AS CLOSE TO EXISTING AS POSSIBLE, ALL VAV UNITS SHALL BE INSTALLED IN THE SAME ROOM AS THE EXISTING UNIT.
- 2 - BASIS OF DESIGN IS VALENT EGAL, DANISH, YORK, TRANE OR CARRIER.
- 3 - PROVIDE UNIT WITH INDOOR INTERFACE TO INTERCONNECT WITH EXISTING DELTA DDC CONTROLS.
- 4 - PROVIDE UNIT WITH INDOOR INTERFACE TO INTERCONNECT WITH EXISTING DELTA DDC CONTROLS.
- 5 - DDC CONTROLS TO OPERATE STEAM RE-HEAT COILS AS PRIMARY HEATING SOURCE WHEN HEAT PUMP IS NOT OPERATING.



VAV BOXES

MARK NO.	TYPE	MAX COOLING CFM	20% OF COOLING CFM	MIN VENTILATION CFM	MIN	MAXIMUM DEADBAND CFM	MAXIMUM HEATING CFM 50% or VENT	INLET IN.	OUTLET IN.	MAX. STATIC LOSS *	CONTROL TYPE
VAV-5	VAV	7187.5	144	50	0	144	359	10	14X13	0.05	DDC
VAV-6	VAV	4025	805	300	0	805	2013	24X18	24X18	0.05	DDC
VAV-7	VAV	517.5	104	40	0	104	259	8	12X10	0.05	DDC
VAV-8	VAV	1380	276	50	0	276	690	12	16X15	0.05	DDC
VAV-9	VAV	546.25	109	60	0	109	273	8	12X10	0.05	DDC
TOTAL		7187.5	***	600		1438	3594				

* - VAV BOX ONLY - MAX. PRESSURE DROP
 ** - THIRD OCTAVE CERTIFIED RATING IN ACCORDANCE WITH ARI STANDARD 590-94
 *** - SET AIR FLOWS FOR EACH ZONE TO BE 115% OF ORIGINAL DESIGN CENS



1 VISITING HVAC FLOOR PLAN
 M2.0 SCALE 1/8"=1'-0"