


1 FIRE PROTECTION FLOOR PLAN  
 FP1.1 SCALE: NOT TO SCALE

NOTES:

- (A) - ALTER SPRINKLER LINES EXPOSED IN MECHANICAL ROOMS ABOVE THIS AREA DUE TO NEW DUCTWORK AND EQUIPMENT.
- (B) - EXISTING GYM FIRE SPRINKLER SYSTEM INSTALLED IN 1971. PROVIDE SEISMIC BRACING OF ALL PIPES PER CURRENT NFPA-13 & OSSC CHAPTER 16 REQUIREMENTS.
- (C) - EXISTING UPPER GYM & MECHANICAL MEZZANINE SPRINKLER SYSTEM INSTALLED IN 1971. PROVIDE SEISMIC BRACING OF ALL PIPES PER CURRENT NFPA-13 & OSSC CHAPTER 16 REQUIREMENTS.
- (D) - ALTER SPRINKLER LINES ABOVE CEILING TO MAKE WAY FOR NEW DUCTWORK.
- (E) - REMOVE EXISTING SPRINKLER SYSTEM FROM THIS AREA. NEW LINES TO BE INSTALLED ABOVE NEW CEILING.
- (F) - ALTER SPRINKLER LINES EXPOSED IN 2ND FLOOR DANCE AREA DUE TO NEW DUCTWORK AND EQUIPMENT.



1 -ADD #2 2/22/2018

M  
 E  
 A  
 Consulting Engineers  
 2007 S.E. Ash St.  
 Portland, OR 97214  
 PHN: (503) 231-0518  
 FAX: (503) 231-0677  
 INC. WWW.MEA-ENG.COM  
 CONTACT: Elena von Kaments

A NEW REMODEL PROJECT FOR:

**SHERWOOD HIGH SCHOOL**

16956 SW MEINECKE ROAD SHERWOOD, OR

DRAWN BY:	EVK
CHECKED BY:	SWM
DATE:	1-30-18
TITLE:	FIRE PROTECTION FLOOR PLAN
SCALE:	NOT TO SCALE

SHEET NO:	FP-1.1
	1 OF 1