

GENERAL NOTES:

L_____

- A. TECHNOLOGY DRAWINGS ARE DIAGRAMMATICAL AND MAY NOT ACCURATELY REFLECT ACTUAL CONSTRUCTION CONDITIONS. THE TECHNOLOGY CONTRACTOR SHALL BE RESPONSIBLE FOR COORDINATING THE INSTALLATION OF ALL TECHNOLOGY EQUIPMENT, WITH ALL TRADES PRIOR TO AND DURING CONSTRUCTION.
- B. TECHNOLOGY ENTRANCE LOCATION DESIGN IS BASED ON INFORMATION PROVIDED BY THE UTILITY THRU THE DESIGN PROCESS. HOWEVER IT IS UP TO THE CONTRACTOR TO VERIFY CONDITIONS AND REQUIREMENTS HAVE NOT CHANGED PRIOR TO THE INSTALLATION DATE.
- C. COORDINATE WITH LOCAL UTILITY PROVIDER FOR EXACT SERVICE CONDUIT SIZES AND LOCATION TO ROUTE TO CONDUIT TO.
- D. CUSTOMER TO PROVIDE ALL TRENCHING AND BACKFILLING. TRENCH TO BE 36 INCHES DEEP AND 30 INCHES WIDE, MEASURED FROM FINAL GRADE.
- E. THE TECHNOLOGY CONTRACTOR SHALL REFER TO THE ARCHITECTURAL DRAWINGS FOR ALL MOUNTING HEIGHTS AND FINISHES OF DEVICES AND FIXTURES.
- F. COORDINATE WITH MECHANICAL PLANS FOR LOCATIONS OF SMOKE, FIRE/SMOKE DAMPERS, AND ROOF TOP UNITS REQUIRING CONNECTION TO FIRE ALARM SYSTEM.
- G. FOR VOICE/DATA OUTLETS PROVIDE A SINGLE GANG MUD-RING WITH A 1" CONDUIT FROM THE TOP OF THE MUD-RING TO ACCESSIBLE CEILING SPACE. TERMINATE CONDUIT WITH END CONNECTORS AND THREAD ON PLASTIC BUSHING FOR CABLE PROTECTION. OUTLET SHALL BE AT THE SAME HEIGHT AS ADJACENT POWER OUTLET AND LESS THAN 18" SEPARATION. COORDINATE WITH ELECTRICAL.
- H. COORDINATE ALL DEVICE LOCATIONS WITH LATEST ARCHITECTURAL INTERIOR ELEVATIONS TO VERIFY DEVICES WILL NOT BE OBSTRUCTED.
- I. REFER TO ENLARGED TYPICAL UNIT PLANS (IF PROVIDED) FOR TYPICAL LAYOUTS FOR ALL APARTMENT UNIT TYPES.

	$> N \qquad $			
	FIRE ALARM SYMBOLS		SECURITY SYMBOLS	
F	FIRE ALARM MANUAL PULL STATION, +48" A.F.F.		CCTV CAMERA	A.F.F.
M	MAGNETIC DOOR HOLDER	(⊗ _{ptz}	DOME CAMERA (W/ PTZ OR FIX)	APP.
⊡–	SMOKE DETECTOR, DUCT, IONIZATION TYPE W/SAMPLING TUBE	PTZ	DOME CAMERA (W/ FIZ OR FIA)	С
P	SMOKE DETECTOR, DUCT, PHOTO TYPE W/SAMPLING TUBE	⊡<`Х`	INTRUSION SENSOR ('X' INDICATES DEG. OF COVERAGE)	C.O.
0	SMOKE DETECTOR, IONIZATION TYPE	G.B.	GLASS BREAK SENSOR	CATV
Ð	SMOKE DETECTOR, PHOTO TYPE	D	DOOR POSITION SENSOR	CCTV
Ð	HEAT DETECTOR, RATE-OF-RISE OR FIXED TEMP.	К	KEYPAD +48" A.F.F.	CLG
\oslash	FIRE MAIN FLOW DETECTION SWITCH	C.R.	PROXIMITY CARD READER +48" A.F.F.	(E)
	FIRE MAIN TAMPER DETECTION SWITCH	E.L.	ELECTRIC LATCH/LOCK	FACP
Ê	FIRE ALARM BELL, +80" A.F.F., U.O.N.	REX	REQUEST TO EXIT DEVICE	FP
E ∽ P E	FIRE ALARM SPEAKER, +80" A.F.F.			FS
	FIRE ALARM SPEAKER/STROBE, +80" TO 96" A.F.F.		APPROX. CAMERA VIEW	FSD
OR E	FIRE ALARM STROBE, +80" TO 96" A.F.F.			GND
IM	FIRE ALARM INPUT MODULE	ENTRY	APARTMENT ENTRY SYSTEM	I R
OM	FIRE ALARM OUTPUT MODULE			JB
FACP	FIRE ALARM CONTROL PANEL			N.I.C.
FARA	FIRE ALARM REMOTE ANNUNCIATOR		PAGING AND	OFCI
S	STAND ALONE - RESIDENTIAL SMOKE DETECTOR 120V W/ BATTERY		<u>INTERCOM SYMBOLS</u>	OFOI
\odot	CARBON MONOXIDE DETECTOR RESIDENTIAL 120V W/ BATTERY	S	CEILING MOUNTED SPEAKER	P.A.
		\$\$H	WALL MOUNTED SPEAKER	P.E.T.
			INTERCOM CALL SWITCH	SD
			SIGNAL BUZZER	TS
$\langle 1 \rangle$	NOTATIONS	Ä	SIGNAL HORN	TTB
$\mathbf{\underline{'}}$	DRAWING NOTE	VC	VOLUME CONTROL +48" A.F.F.	TYP.
2 E3		\mathbf{A}		U.G.
E3	DETAIL REFERENCE: TOP=DETAIL NO., BOTTOM=SHEET NO.	/Z01		U.O.N.
EF 2			- HOMERUN TO EQUIPMENT	W.G.
\mathcal{L}	MECHANICAL EQUIPMENT MARK NO. (SEE EQUIPMENT SCHEDULE)		> ZONE INDICATION	W.P.
AAA	EQUIPMENT NO. (SEE EQUIPMENT SCHEDULE)		-SPEAKER CONNECTION, NOT INDICATING CABLE PATH	X.P.

FIRE ALARM GENERAL NOTES:

A. HIGH-RISE BUILDING SHALL BE PROVIDED WITH AN AUTOMATIC SMOKE DETECTION SYSTEM IN ACCORDANCE WITH SECTION 907.2.12.1, A FIRE DEPARTMENT COMMUNICATION SYSTEM IN ACCORDANCE WITH SECTION 907.2.12.2 AND AN EMERGENCY VOICE ALARM COMMUNICATION SYSTEM IN ACCORDANCE WITH SECTION 907.5.2.2.

B. AREA SMOKE DETECTION IN ACCORDANCE WITH 907.2.12.1.1 SHALL BE CONNECTED TO AN AUTOMATIC FIRE ALARM SYSTEM. THE ACTIVATION OF ANY DETECTOR REQUIRED BY THIS SECTION SHALL ACTIVATE THE EMERGENCY VOICE ALARM SYSTEM IN ACCORDANCE WITH SECTION 907.5.2.2. IN ADDITION TO SMOKE DETECTORS REQUIRED BY SECTIONS 907.2.1 THROUGH 907.2.9 SMOKE DETECTORS SHALL ALSO BE LOCATED IN ROOMS HOUSING MECHANICAL EQUIPMENT, ELECTRICAL EQUIPMENT AND/OR TRANSFORMERS, TELEPHONE EQUIPMENT OR SIMILAR ROOM NOT EQUIPPED WITH A SPRINKLER PROTECTION. ALSO, EACH ELEVATOR MACHINE ROOM, MACHINERY SPACE, CONTROL ROOM, AND ELEVATOR LOBBIES.

\sum

ABBREVIATIONS

ABOVE FINISHED FLOOR APPROXIMATE CONDUIT CONDUIT ONLY CABLE TELEVISION CLOSED CIRCUIT TELEVISION CEILING MOUNTED EXISTING FIRE ALARM CONTROL PANEL FACEPLATE FLOW SWITCH (SEE FIRE ALARM SYMBOLS) FIRE/SMOKE DAMPER GROUND INFRARED JUNCTION BOX NOT IN CONTRACT OWNER FURNISHED, CONTRACTOR INSTALLED OWNER FURNISHED, OWNER INSTALLED PUBLIC ADDRESS PROTECTIVE ENTRANCE TERMINAL SMOKE DAMPER TAMPER SWITCH (SEE FIRE ALARM SYMBOLS) TELEPHONE TERMINAL BOARD TYPICAL UNDERGROUND UNLESS OTHERWISE NOTED WIRE GUARD WEATHERPROOF

EXPLOSION PROOF

FIRE ALARM AND DETECTION SYSTEM SHOWN ON PLAN(S) ARE FOR DESIGN INTENT ONLY. THIS IS A DEFERRED SUBMITTAL SYSTEM REQUIRING THE CONTRACTOR TO COMPLETE THE PERMIT READY DESIGN AND CALCULATIONS AS REQUIRED PER THE AUTHORITY HAVING JURISDICTION. VERIFY BUILDING OCCUPANCY TYPE AND OCCUPANT LOAD WITH ARCHITECTURAL PLANS.





Project Name:

MINNESOTA PLACES

1208 N. JESSUP & 5627 N. MINNESOTA (R226159, R226160)

PERMIT SET

Issued: 7.29.2021 PERMIT SET

Job #: 2020 ORIGINAL SHEET SIZE: 24" x 36" HALF SIZE: 12" x 18"

TECHNOLOGY SYMBOL LIST

Drawing Number

