



Checklist Comments Report

Project Name: ELE21-01722

Workflow Started: 12/14/2021 11:28 AM

Report Generated: 12/29/2021 04:18 PM

Grouping	Cycle	Ref #	Permit Type	Group Name	Comment Type	Category Type	Reviewer Comment	Applicant Response	Status	Updated By	Last Updated	Completed?	Date Completed
Main Workflow	1	3	Building Permit	Electrical Review	General	Department Review	Please provide how circuits originating at the Accessory Building Panel H1 serving lighting and power at the Plaza structure meet the requirements of NEC 225.30, 225.31, 225.32, 250.32.	MFIA: Plan set revised to provide a sub-fed NEMA 3R panel with MCB at the plaza structure (sub-fed from accessory bldg), to serve the plaza structure fixtures & devices.	Not Met	Brandon King	12/29/2021 11:15 AM	False	12/29/2021 11:15 AM
		4	Building Permit	Electrical Review	General	Department Review	Please provide available fault current documentation for new service per OAR 918-311-0040.	MFIA: Sheet E1.11 updated to include the available fault current provided by the utility.	Not Met	Brandon King	12/29/2021 11:15 AM	False	12/29/2021 11:15 AM
		5	Building Permit	Electrical Review	General	Department Review	Please provide energy compliance documentation for interior/exterior lighting. (COMcheck ASHRAE Standard 90.1-2019)	MFIA: Provided to architect at time of permit submittal. Will resend to arch to include with this response.	Not Met	Brandon King	12/29/2021 12:50 PM	False	12/29/2021 12:50 PM