



- HVAC NOTES:**
- PROVIDE VRF INDOOR FAN COILS AS REQUIRED FOR SPACE/TENANT LAYOUTS.
  - COORDINATE BRANCH SELECTOR BOXES AND REFRIGERANT PIPE ROUTING WITH ARCHITECT.
  - DOAS UNIT TO BE SIZED TO MEET BUILDING VENTILATION REQUIREMENTS
  - VRF SYSTEM TO BE SIZED TO MEET BUILDING HEATING AND COOLING LOADS, AND BE DESIGNED TO HANDLE INTENDED TENANT SPACE USES.

**1** 2ND FLOOR HVAC PLAN  
M2.01 SCALE: 1/4" = 1'-0"

THIS DRAWING IS INTENDED TO ASSIST THE DESIGNER/CONTRACTOR AND SHOULD BE USED AS A BASIS OF DESIGN ONLY. DESIGNER/CONTRACTOR SHALL BE RESPONSIBLE FOR COMPLETE DESIGN DOCUMENTS AND PERMITS AS REQUIRED BY ALL NATIONAL, STATE AND LOCAL CODES AND ORDINANCES.

THIS DRAWING IS NOT INTENDED TO BE USED FOR CONSTRUCTION OR FOR ANY PERMITTING APPLICATIONS

**Not for Construction**

HoodRiver Waterfront  
DD Set

Location:  
Lot 4 Industrial  
Hood River OR 97301  
Project No:  
15120  
Issue:  
DD Set

Date:  
Oct 9, 2015  
Revision:

**M2.01**