



22X22 GREASE EXHAUST AND MUA FOR FUTURE TYPE 1 HOOD, ROUTED UP TO ROOF IN 30X60 RATED SHAFT

VENTILATION DUCTS FROM UNIT TO BELOW

BATHROOM EXHAUST DUCT UP TO FAN ON ROOF

- HVAC NOTES:**
- PROVIDE VRF INDOOR FAN COILS AS REQUIRED FOR SPACE/TENANT LAYOUTS.
 - COORDINATE BRANCH SELECTOR BOXES AND REFRIGERANT PIPE ROUTING WITH ARCHITECT.
 - DOAS UNIT TO BE SIZED TO MEET BUILDING VENTILATION REQUIREMENTS
 - VRF SYSTEM TO BE SIZED TO MEET BUILDING HEATING AND COOLING LOADS, AND BE DESIGNED TO HANDLE INTENDED TENANT SPACE USES.

1 3rd FLOOR HVAC PLAN
M2.02 SCALE: 1/4" = 1'-0"

THIS DRAWING IS INTENDED TO ASSIST THE DESIGNER/CONTRACTOR AND SHOULD BE USED AS A BASIS OF DESIGN ONLY. DESIGNER/CONTRACTOR SHALL BE RESPONSIBLE FOR COMPLETE DESIGN DOCUMENTS AND PERMITS AS REQUIRED BY ALL NATIONAL, STATE AND LOCAL CODES AND ORDINANCES.

THIS DRAWING IS NOT INTENDED TO BE USED FOR CONSTRUCTION OR FOR ANY PERMITTING APPLICATIONS

43 Southwest 13th Ave. Suite 200
Portland, Oregon 97205 USA
+1 503 226 6315 Office
+1 503 226 0028 Fax
www.skylabarchitecture.com

M Consulting Engineers
F 2007 S.E. Ash St.
E Portland, OR 97214
INC. PHN: (503) 234-0548
FAX: (503) 234-0877
WWW.MFIA-ENG.COM
CONTACT: Mark Denyer/Ron Mart

Not for Construction

HoodRiver Waterfront
DD Set

Location:
Lot 4 Industrial
Hood River OR 97301

Project No:
15120

Issue:
DD Set

Date:
Oct 9, 2015

Revision:

M2.02

© 2015 SkyLab Architecture. This document is an Instrument of Service and the property of the Architect and may not be duplicated, displayed, or reproduced without the written consent of SkyLab Architecture.