



COMcheck Software Version COMcheckWeb

Mechanical Compliance Certificate

Project Information

Energy Code: 90.1 (2019) Standard
Project Title: Thurman Townhomes
Location: Portland, Oregon
Climate Zone: 4c
Project Type: New Construction

Construction Site:
2771 NW Thurman. St
Portland, Oregon 97210

Owner/Agent:
Sky Lab Architecture
503 525 9315

Designer/Contractor:
Mark Denyer
MFIA Consulting Engineers
(503) 234-0548

Mechanical Systems List

Quantity System Type & Description

- 6 HP-1 (Single Zone):
Split System Heat Pump
Heating Mode: Capacity = 12 kBtu/h,
Proposed Efficiency = 12.10 HSPF, Required Efficiency = 8.20 HSPF
Cooling Mode: Capacity = 12 kBtu/h,
Proposed Efficiency = 19.80 SEER, Required Efficiency: 14.00 SEER
Fan System: FAN SYSTEM 2 | FC-1 -- Compliance (Motor nameplate HP and fan efficiency method) : Passes


Fans:
FAN 2 Supply, Constant Volume, 383 CFM, 0.3 motor nameplate hp, 1.00 fan energy index
- 5 HP-2 (Single Zone):
Split System Heat Pump
Heating Mode: Capacity = 36 kBtu/h,
Proposed Efficiency = 9.00 HSPF, Required Efficiency = 8.20 HSPF
Cooling Mode: Capacity = 36 kBtu/h,
Proposed Efficiency = 16.00 SEER, Required Efficiency: 14.00 SEER
Fan System: FAN SYSTEM 1 | Townhouse -- Compliance (Motor nameplate HP and fan efficiency method) : Passes

Fans:
FAN 1 Supply, Constant Volume, 1200 CFM, 1.0 motor nameplate hp, 1.00 fan energy index
- 5 Water Heater:
Electric Storage Water Heater, Capacity: 50 gallons
No minimum efficiency requirement applies

Mechanical Compliance Statement

Compliance Statement: The proposed mechanical design represented in this document is consistent with the building plans, specifications, and other calculations submitted with this permit application. The proposed mechanical systems have been designed to meet the 90.1 (2019) Standard requirements in COMcheck Version COMcheckWeb and to comply with any applicable mandatory requirements listed in the Inspection Checklist.

Mark Denyer
Name - Title


Signature

1-11-22
Date



Inspection Checklist

Energy Code: 90.1 (2019) Standard

Requirements: 98.0% were addressed directly in the COMcheck software

Text in the "Comments/Assumptions" column is provided by the user in the COMcheck Requirements screen. For each requirement, the user certifies that a code requirement will be met and how that is documented, or that an exception is being claimed. Where compliance is itemized in a separate table, a reference to that table is provided.

| Section # & Req.ID | Plan Review | Complies? | Comments/Assumptions |
|---|---|--|--------------------------|
| 4.2.2, 6.4.4.2.1, 6.7.2 [PR2] ¹ | Plans, specifications, and/or calculations provide all information with which compliance can be determined for the mechanical systems and equipment and document where exceptions to the standard are claimed. Load calculations per acceptable engineering standards and handbooks. | <input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable | Requirement will be met. |
| 4.2.2, 7.7.1, 10.4.2 [PR3] ¹ | Plans, specifications, and/or calculations provide all information with which compliance can be determined for the service water heating systems and equipment and document where exceptions to the standard are claimed. Hot water system sized per manufacturer's sizing guide. | <input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable | Requirement will be met. |
| 4.2.2, 8.4.1.1, 8.4.1.2, 8.7 [PR6] ² | Plans, specifications, and/or calculations provide all information with which compliance can be determined for the electrical systems and equipment and document where exceptions are claimed. Feeder connectors sized in accordance with approved plans and branch circuits sized for maximum drop of 3%. | <input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable | Requirement will be met. |
| 4.2.5.2 [PR5] ¹ | Commissioning shall be performed as stated in Sections 5.9.2, 6.9.2, 7.9.2, 8.9.2, 9.9.2, 10.9.2, 11.2(d), and G1.2.1(c). Commissioning must utilize ASHRAE/IES Standard 202 or other generally accepted engineering standards acceptable to the building official. FPT and verification requirements for commissioning are as stated in Section 4.2.5.1. Commissioning shall document compliance of the building systems, controls, and building envelope with required provisions of this standard. Commissioning requirements shall be incorporated into the construction documents. | <input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable | Requirement will be met. |

Additional Comments/Assumptions:

| | | | | | |
|---|----------------------|---|------------------------|---|---------------------|
| 1 | High Impact (Tier 1) | 2 | Medium Impact (Tier 2) | 3 | Low Impact (Tier 3) |
|---|----------------------|---|------------------------|---|---------------------|

| Section # & Req.ID | Footing / Foundation Inspection | Complies? | Comments/Assumptions |
|-------------------------------|--|--|---|
| 6.4.3.7 [F09] ³ | Freeze protection and snow/ice melting system sensors for future connection to controls. | <input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable | Exception: Requirement does not apply. |

Additional Comments/Assumptions:

| | | | | | |
|---|----------------------|---|------------------------|---|---------------------|
| 1 | High Impact (Tier 1) | 2 | Medium Impact (Tier 2) | 3 | Low Impact (Tier 3) |
|---|----------------------|---|------------------------|---|---------------------|

| Section # & Req.ID | Plumbing Rough-In Inspection | Complies? | Comments/Assumptions |
|----------------------------|--|--|--------------------------|
| 7.4.4.1 [PL2] ³ | Temperature controls installed on service water heating systems (<=120°F to maximum temperature for intended use). | <input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable | Requirement will be met. |
| 7.4.6 [PL4] ³ | Heat traps installed on non-circulating storage water tanks. | <input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable | Requirement will be met. |

Additional Comments/Assumptions:

| | | | | | |
|---|----------------------|---|------------------------|---|---------------------|
| 1 | High Impact (Tier 1) | 2 | Medium Impact (Tier 2) | 3 | Low Impact (Tier 3) |
|---|----------------------|---|------------------------|---|---------------------|

| Section # & Req.ID | Mechanical Rough-In Inspection | Plans Verified Value | Field Verified Value | Complies? | Comments/Assumptions |
|---|--|----------------------|----------------------|--|--|
| 6.4.1.4, 6.4.1.5 [ME1] ² | HVAC equipment efficiency verified. Non-NAECA HVAC equipment labeled as meeting 90.1. | Efficiency: _____ | Efficiency: _____ | <input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable | See the Mechanical Systems list for values. |
| 6.4.3.4.1 [ME3] ³ | Stair and elevator shaft vents have motorized dampers that automatically close. | | | <input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable | Exception: Requirement does not apply. |
| 6.4.3.4.2, 6.4.3.4.3 [ME4] ³ | Outdoor air and exhaust systems have motorized dampers that automatically shut when not in use and meet maximum leakage rates. Check gravity dampers where allowed. | | | <input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable | Requirement will be met. |
| 6.4.3.4.5 [ME39] ³ | Enclosed parking garage ventilation has automatic contaminant detection and capacity to stage or modulate fans to 50% or less of design capacity. | | | <input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable | Exception: Requirement does not apply. |
| 6.4.3.4.4 [ME5] ³ | Ventilation fans >0.75 hp have automatic controls to shut off fan when not required. | | | <input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable | Exception: HVAC systems intended to operate continuously. |
| 6.4.3.8 [ME6] ¹ | Demand control ventilation provided for spaces >500 ft ² and >25 people/1000 ft ² occupant density and served by systems with air side economizer, auto modulating outside air damper control, or design airflow >3,000 cfm. | | | <input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable | Exception: Systems with heat recovery. |
| 6.5.3.2.1 [ME40] ² | DX cooling systems ≥ 75 kBtu/h (≥ 65 kBtu/h effective 1/2016) and chilled-water and evaporative cooling fan motor hp ≥ ¼ designed to vary supply fan airflow as a function of load and comply with operational requirements. | | | <input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable | Exception: Requirement does not apply. See the Mechanical Systems list for values. |
| 6.4.4.1.1 [ME7] ³ | Insulation exposed to weather protected from damage. Insulation outside of the conditioned space and associated with cooling systems is vapor retardant. | | | <input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable | Requirement will be met. |
| 6.4.4.1.2 [ME8] ² | HVAC ducts and plenums insulated per Table 6.8.2. Where ducts or plenums are installed in or under a slab, verification may need to occur during Foundation Inspection. | R- _____ | R- _____ | <input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable | Requirement will be met. |
| 6.4.4.1.3 [ME9] ² | HVAC piping insulation thickness. Where piping is installed in or under a slab, verification may need to occur during Foundation Inspection. | _____ in. | _____ in. | <input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable | Exception: Requirement does not apply. |
| 6.4.4.1.4 [ME41] ³ | Thermally ineffective panel surfaces of sensible heating panels have insulation ≥ R-3.5. | | | <input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable | Exception: Requirement does not apply. |

| | | | | | |
|---|----------------------|---|------------------------|---|---------------------|
| 1 | High Impact (Tier 1) | 2 | Medium Impact (Tier 2) | 3 | Low Impact (Tier 3) |
|---|----------------------|---|------------------------|---|---------------------|

| Section # & Req.ID | Mechanical Rough-In Inspection | Plans Verified Value | Field Verified Value | Complies? | Comments/Assumptions |
|-------------------------------|--|----------------------|----------------------|--|---|
| 6.4.4.2.1 [ME10] ² | Ducts and plenums having pressure class ratings are Seal Class A construction. | | | <input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable | Exception: Requirement does not apply. |
| 6.4.4.2.2 [ME11] ³ | Ductwork operating >3 in. water column requires air leakage testing. | | | <input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable | Exception: Requirement does not apply. |
| 6.4.4.2.2 [ME11] ³ | Ductwork operating >3 in. water column requires air leakage testing. | | | <input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable | Exception: Requirement does not apply. |
| 6.5.2.3 [ME19] ³ | Dehumidification controls provided to prevent reheating, recooling, mixing of hot and cold airstreams or concurrent heating and cooling of the same airstream. | | | <input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable | Exception: Cooling capacity 40 kBtu/h. |
| 6.5.2.4.1 [ME68] ³ | Humidifiers with airstream mounted preheating jackets have preheat auto-shutoff value set to activate when humidification is not required. | | | <input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable | Exception: Requirement does not apply. |
| 6.5.2.4.2 [ME69] ³ | Humidification system dispersion tube hot surfaces in the airstreams of ducts or air-handling units insulated >= R-0.5. | | | <input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable | Exception: Requirement does not apply. |
| 6.5.2.5 [ME70] ³ | Preheat coils controlled to stop heat output whenever mechanical cooling, including economizer operation, is active. | | | <input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable | Requirement will be met. Location on plans/spec: NA |
| 6.5.2.6 [ME106] ³ | Units that provide ventilation air to multiple zones and operate in conjunction with zone heating and cooling systems are prevented from using heating or heat recovery to warm supply air above 60°F when representative building loads or outdoor air temperature indicate that most zones demand cooling. | | | <input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable | Exception: Requirement does not apply. |
| 6.5.3.6 [ME72] ² | Motors for fans >= 1/12 hp and < 1 hp are electronically-commutated motors or have a minimum motor efficiency of 70%. These motors are also speed adjustable for either balancing or remote control. | | | <input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable | Requirement will be met. |
| 6.5.3.6 [ME72] ² | Motors for fans >= 1/12 hp and < 1 hp are electronically-commutated motors or have a minimum motor efficiency of 70%. These motors are also speed adjustable for either balancing or remote control. | | | <input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable | |

| Section # & Req.ID | Mechanical Rough-In Inspection | Plans Verified Value | Field Verified Value | Complies? | Comments/Assumptions |
|------------------------------|---|----------------------|----------------------|--|---|
| 6.5.3.4 [ME108] ² | Parallel-flow fan-powered VAV air terminals have automatic controls to a) turn off the terminal fan except when space heating is required or if required for ventilation; b) turn on the terminal fan as the first stage of heating before the heating coil is activated; and c) during heating for warmup or setback temperature control, either operate the terminal fan and heating coil without primary air or reverse the terminal damper logic and provide heating from the central air handler through primary air. | | | <input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable | Exception: Requirement does not apply. |
| 6.5.3.4 [ME108] ² | Parallel-flow fan-powered VAV air terminals have automatic controls to a) turn off the terminal fan except when space heating is required or if required for ventilation; b) turn on the terminal fan as the first stage of heating before the heating coil is activated; and c) during heating for warmup or setback temperature control, either operate the terminal fan and heating coil without primary air or reverse the terminal damper logic and provide heating from the central air handler through primary air. | | | <input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable | Exception: Requirement does not apply. |
| 6.5.3.7 [ME109] ² | Required minimum outdoor air rate is the larger of minimum outdoor air rate or minimum exhaust air rate required by Standard 62.1, Standard 170, or applicable codes or accreditation standards. Outdoor air ventilation systems shall comply with one of the following: a) design minimum system outdoor air provided < 135% of the required minimum outdoor air rate, b) dampers, ductwork, and controls allow the system to supply <= the required minimum outdoor air rate with a single set-point adjustment., or c) system includes exhaust air energy recovery complying with Section 6.5.6.1. | | | <input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable | Requirement will be met. |

| | | | | | |
|---|----------------------|---|------------------------|---|---------------------|
| 1 | High Impact (Tier 1) | 2 | Medium Impact (Tier 2) | 3 | Low Impact (Tier 3) |
|---|----------------------|---|------------------------|---|---------------------|

| Section # & Req.ID | Mechanical Rough-In Inspection | Plans Verified Value | Field Verified Value | Complies? | Comments/Assumptions |
|--------------------------------|---|----------------------|----------------------|--|---|
| 6.5.3.7 [ME109] ² | Required minimum outdoor air rate is the larger of minimum outdoor air rate or minimum exhaust air rate required by Standard 62.1, Standard 170, or applicable codes or accreditation standards. Outdoor air ventilation systems shall comply with one of the following: a) design minimum system outdoor air provided < 135% of the required minimum outdoor air rate, b) dampers, ductwork, and controls allow the system to supply <= the required minimum outdoor air rate with a single set-point adjustment., or c) system includes exhaust air energy recovery complying with Section 6.5.6.1. | | | <input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable | Requirement will be met. |
| 6.5.3.3 [ME42] ³ | Multiple zone VAV systems with DDC of individual zone boxes have static pressure setpoint reset controls. | | | <input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable | Exception: Requirement does not apply. <i>See the Mechanical Systems list for values.</i> |
| 6.5.3.3 [ME42] ³ | Multiple zone VAV systems with DDC of individual zone boxes have static pressure setpoint reset controls. | | | <input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable | Exception: Requirement does not apply. <i>See the Mechanical Systems list for values.</i> |
| 6.5.4.2 [ME25] ³ | HVAC pumping systems with >= 3 control valves designed for variable fluid flow (see section details). | | | <input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable | Exception: Requirement does not apply. |
| 6.5.6.1.1 [ME56] ¹ | Exhaust Air Energy Recovery for Nontransient Dwelling Units | | | <input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable | Requirement will be met. |
| 6.5.6.1.2 [ME111] ¹ | Exhaust air energy recovery for spaces other than Nontransient dwelling units meeting Tables 6.5.6.1.2-1, and 6.5.6.1.2-2. | | | <input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable | Exception: Requirements do not apply. |
| 6.5.7.2.1 [ME32] ² | Kitchen hoods >5,000 cfm have make up air >=50% of exhaust air volume. | | | <input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable | Exception: Requirement does not apply. |
| 6.5.7.1 [ME100] ² | Conditioned supply air to space with mechanical exhaust <= the greater of criteria of supply flow, required ventilation rate, exhaust flow minu the available transfer air (see section details). | | | <input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable | Requirement will be met. |
| 6.5.7.1 [ME100] ² | Conditioned supply air to space with mechanical exhaust <= the greater of criteria of supply flow, required ventilation rate, exhaust flow minu the available transfer air (see section details). | | | <input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable | Requirement will be met. |

| Section # & Req.ID | Mechanical Rough-In Inspection | Plans Verified Value | Field Verified Value | Complies? | Comments/Assumptions |
|-------------------------------|---|----------------------|----------------------|--|---|
| 6.5.3.8 [ME112] ¹ | Occupied standby controls for zones serving rooms that are required to have automatic partial OFF or automatic full OFF lighting controls per Section 9.4.1.1 shall meet the following within five minutes of all rooms in that zone entering occupied-standby mode: a)Active heating set point shall be setback at least 1°F, b)Active cooling set point shall be setup at least 1°F and c)All airflow supplied to the zone shall be shut off whenever the space temperature is between the active heating and cooling set points. | | | <input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable | Exception: Requirement does not apply. |
| 6.5.7.2.4 [ME49] ³ | Approved field test used to evaluate design air flow rates and demonstrate proper capture and containment of kitchen exhaust systems. | | | <input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable | Exception: Requirement does not apply. |
| 6.5.8.1 [ME34] ² | Unenclosed spaces that are heated use only radiant heat. | | | <input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable | Exception: Requirement does not apply. |
| 7.4.2 [ME36] ² | Service water heating equipment meets efficiency requirements. | | | <input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable | |
| 6.4.3.9 [ME63] ² | Heating for vestibules and air curtains with integral heating include automatic controls that shut off the heating system when outdoor air temperatures > 45F. Vestibule heating and cooling systems controlled by a thermostat in the vestibule with heating setpoint <= 60F and cooling setpoint >= 80F. | | | <input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable | Exception: Requirement does not apply. |
| 6.5.10 [ME73] ³ | Doors separating conditioned space from the outdoors have controls that disable/reset heating and cooling system when open. | | | <input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable | Requirement will be met. |

Additional Comments/Assumptions:

| | | | | | |
|---|----------------------|---|------------------------|---|---------------------|
| 1 | High Impact (Tier 1) | 2 | Medium Impact (Tier 2) | 3 | Low Impact (Tier 3) |
|---|----------------------|---|------------------------|---|---------------------|

| Section # & Req.ID | Rough-In Electrical Inspection | Complies? | Comments/Assumptions |
|---------------------------|--|--|--------------------------|
| 8.4.2 [EL10] ² | At least 50% of all 125 volt 15- and 20-Amp receptacles are controlled by an automatic control device. | <input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable | Requirement will be met. |
| 8.4.3 [EL11] ² | New buildings have electrical energy use measurement devices installed. Where tenant spaces exist, each tenant is monitored separately. In buildings with a digital control system the energy use is transmitted to to control system and displayed graphically. | <input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable | Requirement will be met. |
| 10.4.1 [EL9] ² | Electric motors meet requirements where applicable. | <input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable | Requirement will be met. |

Additional Comments/Assumptions:

| Section # & Req.ID | Final Inspection | Complies? | Comments/Assumptions |
|-------------------------------|---|--|--|
| 6.4.3.1.2 [FI3] ³ | Thermostatic controls have a 5 °F deadband. | <input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable | Requirement will be met. |
| 6.4.3.2 [FI20] ³ | Temperature controls have setpoint overlap restrictions. | <input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable | Requirement will be met. |
| 6.4.3.3.1 [FI21] ³ | HVAC systems equipped with at least one automatic shutdown control. | <input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable | Exception: Systems designed for continuous operation. |
| 6.4.3.3.2 [FI22] ³ | Setback controls allow automatic restart and temporary operation as required for maintenance. | <input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable | Exception: Systems designed for continuous operation. |
| 6.4.3.5 [FI5] ³ | Heat pump controls prevent supplemental electric resistance heat from coming on when not needed. | <input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable | Requirement will be met. |
| 6.4.3.5 [FI5] ³ | Heat pump controls prevent supplemental electric resistance heat from coming on when not needed. | <input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable | Exception: Heat pumps regulated by and meeting NAECA requirements and using internal electric resistance heating. |
| 6.4.3.6 [FI6] ³ | When humidification and dehumidification are provided to a zone, simultaneous operation is prohibited. Humidity control prohibits the use of fossil fuel or electricity to produce RH > 30% in the warmest zone humidified and RH < 60% in the coldest zone dehumidified. | <input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable | Requirement will be met. |
| 6.7.2.1 [FI7] ³ | Furnished HVAC as-built drawings submitted within 90 days of system acceptance. | <input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable | Requirement will be met. |
| 6.7.2.2 [FI8] ³ | Furnished O&M manuals for HVAC systems within 90 days of system acceptance. | <input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable | Requirement will be met. |
| 6.7.2.3 [FI9] ¹ | An air and/or hydronic system balancing report is provided for HVAC systems serving zones >5,000 ft2 of conditioned area. | <input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable | Requirement will be met. |
| 7.4.4.3 [FI11] ³ | Public lavatory faucet water temperature <=110°F. | <input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable | Requirement will be met. |
| 10.4.3 [FI24] ² | Elevators are designed with the proper lighting, ventilation power, and standby mode. | <input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable | Exception: Requirement does not apply. |

☐ 1 High Impact (Tier 1)
 ☒ 2 Medium Impact (Tier 2)
 ☐ 3 Low Impact (Tier 3)

| Section # & Req.ID | Final Inspection | Complies? | Comments/Assumptions |
|---------------------------|---|--|--------------------------|
| 7.4.3 [FI45] ² | First 8 ft of outlet piping in nonrecirculating storage system, or branch piping connected to recirculated, heat traced, or impedance heated piping is insulated. | <input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable | Requirement will be met. |

Additional Comments/Assumptions:

| | | | | | |
|---|----------------------|---|------------------------|---|---------------------|
| 1 | High Impact (Tier 1) | 2 | Medium Impact (Tier 2) | 3 | Low Impact (Tier 3) |
|---|----------------------|---|------------------------|---|---------------------|