



1 OVERALL FLOOR PLAN
 E1.11 SCALE: 1/16" = 1'-0"

GENERAL LIGHTING NOTES:

- A. CONTRACTOR SHALL FIELD VERIFY ALL EXISTING CONDITIONS PRIOR TO THE START OF ANY WORK, INCLUDING LOCATION OF ALL EXISTING ELECTRICAL PANELS AND SWITCH GEAR, AND REPORT ANY DISCREPANCIES TO THE ARCHITECT IMMEDIATELY.
- B. CONTRACTOR TO PROVIDE AND INSTALL TWO CEILING FANS IN EACH CLASSROOM (FOUR IN THE MUSIC ROOM). REFER TO SHEET E1.00 FOR FIXTURE SCHEDULE. FANS SHALL BE CIRCUITED TO NEAREST 480/277V BRANCH PANEL WITH AVAILABLE SPACE. CONTRACTOR TO FIELD IDENTIFY SPARE CIRCUIT AVAILABILITY PRIOR TO THE START OF ANY WORK TO DETERMINE WHICH CIRCUITS ARE TO BE USED.
- C. CONTRACTOR SHALL PROVIDE APPROPRIATE BLOCKING AND COORDINATE INSTALLATION WITH STRUCTURAL ENGINEER ABOVE THE DROP CEILING FOR CEILING FAN SUPPORT. BLOCKING SHALL PROVIDE ADEQUATE SUPPORT OF THE CEILING FAN WEIGHT AND MINIMIZE VIBRATION. SUPPORT(S) SHALL BE ABOVE THE DROP CEILING AT THE STRUCTURAL MEMBERS, EXTENDED TO THE CEILING GRID TO SUPPORT THE FIXTURE WEIGHT. FIXTURES SHALL NOT BE ATTACHED TO THE CEILING GRID IN ANY WAY. CONTRACTOR WILL MINIMIZE ANY CUTS IN THE CEILING TILES TO PROVIDE A FINISHED APPEARANCE.
- D. CEILING FANS SHALL BE PER DISTRICT STANDARD SPECIFICATION WITH 3-SPEED FUNCTIONS. PROVIDE WALL CONTROLS, LOCATED PER ARCHITECT'S DIRECTION AND CIRCUIT TO NEAREST EXISTING LIGHTING CIRCUIT WITH AVAILABLE CAPACITY TO SUPPORT THE ELECTRICAL LOAD.
- E. FIELD FIT CEILING FANS TO AVOID CONFLICT EXISTING LIGHTS AND OTHER CEILING FIXTURES.
- F. BALANCE CEILING FAN LOCATIONS TO ENSURE BEST POSSIBLE AIR CIRCULATION.
- G. PROVIDE ENVIROFAN SPEED CONTROL SWITCH MODEL 105FR (REVERSIBLE), OR APPROVED EQUAL MOUNT SWITCH AT 48" A.F.F. AS INDICATED ON PLANS, UNLESS OTHERWISE NOTED.

KEYED LIGHTING NOTES:

- ① 480/277V LIGHTING PANEL LOCATION.

RECORD DRAWING:
 THIS DRAWING HAS BEEN UPDATED TO REFLECT CHANGES MADE DURING CONSTRUCTION BASED UPON INFORMATION FURNISHED TO THE ENGINEER BY THE INSTALLATION CONTRACTOR. NO WARRANTY EITHER EXPLICIT OR IMPLIED IS GIVEN BY MFIA, INC. AS TO THE ACCURACY AND/OR COMPLETENESS OF THIS INFORMATION.

M Consulting Engineers
 2007 S.E. Ash St.
 Portland, OR 97214
 PHN: (503) 234-0548
 FAX: (503) 234-0877
 WWW.MFIA-ENG.COM
 CONTACT:

RECORD SET
 1/29/2016

COPYRIGHT 2015
 STEELE ASSOCIATES ARCHITECTS LLC
 All rights reserved. Reproduction or
 use in any form or by any means --
 graphic, electronic, mechanical, etc. --
 without written permission of
 STEELE ASSOCIATES ARCHITECTS LLC is
 prohibited and subject to criminal prosecution.

STEELE ASSOCIATES
 ARCHITECTS LLC
 760 NW YORK DRIVE, SUITE 200
 BEND, OR 97701
 541.382.9867 FAX 541.385.8816
 info@steele-arch.com

JEWELL ELEMENTARY REMODEL
 20350 MURPHY ROAD
 BEND OREGON
 ELECTRICAL OVERALL PLAN

PRINTS ISSUED:	DATE:
JOB NO. 14117.01	DATE 11-21-14
DRAWN BY CMT	CHECKED BY RL C
REVISIONS APPENDIX 1	DATE 4/13/15

SHEET NO.
E1.11
 OF SHEETS

RECORD SET - JANUARY 29, 2016