




IN THE EVENT CONFLICTS ARE DISCOVERED BETWEEN THE ORIGINAL SIGNED AND SEALED DOCUMENTS PREPARED BY THE ARCHITECTS AND OTHER CONSULTANTS, ANY COPY OF THE DOCUMENTS TRANSMITTED BY MAIL SHALL ELECTRONICALLY OR OTHERWISE, THE ORIGINAL SIGNED AND SEALED DOCUMENTS SHALL GOVERN.

PROJECT # 2019-179
DATE: 28 AUGUST 2020

REVISIONS
PLAN REVIEW 11.03.2020
PLAN REVIEW 03.19.2021
PLAN REVIEW 05.10.2021
OWNER CHANGES 06.20.2021
UTILITY COORD. 08.19.2021

McKINNEY LANE APARTMENTS PHASE II
RUSSELL DRIVE & MCKINNEY LANE
LEBANON, OREGON 97331

ELECTRICAL SYMBOL LIST

LIGHTING SYMBOLS

- LIGHT FIXTURE, RECESSED
- LIGHT FIXTURE, RECESSED - EMERGENCY
- LIGHT FIXTURE, SURFACE MOUNT
- LIGHT FIXTURE, SURFACE MOUNT - EMERGENCY
- LIGHT FIXTURE, STRIP
- LIGHT FIXTURE, STRIP - EMERGENCY
- DOWNLIGHT FIXTURE, RECESSED
- DOWNLIGHT FIXTURE, RECESSED, WALLWASH
- DOWNLIGHT FIXTURE, RECESSED - EMERGENCY
- LIGHT FIXTURE, WALL MOUNT
- LIGHT FIXTURE, CEILING MOUNT
- RECESSED LIGHT FIXTURE, WALL MOUNT
- LIGHT FIXTURE, WALL MOUNT
- LIGHT FIXTURE, WALL SCONCE
- LIGHT FIXTURE, COVE - RECESSED
- LIGHT FIXTURE, COVE - SURFACE
- LIGHT FIXTURE, UNDER CABINET/SHELF
- EXIT SIGN, UNIVERSAL MOUNT, W/ DIRECTIONAL ARROW
- EXIT SIGN, WALL MOUNT, +8"-0" A.F.F.
- EMERGENCY LIGHT W/ BATTERY PACK, +8"-0" A.F.F.
- FLOOD LIGHT
- AREA LUMINAIRE, POST TOP
- AREA LUMINAIRE, BOLLARD
- AREA LUMINAIRE, WALL MOUNT
- AREA LUMINAIRE, POLE MOUNT

SWITCH SYMBOLS

- SWITCH, SPST +48" A.F.F.
- SWITCH, DPST +48" A.F.F.
- SWITCH, 3-WAY +48" A.F.F.
- SWITCH, 4-WAY +48" A.F.F.
- SWITCH, MOMENTARY +48" A.F.F.
- SWITCH, DIMMER +48" A.F.F.
- SWITCH, SPST, W/PILOT LIGHT +48" A.F.F.
- SWITCH, 3-WAY, W/PILOT LIGHT +48" A.F.F.
- SWITCH, KEY-OPERATED +48" A.F.F.
- SWITCH, TIMED +48" A.F.F.
- EXISTING SWITCH, SPST
- PHOTOCELL CONTROL
- OCCUPANCY SENSOR CONTROL

WIRING SYMBOLS

- PANEL & CIRCUIT NUMBER
- HOMERUN TO PANEL
- CONDUCTOR SIZE (IF OTHER THAN #12)
- PHASE CONDUCTOR
- NEUTRAL CONDUCTOR
- GROUND CONDUCTOR
- CONCEALED CONDUIT
- CONDUIT SIZE
- CONDUIT (UNDER SLAB OR FLOOR)
- FLEXIBLE CONNECTION
- CONDUIT, STUBBED & CAPPED
- NORMAL POWER CIRCUIT LINETYPE
- EMERGENCY POWER CIRCUIT LINETYPE
- EXISTING POWER CIRCUIT LINETYPE
- PRIMARY ELECTRICAL UTILITY FEEDER
- SECONDARY ELECTRICAL UTILITY FEEDER

FIRE-RATED INSTALLATION NOTE:
ELECTRICAL ITEMS (LIGHT FIXTURES, BOXES, ETC.) WHICH ARE RECESSED INTO FIRE-RATED CEILINGS OR WALLS, SHALL BE "ALLOWED" IN DRYRUM BOARD ENCLOSURES PER ARCHITECTURAL DETAILS, OR THE DEVICES SHALL BE UL LISTED WITH FIRE-RATING EQUAL TO OR GREATER THAN THE FIRE-RATING OF THE ADJACENT CONSTRUCTION.

1. SYMBOLS & ABBREVIATIONS MAY OR MAY NOT APPLY TO PROJECT
2. REFER TO LOW VOLTAGE DRAWINGS FOR ASSOCIATED SYMBOLS

POWER SYMBOLS

- RECEPTACLE, SINGLE +18" A.F.F.
- RECEPTACLE, DUPLEX +18" A.F.F.
- RECEPTACLE, QUAD +18" A.F.F.
- RECEPTACLE, DUPLEX +48" ABV COUNTER
- RECEPTACLE, DUPLEX +18" A.F.F. (ONE OUTLET SWITCHED)
- RECEPTACLE, DUPLEX +18" A.F.F. (BOTH OUTLETS SWITCHED)
- RECEPTACLE, DUPLEX, PEDESTAL MOUNT
- RECEPTACLE, DUPLEX, FLUSH FLOOR MOUNT
- RECEPTACLE, SPECIAL (COORDINATE WITH EQUIPMENT SERVED)
- RELAY
- TIME CLOCK CONTROL
- PUSHBUTTON STATION
- JUNCTION BOX
- JUNCTION BOX, EMERGENCY CIRCUIT
- THERMOSTAT
- TRANSFORMER
- DISCONNECT, NON-FUSED
- DISCONNECT, FUSED
- ELECTRICAL CONNECTION
- ELECTRICAL CONNECTION, SINGLE MOTOR
- ELECTRICAL CONNECTION, MULTI-MOTOR
- ELECTRICAL DISTRIBUTION PANEL, RECESSED
- ELECTRICAL DISTRIBUTION PANEL, SURFACE
- MISCELLANEOUS PANEL, RECESSED
- MISCELLANEOUS PANEL, SURFACE
- FLUSH FLOOR BOX (W/ DEVICES AS SHOWN ON PLAN)
- FIRE SMOKE DAMPER

ONE-LINE DIAGRAM SYMBOLS

- ELECTRICAL DISTRIBUTION PANELBOARD (MLO)
- ELECTRICAL DISTRIBUTION PANELBOARD (MCB)
- SUB-FEED CIRCUIT BREAKER
- CIRCUIT BREAKER (TRIP RATING & POLES AS INDICATED ON PLAN)
- MAIN SWITCH (RATING & POLES AS INDICATED ON PLAN)
- FUSE (RATING & CLASS AS INDICATED ON PLAN)
- TRANSFER SWITCH (MANUAL OR AUTOMATIC)
- GENERATOR (RATING AS INDICATED ON PLAN)
- TRANSFORMER (RATING AS INDICATED ON PLAN)
- FUSE (RATING & CLASS AS INDICATED ON PLAN)
- GROUND SYSTEM (SIZE AS INDICATED ON PLAN)
- WATER PIPE GROUND ELECTRODE
- TRANSIENT VOLTAGE SURGE SUPPRESSOR
- UTILITY METER & METER BASE
- UTILITY METER CURRENT TRANSFORMER
- FEEDER NO. (SEE FEEDER SCHEDULE)
- POTENTIAL TRANSFORMER (RATING AS INDICATED ON PLANS)

ABBREVIATIONS

- 'A' LIGHT FIXTURE TYPE (SEE FIXTURE LIST)
- A.F.F. ABOVE FINISHED FLOOR
- A.F.G. ABOVE FINAL GRADE
- A.F.I. ARC FAULT INTERRUPTER
- A.T.S. TRANSFER SWITCH, AUTOMATIC
- C CONDUIT
- C.O. CONDUIT ONLY
- CATV CABLE TELEVISION
- CB CIRCUIT BREAKER
- CCTV CLOSED CIRCUIT TELEVISION
- C.T. CURRENT TRANSFORMER
- (E) EXISTING
- E.L. EMERGENCY LIGHT
- E.L.C. EXTERIOR LIGHTING CONTROL
- FACP FIRE ALARM CONTROL PANEL
- G.F.I. GROUND FAULT INTERRUPTER
- GROUND
- H.I.D. HIGH INTENSITY DISCHARGE
- HP HORSEPOWER
- I.G. ISOLATED GROUND
- I R INFRARED
- JB JUNCTION BOX
- LCP LIGHTING CONTROL PANEL
- MCB MAIN CIRCUIT BREAKER
- MLO MAIN LUGS ONLY
- M.T.S. TRANSFER SWITCH, MANUAL
- (N) NEW
- N.I.C. NOT IN CONTRACT
- N.L. NIGHT LIGHT
- OL OVERLOAD
- O.L.C. OFFICE LIGHTING CONTROL
- P POLE
- P.A. PUBLIC ADDRESS
- PC PARTIAL CIRCUIT
- PH PHASE
- PRI PRIMARY
- R.T.U. REMOTE TELEMETRY UNIT
- SEC SECONDARY
- SCCR SHORT CIRCUIT CURRENT RATING
- T.V.S.S. TRANSIENT VOLTAGE SURGE SUPPRESSOR
- U.G. UNDERGROUND
- U.O.N. UNLESS OTHERWISE NOTED
- VFD VARIABLE FREQUENCY DRIVE
- W WIRE
- W.G. WIRE GUARD
- W.P. WEATHERPROOF
- W.T. WATERTIGHT
- X.P. EXPLOSION PROOF

NOTATIONS

- DRAWING NOTE
- DETAIL REFERENCE: TOP=DETAIL NO., BOTTOM=SHEET NO.
- MECHANICAL EQUIPMENT MARK NO. (SEE EQUIPMENT SCHEDULE)
- EQUIPMENT NO. (SEE EQUIPMENT SCHEDULE)
- EQUIPMENT NO. (SEE EQUIPMENT SCHEDULE)
- EQUIPMENT NO. (SEE EQUIPMENT SCHEDULE)
- FIXTURE REFERENCE: TOP=TYPE, BOTTOM=LAMP QTY & WATTS

GENERAL CONSTRUCTION NOTES:


CONTRACTOR SHALL BE RESPONSIBLE FOR THOROUGHLY REVIEWING THE PLANS AND SPECIFICATION DOCUMENTS PRIOR TO THE START OF ANY WORK. ANY DISCREPANCIES IN THE PROJECT DOCUMENTS SHALL BE BROUGHT TO THE ATTENTION OF THE ARCHITECT IMMEDIATELY AND PRIOR TO THE START OF ANY WORK.

ALL DIMENSIONS ARE MEASURED TO THE CENTER OF THE DEVICE ABOVE FINISHED FLOOR UNLESS OTHERWISE NOTED AS IS STANDARD BUILDING PRACTICE.

ALL ELECTRICAL PLANS ARE DIAGRAMMATICAL AND THE CONTRACTOR SHALL CONSULT THE ARCHITECTURAL PLANS AND ELEVATIONS FOR EXACT LOCATION AND MOUNTING HEIGHTS OF DEVICES AND FIXTURES.

THE ELECTRICAL CONTRACTOR SHALL REVIEW ALL PROJECT DOCUMENTATION AND COORDINATE WITH ALL OTHER TRADES THROUGHOUT THE COURSE OF THE PROJECT.

ALL WORK SHALL BE IN ACCORDANCE WITH ALL NATIONAL, STATE AND LOCAL CODES. CONTRACTOR SHALL BE RESPONSIBLE TO BE INFORMED OF ALL SUCH CODES AS THEY APPLY TO THE SCOPE OF THE PROJECT.




IN THE EVENT CONFLICTS ARE DISCOVERED BETWEEN THE ORIGINAL SIGNED AND SEALED DOCUMENTS PREPARED BY THE ARCHITECTS AND THEIR CONSULTANTS, ANY COPY OF THE DOCUMENTS TRANSMITTED BY MAIL SHALL ELECTRONICALLY OR OTHERWISE, THE ORIGINAL SIGNED AND SEALED DOCUMENTS SHALL GOVERN.

PROJECT # 2019-179
DATE: 28 AUGUST 2020

REVISIONS	
PLAN REVIEW	11.03.2020
PLAN REVIEW	03.19.2021
PLAN REVIEW	05.10.2021
OWNER CHANGES	06.20.2021
UTILITY COORD.	08.19.2021

MCKINNEY LANE APARTMENTS PHASE II
RUSSELL DRIVE & MCKINNEY LANE
LEBANON, OREGON



1 SITE ELECTRICAL UTILITY PLAN
E1.01 SCALE: 1" = 30'-0"

GENERAL NOTES:

- ALL WORK SHALL BE PERFORMED IN ACCORDANCE WITH ALL APPLICABLE LOCAL, STATE AND NATIONAL CODES.
- ELECTRICAL PLANS ARE DIAGRAMMATIC AND MAY OR MAY NOT REFLECT ACTUAL FIELD CONDITIONS.
- REFER TO LIGHTING PLANS FOR BUILDING MOUNTED LIGHT FIXTURE LOCATIONS.
- COORDINATE WITH LOCAL UTILITY PROVIDER FOR EXACT SERVICE CONDUIT AND CONDUCTORS REQUIREMENTS.
- ALL UTILITY WORK SHALL BE DONE IN ACCORDANCE WITH CLARK PUBLIC UTILITIES ELECTRICAL SERVICE REQUIREMENTS.
- U.G. PRIMARY FEEDER SHALL HAVE A MINIMUM 48 INCH BURY.
- U.G. SECONDARY FEEDER SHALL HAVE A MINIMUM 36 INCH BURY.
- REFER TO SHEET E1.11 FOR ONE-LINE DIAGRAM, LOAD SUMMARY INFORMATION AND TYPICAL FEEDER SCHEDULE.
- SECONDARY CONDUIT SWEEPS SHALL BE MINIMUM 60 INCH RADIUS WITH A MINIMUM OF 7'-0" STRAIGHT CONDUIT RUN BETWEEN SWEEPS.
- CONTRACTOR SHALL REVIEW THE UTILITY PROVIDER'S ELECTRICAL SERVICE REQUIREMENTS PRIOR TO THE START OF ANY WORK.
- LOCATION AND INSTALLATION OF THE PRIMARY AND SECONDARY CONDUITS, TRANSFORMER, ETC. SHALL BE PROVIDED PER UTILITY PROVIDER'S ELECTRICAL SERVICE REQUIREMENTS.
- CONTRACTOR SHALL REVIEW ALL PROJECT DOCUMENTS AND SPECIFICATIONS IN DETAIL AND REFER TO THE DOCUMENTS THROUGHOUT THE CONSTRUCTION.
- CONTRACTOR SHALL CONSULT WITH THE CIVIL ENGINEER TO IDENTIFY ALL EXISTING UNDERGROUND UTILITIES PRIOR TO ANY TRENCHING.
- TRENCHING AND UNDERGROUND UTILITY CONDUIT RUNS SHALL BE PERFORMED IN COORDINATION WITH THE CIVIL PLANS.


KEYED POWER NOTES:

- 1" PVC CONDUIT ROUTED UNDER GROUND FROM HOUSE PANEL TO BUILDING DISCONNECT SWITCH. REFER TO PANEL SCHEDULES ON SHEET E1.11 FOR ADDITIONAL INFORMATION.
- PROVE WEATHER PROOF GFCI 20A 120V DUPLEX RECEPTACLES AT WATER VAULT(S) AS DIRECTED BE CIVIL ENGINEER. ROUTE EACH CIRCUIT IN 3/4" PVC CONDUIT UNDER GROUND FROM THE BUILDING #6 HOUSE PANEL.
- PROVIDE ONE EMPTY 1" PVC CONDUIT WITH PULL STRING FOR FUTURE POOL ELECTRICAL PANEL, ROUTED UNDERGROUND FROM CLUBHOUSE PANEL 'CH' TO THE EQUIPMENT PANEL AT THE POOL EQUIPMENT ROOM. A 60A, 208V, 1P DISCONNECT SHALL BE LOCATED AT THE BUILDING EXTERIOR, AHEAD FOR THE PANEL. REFER TO E5.02 FOR ADDITIONAL INFORMATION.
- ELECTRICAL CONTRACTOR SHALL COORDINATE WITH THE POOL EQUIPMENT INSTALLER TO PROVIDE AND INSTALL THE APPROPRIATE DISCONNECT MEANS FOR THE POOL EQUIPMENT FROM THE PANEL AT THE EQUIPMENT ROOM, AND PROVIDE FINAL ELECTRICAL CONNECTION(S).
- ROUTE ONE 3/4" PVC CONDUIT, EMPTY WITH PULL-STRING, UNDERGROUND FROM HOUSE PANEL 'CH2', CIRCUIT #10 STUBBED UP THE MONUMENT SIGNS AND CAP BOTH ENDS. PROVIDE ONE WEATHER PROOF J-BOX AT EACH SIGN. COORDINATE WITH SIGN INSTALLER AND PROVIDE FINAL ELECTRICAL CONNECTIONS.

UTILITY REQUIREMENTS

- CUSTOMER TO PROVIDE ALL TRENCHING AND BACKFILLING. TRENCH TO BE 36 INCHES DEEP AND 30 INCHES WIDE, MEASURED FROM FINAL GRADE.
- ALL UTILITY CONDUCTORS TO BE INSTALLED IN GRAY SCHEDULE 40, ELECTRICAL GRADE, PVC CONDUIT WITH NYLON PULL STRINGS (MIN 500 LBS. TEST). CLARK PUBLIC UTILITIES TO DETERMINE THE SIZE AND NUMBER OF CONDUITS REQUIRED. ALL ELBOWS TO BE 36 INCH (MIN) RADIUS. ALL BENDS MAY BE FACTORY MADE. IF MORE THAN 270 DEGREES OF BENDS OR IF RUN IS LONGER THAN 150 FEET, BENDS MUST BE RIGID STEEL.
- CONSULT WITH UTILITY REPRESENTATIVE 2 WEEKS BEFORE STARTING MAIN POWER TRENCHING FOR A PRE-CONSTRUCTION CONFERENCE. INCLUDED IN THIS CONFERENCE WILL BE EXCAVATOR, CPU, TELCO, CATV, AND GAS.
- UNLESS OTHERWISE NOTED, ALL UTILITY TRANSFORMERS USED ON THIS PROJECT SHALL BE OLD CASTLE PREFAB MODEL 644-TRANS-PCORP.

UTILITY SERVICE CONTACT:
Elke Vath
Journeyman Estimator
Work Order #6897227
Pacific Power
P: 541.967.6160
PO Box 246
Albany, OR 97322



GENERAL SITE LIGHTING NOTES:

- A. ALL WORK SHALL BE PERFORMED IN ACCORDANCE WITH ALL APPLICABLE LOCAL, STATE AND NATION CODES.
- B. ALL PLANS ARE CONSIDERED DIAGRAMMATICAL. THEREFORE ALL EQUIPMENT SIZES AND DEVICE LOCATIONS ARE APPROXIMATE AND SUBJECT TO FIELD CONDITIONS AND PRODUCT APPROVAL.
- C. REFER TO SHEETS E1.11 FOR ONE-LINE DIAGRAM, LOAD SUMMARY INFORMATION AND TYPICAL FEEDER SCHEDULE.
- D. REFER TO SHEETS E2 SERIES SHEETS FOR EXTERIOR BUILDING LIGHTS.
- E. REFER TO SHEET E1.21 FOR LIGHT FIXTURE SCHEDULE.

KEYED POWER NOTES:

1. 3/4" PVC CONDUIT ROUTED UNDER GROUND FROM HOUSE PANEL TO BUILDING STRUCTURE FOR LIGHTING CIRCUIT(S). REFER TO PANEL SCHEDULES ON SHEET E1.11 FOR ADDITIONAL INFORMATION.
2. 3/4" PVC CONDUIT ROUTED UNDER GROUND FROM HOUSE PANEL TO WEATHER PROOF J-BOX FOR MONUMENT SIGN LIGHTING. REFER TO PANEL SCHEDULES ON SHEET E1.11 FOR ADDITIONAL INFORMATION.



LUMINAIRE SCHEDULE									
Symbol	Label	Qty	Catalog Number	Description	Lamp	File	Lumens	LLF	Watts
	S1	13	AA-20166-1-W30-Rev.2	Atlantic sheppards crook single medium shade post top LED	1 LED COB 3000K 0.4247,0.3936 3130K Ra84	S1 AA-20166-1-W30-Rev.2 IES	Absolute	1.00	41.2
	S2	40		photopiaALMINRF-L18-YF20photopia	LED 0.959W XLAMP OUTDOOR WHITE (305MA) (CORE ONLY)	S2 NRF-LED70-L18-3D-CNS-YF20-LUS.ies	Absolute	1.00	70
	S3	5	AA-30186-1-W30-Rev.2	Atlantic sheppards crook medium shade wall light LED	1 LED COB 3000K 0.4247,0.3936 3130K Ra84	S3 AA-30186-1-W30-Rev.2 IES	Absolute	1.00	41.2
	S4	17	FEM L48 3000LM LPPFL PCO 90CRI 30K	FEM LED 48", 3,000 lumens, polycarbonate, low profile frosted lens, parking garage distribution, 90 CRI, 3000 K		S4 FEM_L48_3000LM_LPPFL_POD_90CRI30 K.ies	Absolute	1.00	18.05

STATISTICS						
Description	Symbol	Avg	Max	Min	Max/Min	Avg/Min
Parking 1	+	0.9 fc	3.8 fc	0.2 fc	19.0:1	4.5:1
Parking 2	+	0.9 fc	4.4 fc	0.2 fc	22.0:1	4.5:1
Parking 3	+	0.8 fc	3.8 fc	0.2 fc	19.0:1	4.0:1
Parking 4	+	1.2 fc	8.5 fc	0.3 fc	28.3:1	4.0:1
Parking 5	+	0.8 fc	2.1 fc	0.2 fc	10.5:1	3.0:1

- NOTES:
- Photometric studies are for reference only and shall not be used for construction purposes. Refer to the electrical site plan sheet, E1.02 for additional information.
 - Photometric data is based on manufacturer provided IES files. Illuminance calculations are approximate and may differ from actual field measurements.
 - Refer to Light Fixture Schedule on sheet E1.21 for fixture type, lamp, and pole heights.
 - Data does not factor in existing light fixtures on adjacent properties or at the street.
 - For the purposes of this study, areas with "0.0" lumen levels have been masked to provide the statistics shown in the table.
 - This study does not factor in building mounted light fixtures (other than those at the garages).

IN THE EVENT CONFLICTS ARE DISCOVERED
BETWEEN THE ORIGINAL SIGNED AND SEALED
DOCUMENTS PREPARED BY THE ARCHITECTS
AND THE COPIES TRANSMITTED BY MAIL, FAX,
ELECTRONICALLY OR OTHERWISE, THE ORIGINAL
SIGNED AND SEALED DOCUMENTS SHALL GOVERN.

PROJECT # 2019-179
DATE: 28 AUGUST 2020

REVISIONS

- PLAN REVIEW 11.03.2020
PLAN REVIEW 03.19.2021
PLAN REVIEW 05.10.2021
OWNER CHANGES 06.20.2021
UTILITY COORD. 08.19.2021

MCKINNEY LANE APARTMENTS PHASE II
RUSSELL DRIVE & MCKINNEY LANE
LEBANON, OREGON








1 PEDESTRIAN AREAS PHOTOMETRIC STUDY
E1.04
SCALE: 1" = 30'-0"

LUMINAIRE SCHEDULE									
Symbol	Label	Qty	Catalog Number	Description	Lamp	File	Lumens	LLF	Watts
	S1	13	AA-20166-1-W30-Rev 2	Atlantic sheppards crook single medium shade post top LED	1 LED COB 3000K 0.4247/0.3936 3130K Ra84	S1 AA-20166-1-W30-Rev 2 IES	Absolute	1.00	41.2
	S2	41		photopiaALMNRFL-16-YF20photopia	LED 0.959W XLAMP OUTDOOR WHITE (300MA) (CORE ONLY)	S2 NRF-LE070-L18-30 CANS-YF20-UL-5 IES	Absolute	1.00	70
	S3	5	AA-30186-1-W30-Rev 2	Atlantic sheppards crook medium shade wall light LED	1 LED COB 3000K 0.4247/0.3936 3130K Ra84	S3 AA-30186-1-W30-Rev 2 IES	Absolute	1.00	41.2
	S4	17	FEM L48 3000LM LPFPL PGD 90CRI 30K	FEM LED 48" 3000 lumens, polycarbonate, low profile frosted lens, parking garage distribution, 90 CRI, 3000 K		S4 FEM_L48_300 04LM LPFPL_P GD_90CRI_30 K IES	Absolute	1.00	18.05

STATISTICS						
Description	Symbol	Avg	Max	Min	Max/Min	Avg/Min
Bldg 5 & Grounds	+	2.3 fc	6.6 fc	0.3 fc	22.0:1	7.7:1
Bldg 6 Walks	+	2.2 fc	4.9 fc	0.2 fc	24.5:1	11.0:1
Bldg #2, 3, 4	+	2.4 fc	6.0 fc	0.2 fc	30.0:1	12.0:1
Clubhouse/Bldg #1 Walks	+	2.3 fc	5.0 fc	0.4 fc	12.5:1	5.8:1

- NOTES:
1. Photometric studies are for reference only and shall not be used for construction purposes. Refer to the electrical site plan sheet E1.02 for additional information.
2. Photometric data is based on manufacturer provided IES files. Illuminance calculations are approximate and may differ from actual field measurements.
3. Refer to Light Fixture Schedule on sheet E1.21 for fixture type, lamp, and pole heights.
4. Data does not factor in existing light fixtures on adjacent properties or at the street.
5. For the purposes of this study, areas with "0.0" lumen levels have been masked to provide the statistics shown in the table.
6. This study does not factor in building mounted light fixtures (other than those at the garages).



ELECTRICAL ONE-LINE DIAGRAMS (BY TYPICAL BUILDING TYPE)


MECHANICAL EQUIPMENT SCHEDULE									
NO.	EQUIPMENT NAME	HP/KW	VOLTS	PH	AMPS	CONDUIT	WIRE	GND	CIRCUIT
EF-1	EXHAUST FAN NO.1	11.7W	120	1		1/2"	#12	#12	SEE POWER PLANS
EH-1	ELECTRIC WALL HEATER NO.1	4.0 KW	240	1		1/2"	#10	#10	SEE POWER PLANS
EH-2	ELECTRIC WALL HEATER NO.2	2.0KW	240	1		1/2"	#12	#12	SEE POWER PLANS
EH-3	ELECTRIC WALL HEATER NO.3	1.5 KW	240	1		1/2"	#12	#12	SEE POWER PLANS
EH-4	ELECTRIC WALL HEATER NO.4	500W	120	1		1/2"	#12	#12	SEE POWER PLANS
EH-5	ELECTRIC WALL HEATER NO.5	500W	120	1		1/2"	#12	#12	SEE POWER PLANS
F-1	FAN COIL NO.1		120	1	11.7 MCA	1/2"	#12	#12	CH2-3
CU-1	CONDENSER NO.1		240	1	3/4"	#8	#10	#10	CH2-5,7
F-2	FAN COIL NO.2		120	1	11.7 MCA	1/2"	#12	#12	CH2-9
CU-2	CONDENSER NO.2		240	1		3/4"	#8	#10	CH2-11,13
WH-1	WATER HEATER NO.1	4.5 KW	240	1		1/2"	#12	#12	SEE POWER PLANS

GENERAL EQUIPMENT NOTES:

- CONTRACTOR/DESIGNER SHALL VERIFY ALL MECHANICAL EQUIPMENT CONNECTION LOAD REQUIREMENTS WITH THE MECHANICAL EQUIPMENT PROVIDER PRIOR TO ROUGH IN.
- MECHANICAL EQUIPMENT SIZES SHOWN IN THE MECHANICAL SCHEDULE ABOVE ARE FOR REFERENCE ONLY AND MAY NOT REFLECT THE ACTUAL EQUIPMENT TO BE INSTALLED.
- WALL HEATERS INSTALLED IN THE APARTMENT UNITS ARE TO BE PROVIDED AND INSTALLED BY THE ELECTRICAL CONTRACTOR. INSTALLATION TO INCLUDE WIRING AND DEVICES FOR REMOTE THERMOSTATS. COORDINATE WORK WITH THE MECHANICAL CONTRACTOR PRIOR TO ROUGH IN.

- EH-1 ELECTRIC WALL MOUNTED HEATER WITH REMOTE THERMOSTAT, 4.0KW @ 240V
- EH-2 ELECTRIC WALL MOUNTED HEATER WITH REMOTE THERMOSTAT, 2.0KW @ 240V
- EH-3 ELECTRIC WALL MOUNTED HEATER WITH REMOTE THERMOSTAT, 1.5KW @ 240V
- EH-4 ELECTRIC CEILING MOUNTED HEATER WITH REMOTE THERMOSTAT THERMOSTAT, 500W @ 120V
- EH-5 ELECTRIC WALL MOUNTED HEATER WITH INTEGRAL THERMOSTAT THERMOSTAT, 500W @ 120V

- ELECTRIC HEATER NOTES:
- WALL MOUNTED ELECTRIC FAN FORCED AIR HEATERS: UL LISTED RECESSED HEATER WITH PRIMARY ABS SECONDARY THERMAL SAFETIES WITH SECONDARY MANUAL RESET, NICHROME HEATING ELEMENT, RECESSED WALL (CEILING) CAN, TWO STAGE BLOWER, AND POWDER COAT METAL GRILL. APPROVED MFRS: CADET, QMARK, MARKEL, & KING.
 - ELECTRIC HEATER THERMOSTATS:
 - PRIMARY HEATERS (LIVING AREA): PROGRAMMABLE ELECTRONIC, LINE VOLTAGE REMOTE WALL MOUNTED THERMOSTAT WITH DIGITAL DISPLAY.
 - BEDROOM AND BATHROOM HEATERS: MECHANICAL LINE VOLTAGE WALL MOUNTED THERMOSTAT.



FEEDER SCHEDULE (COPPER)					
NO.	AMPS	CONDUIT	CONDUCTOR		
1		*(5) 4"	BY UTILITY CO.	& (1) GND	
2	1200A	4"	ea w/ (3) #600Kcmil	& (1) #3/0 GND	
3	800A	4"	ea w/ (3) #600Kcmil	& (1) #1/0 GND	
4	400A	3"	ea w/ (3) #500Kcmil	& (1) #3 GND	
5	125A	1 1/2"	(3) #1	& (1) #6 GND	
6	100A	1 1/2"	(3) #1	& (1) #8 GND	
7	60A	1"	(3) #4	& (1) #10 GND	

* PARALLEL FEEDER

ONE-LINE GENERAL NOTES:

- COORDINATE ALL WORK ASSOCIATED WITH ELECTRIC SERVICE WITH LOCAL UTILITY. PROVIDE ALL CONDUIT & CONDUCTORS, GROUNDING, TRANSFORMER VAULT/PAD, ETC., IN ACCORDANCE WITH SERVING UTILITY REQUIREMENTS.
- COORDINATE METERING REQUIREMENTS WITH UTILITY.
- FOR LOAD CENTER FEEDER LENGTHS GREATER THAN 145'-0" FROM METER CENTER, INCREASE WIRE SIZE ONE SIZE UP FOR VOLTAGE DROP.

ONE-LINE KEYED NOTES:

- GARAGES SUB-FED FROM BUILDING #3 ONLY.
- PROVIDE GROUNDING AS REQUIRED BY CODE.

MFA PANEL SCHEDULE										18-Mar-21
panel		mounting		location		connected load				
Pnl HP (Typical)		*Surface NEMA 3R		Building Exterior		bus & main				
voltage		phase		no.		MLO		calculated load		
120/240v		va		q/g		no.		va		
C	service	va	q/g <td>L1</td> <td>L2<td>va</td><td>q/g<td>vs</td><td>service</td></td></td>	L1	L2 <td>va</td> <td>q/g<td>vs</td><td>service</td></td>	va	q/g <td>vs</td> <td>service</td>	vs	service	
1	L1S + RECEPT - BLDG EXTERIOR	20/1	1	*	2	20/1			LIGHTING - SITE	
3	S1B4 - RISER ROOM	50/1	3	*	4	20/1			LIGHTING - SITE	
5	SPARE	20/1	5	*	6	20/1			SPARE	
7	SPARE	20/1	7	*	8	20/1			SPARE	
7	*MARGARE #1	11500	125/2	9	*	10	125/2	15000	*MARGARE #2	
		8500								
	BLANK		13	*	14				BLANK	
	BLANK		15	*	16				BLANK	
	BLANK		17	*	18				BLANK	
	BLANK		19	*	20				BLANK	
	BLANK		21	*	22				BLANK	
	BLANK		23	*	24				BLANK	
	BLANK		25	*	26				BLANK	
	BLANK		27	*	28				BLANK	
	BLANK		29	*	30				BLANK	
	BLANK		31	*	32				BLANK	
	BLANK		33	*	34				BLANK	
	BLANK		35	*	36				BLANK	
	BLANK		37	*	38				BLANK	
	BLANK		39	*	40				BLANK	
	BLANK		41	*	42				BLANK	
	Line 1	23000	VA	NOTES:				line-line voltage		
	Line 2	17500	VA	*PANEL WITH LOCKING COVER.				(v)		
				**MDO AT BLDG 7 PANEL ONLY				largest motor		
				ALL OTHERS ARE 100A				0		
Total Connected		47500		VA		total factor		calculated load (va)		
load code:		line 1		line 2		VA		0		
1. LIGHTS		0		VA		0.1		0		
2. RECEPT		0		VA		0.1 + 0.5		0		
3. HEATING		0		500		VA		500		
4. KITCHEN		0		VA		1.00		0		
5. EQUIP		0		VA		1.00		0		
6. MOTORS		0		VA		1.00		0		
7. SUB-PANEL		23000		VA		4000		40000		
(7 = 25% of the largest motor + 100% of the balance)						TOTAL =		40500		

McKinney Lane Phase II																	
BUILDINGS "A" & "F"				RESIDENTIAL LOAD SUMMARY - Bldg Type "A"/Bldgs "A" & "F"													
UNIT TYPE:	QTY PER FLOOR				TOTAL	AREA (SF)	LTS/RECEPT (3VA / 3F)	SM APPL (1500VA X 2)	LAUNDRY (1500VA)	COOKING (CONNECTED)	MICROWAVE (CONNECTED)	DISHWASHER (CONNECTED)	ELECT DRYER (CONNECTED)	WATER HEATER (CONNECTED)	DISPOSAL (CONNECTED)	MOTORS (CONNECTED)	LARGEST O/C AC/HEATING (CONNECTED)
	LW 1	LW 2															
Typical Studio Unit	8	8	0	0	16	500	1500	3000	1500	16500	1500	1200	4000	4500	900	0	4000
TOTALS:	8	8	0	0	16	8000	24000	48000	24000	264000	24000	19200	64000	72000	14400	0	64000
VOLTS:						240	1ph										
TOTALS CONNECTED:						618	KVA										
DEMAND FACTOR:						0.39	Based on Total Number of Residential Units = 16-17 (See N.E.C. Article: 220.84)										
TOTAL CALCULATED:						241	KVA										
CALCULATED AMPS:						1004	AMPS										
NOTE:																	

McKinney Lane Phase II																	
BUILDING "C"				RESIDENTIAL LOAD SUMMARY – Bldg Type "AS"/Bldg "C"													
UNIT TYPE:	QTY PER FLOOR				TOTAL	AREA (SF)	LITG/RECEPT (3VA / 3F)	SM APPL (1500VA X 2)	LAUNDRY (1500VA)	COOKING (CONNECTED)	MICROWAVE (CONNECTED)	DISHWASHER (CONNECTED)	ELECT DRYER (CONNECTED)	WATER HEATER (CONNECTED)	DISPOSAL (CONNECTED)	MOTORS (CONNECTED)	LARGEST OF: AC/HEATING (CONNECTED)
	LW 1	LW 2															
Typical Studio Unit	4	4	0	0	8	500	1500	3000	1500	16500	1500	1200	4000	4500	900	0	4000
TOTALS:	4	4	0	0	8	4000	12000	24000	12000	132000	12000	9600	32000	36000	7200	0	32000
VOLTS:		240		1ph													
TOTAL CONNECTED:		309		KVA													
DEMAND FACTOR:		0.43		Based on Total Number of Residential Units = 8–10 (See N.E.C. Article: 220.84)													
TOTAL CALCULATED:		133		KVA													
CALCULATED AMPS:		553		AMPS													
NOTE:																	

McKinney Lane Phase II																	
BUILDING "B"					RESIDENTIAL LOAD SUMMARY – Bldg Type "B"/Bldg "B"												
UNIT TYPE:	QTY PER FLOOR				TOTAL	AREA (SF)	Ltg/RECEPT (3VA / 3F)	SM APPL (1500VA X 2)	LAUNDRY (1500VA)	COOKING (CONNECTED)	MICROWAVE (CONNECTED)	DISHWASHER (CONNECTED)	ELECT DRYER (CONNECTED)	WATER HEATER (CONNECTED)	DISPOSAL (CONNECTED)	MOTORS (CONNECTED)	LARGEST O/C AC/HEATING (CONNECTED)
	Lv 1	Lv 2															
Typical 1 Brm Unit	7	7	0	0	14	660	1980	3000	1500	16500	1500	1200	4000	4500	900	0	7000
TOTALS:	7	7	0	0	14	9240	27720	42000	21000	231000	21000	16800	56000	63000	12600	0	98000
VOLTS: 240 TOTAL CONNECTED: 589 KVA DEMAND FACTOR: 0.40 TOTAL CALCULATED: 236 KVA CALCULATED AMPS: 982 AMPS NOTE: Based on Total Number of Residential Units = 14–15 (See N.E.C. Article: 220.84)																	

McKinney Lane Phase II																		
BUILDINGS "D" & "E"				RESIDENTIAL LOAD SUMMARY – Bldg Type "C"/ Bldgs "D" & "E"														
UNIT TYPE:	QTY PER FLOOR				TOTAL	AREA (SF)	L16/RECEPT (3VA / S'F)	SM APPL (1500VA X 2)	LAUNDRY (1500VA)	COOKING (CONNECTED)	MICROWAVE (CONNECTED)	DISHWASHER (CONNECTED)	ELECT DRYER (CONNECTED)	WATER HEATER (CONNECTED)	DISPOSAL (CONNECTED)	MOTORS (CONNECTED)	LARGEST O/C AC/HEATING (CONNECTED)	
	LW 1	LW 2																
Typical 1 Brm Unit	2	2	0	0	4	660	1980	3000	1500	16500	1500	1200	4000	4500	900	0	7000	
Typical 2 Brm Unit	4	4	0	0	8	1060	3180	3000	1500	16500	1500	1200	4000	4500	900	0	8500	
TOTALS:	6	6	0	0	12	11120	33360	36000	18000	198000	18000	14400	48000	54000	10800	0	96000	
VOLTS:					240	1ph												
TOTAL CONNECTED:					527	KVA												
DEMAND FACTOR:					0.41	Based on Total Number of Residential Units = 12-13 (See N.E.C. Article: 220.84)												
TOTAL CALCULATED:					216	KVA												
CALCULATED AMPS:					900	AMPS												
NOTE:																		

DWELLING UNIT LOAD CALCULATION	
Project: McKinney Lane Phase II	
Unit Type: Studio	
Area: 500 square feet (average)	
Minimum Size Feeder (NEC 220.40):	
General lighting load at 3 VA / SF	1,500 VA
Small Appliance load (2 cks at 1500VA each)	3,000 VA
Laundry Load (1 ckt at 1500VA)	1,500 VA
Range (GAS)	16,500 VA
Other Cooking Appliance Load (Microwave Oven)	1,500 VA
Dishwasher Load	1,200 VA
Electric Dryer Load	4,000 VA
Electric Water Heater Load	4,500 VA
Disposal load	900 VA
Other motor loads	0 VA
Total "General Loads"	34,800 VA
First 10 kVA of "general loads" at 100%	10,000 VA
Remainder of "general loads" at 40%	9,840 VA
Net "general load"	19,840 VA
Largest of:	
4,000 VA of electric space heating (less than 4) at 65%	2,600 VA
VA of electric space heating (4 or more) at 40%	0 VA
VA of air conditioning/cooling/heat pumps at 100%	0 VA
TOTAL LOAD	22,440 VA
For 120/240-volt, 3-wire, single-phase service or feeder,	
22,440 VA / 240 volts =	94 Amps
Therefore, this dwelling unit shall be permitted to be served by a _____ 125 amp service.	

DWELLING UNIT LOAD CALCULATION	
Project: McKinney Lane II	
Unit Type: 1 Bedroom	
Area: 660 square feet (average)	
Minimum Size Feeder (NEC 220.40):	
General lighting load at 3 VA / SF	1,980 VA
Small Appliance load (2 cks at 1500VA each)	3,000 VA
Laundry Load (1 ckt at 1500VA)	1,500 VA
Range (GAS)	16,500 VA
Other Cooking Appliance Load (Microwave Oven)	1,500 VA
Dishwasher Load	1,200 VA
Electric Dryer Load	4,000 VA
Electric Water Heater Load	4,500 VA
Disposal load	900 VA
Other motor loads	0 VA
Total "General Loads"	35,080 VA
First 10 kVA of "general loads" at 100%	10,000 VA
Remainder of "general loads" at 40%	10,032 VA
Net "general load"	20,032 VA
Largest of:	
7,000 VA of electric space heating (less than 4) at 65%	4,550 VA
VA of electric space heating (4 or more) at 40%	0 VA
VA of air conditioning/cooling/heat pumps at 100%	0 VA
TOTAL LOAD	24,582 VA
For 120/240-volt, 3-wire, single-phase service or feeder,	
24,582 VA / 240 volts =	102 Amps
Therefore, this dwelling unit shall be permitted to be served by a _____ 125 amp service.	

DWELLING UNIT LOAD CALCULATION	
Project: McKinney Lane II	
Unit Type: 2 Bedroom	
Area: 1,080 square feet (average)	
Minimum Size Feeder (NEC 220.40):	
General lighting load at 3 VA / SF	3,180 VA
Small Appliance load (2 cks at 1500VA each)	3,000 VA
Laundry Load (1 ckt at 1500VA)	1,500 VA
Range	16,500 VA
Other Cooking Appliance Load (Microwave Oven)	1,500 VA
Dishwasher Load	1,200 VA
Electric Dryer Load	4,000 VA
Electric Water Heater Load	4,500 VA
Disposal load	900 VA
Other motor loads	0 VA
Total "General Loads"	36,280 VA
First 10 kVA of "general loads" at 100%	10,000 VA
Remainder of "general loads" at 40%	10,512 VA
Net "general load"	20,512 VA
Largest of:	
8,500 VA of electric space heating (less than 4) at 65%	5,525 VA
VA of electric space heating (4 or more) at 40%	0 VA
VA of air conditioning/cooling/heat pumps at 100%	0 VA
TOTAL LOAD	26,037 VA
For 120/240-volt, 3-wire, single-phase service or feeder,	
26,037 VA / 240 volts =	108 Amps
Therefore, this dwelling unit shall be permitted to be served by a _____ 125 amp service.	

MFA CIRCUIT DIRECTORY	
Location Name: LC-STUDIO (TYPICAL)	location
mounting: RECESSED	
phase: 120/240V	bus & main (SCORE: 22K)
service: 125A MLO	
no. L1 L2 no. e/f	no. e/f
20/1(A) 1 * 2	20/1(A) 1 * 2
20/1(A) 3 * 4	20/1(A) 3 * 4
20/1(A) 5 * 6	20/1(A) 5 * 6
20/1(A) 7 * 8	20/1(A) 7 * 8
20/1(A) 9 * 10	20/1(A) 9 * 10
20/1(A) 11 * 12	20/1(A) 11 * 12
20/1(A) 13 * 14	20/1(A) 13 * 14
20/1(A) 15 * 16	20/1(A) 15 * 16
20/1(A) 17 * 18	20/1(A) 17 * 18
20/1(A) 19 * 20	20/1(A) 19 * 20
20/1(A) 21 * 22	20/1(A) 21 * 22
20/1(A) 23 * 24	20/1(A) 23 * 24
20/1(A) 25 * 26	20/1(A) 25 * 26
20/1(A) 27 * 28	20/1(A) 27 * 28
20/1(A) 29 * 30	20/1(A) 29 * 30
20/1(A) 31 * 32	20/1(A) 31 * 32
20/1(A) 33 * 34	20/1(A) 33 * 34
20/1(A) 35 * 36	20/1(A) 35 * 36
20/1(A) 37 * 38	20/1(A) 37 * 38
20/1(A) 39 * 40	20/1(A) 39 * 40
20/1(A) 41 * 42	20/1(A) 41 * 42


NOTES:
1. (A) DENOTES: ARC-FAULT INTERRUPTER CIRCUIT BREAKER. INSTALL PER NEC 210.12
2. LOADS FOR THIS PANEL ARE INDICATED ON THE "DWELLING UNIT LOAD CALCULATION".
3. BREAKER & WIRE SHALL BE SIZED FOR EQUIPMENT INSTALLED.
4. (G) DENOTES GFCI RATED BREAKER.

MFA CIRCUIT DIRECTORY	
Location Name: LC-1BR (TYPICAL)	location
mounting: RECESSED	
phase: 120/240V	bus & main (SCORE: 22K)
service: 125A MLO	
no. L1 L2 no. e/f	no. e/f
20/1(A) 1 * 2	20/1(A) 1 * 2
20/1(A) 3 * 4	20/1(A) 3 * 4
20/1(A) 5 * 6	20/1(A) 5 * 6
20/1(A) 7 * 8	20/1(A) 7 * 8
20/1(A) 9 * 10	20/1(A) 9 * 10
20/1(A) 11 * 12	20/1(A) 11 * 12
20/1(A) 13 * 14	20/1(A) 13 * 14
20/1(A) 15 * 16	20/1(A) 15 * 16
20/1(A) 17 * 18	20/1(A) 17 * 18
20/1(A) 19 * 20	20/1(A) 19 * 20
20/1(A) 21 * 22	20/1(A) 21 * 22
20/1(A) 23 * 24	20/1(A) 23 * 24
20/1(A) 25 * 26	20/1(A) 25 * 26
20/1(A) 27 * 28	20/1(A) 27 * 28
20/1(A) 29 * 30	20/1(A) 29 * 30
20/1(A) 31 * 32	20/1(A) 31 * 32
20/1(A) 33 * 34	20/1(A) 33 * 34
20/1(A) 35 * 36	20/1(A) 35 * 36
20/1(A) 37 * 38	20/1(A) 37 * 38
20/1(A) 39 * 40	20/1(A) 39 * 40
20/1(A) 41 * 42	20/1(A) 41 * 42





NOTES:
1. (A) DENOTES: ARC-FAULT INTERRUPTER CIRCUIT BREAKER. INSTALL PER NEC 210.12
2. LOADS FOR THIS PANEL ARE INDICATED ON THE "DWELLING UNIT LOAD CALCULATION".
3. BREAKER & WIRE SHALL BE SIZED FOR EQUIPMENT INSTALLED.
4. (G) DENOTES GFCI RATED BREAKER.

MFA CIRCUIT DIRECTORY	
Location Name: LC-2BR (TYPICAL)	location
mounting: RECESSED	
phase: 120/240V	bus & main (SCORE: 22K)
service: 125A MLO	
no. L1 L2 no. e/f	no. e/f
20/1(A) 1 * 2	20/1(A) 1 * 2
20/1(A) 3 * 4	20/1(A) 3 * 4
20/1(A) 5 * 6	20/1(A) 5 * 6
20/1(A) 7 * 8	20/1(A) 7 * 8
20/1(A) 9 * 10	20/1(A) 9 * 10
20/1(A) 11 * 12	20/1(A) 11 * 12
20/1(A) 13 * 14	20/1(A) 13 * 14
20/1(A) 15 * 16	20/1(A) 15 * 16
20/1(A) 17 * 18	20/1(A) 17 * 18
20/1(A) 19 * 20	20/1(A) 19 * 20
20/1(A) 21 * 22	20/1(A) 21 * 22
20/1(A) 23 * 24	20/1(A) 23 * 24
20/1(A) 25 * 26	20/1(A) 25 * 26
20/1(A) 27 * 28	20/1(A) 27 * 28
20/1(A) 29 * 30	20/1(A) 29 * 30
20/1(A) 31 * 32	20/1(A) 31 * 32
20/1(A) 33 * 34	20/1(A) 33 * 34
20/1(A) 35 * 36	20/1(A) 35 * 36
20/1(A) 37 * 38	20/1(A) 37 * 38
20/1(A) 39 * 40	20/1(A) 39 * 40
20/1(A) 41 * 42	20/1(A) 41 * 42

NOTES:
1. (A) DENOTES: ARC-FAULT INTERRUPTER CIRCUIT BREAKER. INSTALL PER NEC 210.12
2. LOADS FOR THIS PANEL ARE INDICATED ON THE "DWELLING UNIT LOAD CALCULATION".
3. BREAKER & WIRE SHALL BE SIZED FOR EQUIPMENT INSTALLED.
4. (G) DENOTES GFCI RATED BREAKER.



1 TYPICAL WASHER/DRYER ALCOVE
NO SCALE



MFA PANEL SCHEDULE											18-Mar-21
panel Pnl G125 (typical)		mounting Surface NEMA 3R		location Big Exterior		connected load				83	
voltage 120/240V				bus & bldg		calculated load				83	
C		1		125A/60A		MLO				83	
services		w/ o/p		L1 L2		w/ o/p		w/ o/p		83	
5	STALL 1 LTS & RECEPT	1500	20/1	1	2	2	20/1	1500	STALL 4 LTS & RECEPT	5	
5	STALL 2 LTS & RECEPT	1500	20/1	1	2	2	20/1	1500	STALL 5 LTS & RECEPT	5	
5	STALL 3 LTS & RECEPT	1500	20/1	1	2	2	20/1	1500	STALL 6 LTS & RECEPT	5	
3	DH-1 HEATER	2000	20/2	7	*	8	20/2	2000	DH-1 HEATER	3	
		2000	9	*	10		2000			3	
MAINT. SHOP RECEPT.		1500	20/1	12	11	12	20/1	0 SPARE		3	
2 MAINTANCE SHOP RECEPT.		1500	20/1	13	*	14	20/1	0 SPARE		3	
BLANK			15	*	16		BLANK				
BLANK			17	*	18		BLANK				
BLANK			19	*	20		BLANK				
BLANK			21	*	22		BLANK				
BLANK			23	*	24		BLANK				
BLANK			25	*	26		BLANK				
BLANK			27	*	28		BLANK				
BLANK			29	*	30		BLANK				
BLANK			31	*	32		BLANK				
BLANK			33	*	34		BLANK				
BLANK			35	*	36		BLANK				
BLANK			37	*	38		BLANK				
BLANK			39	*	40		BLANK				
BLANK			41	*	42		BLANK				
Line 1		11500	VA					NOTES			
Line 2		8500	VA	PROVIDE PANEL WITH LOCKING COVER. AT GARGE ONLY BUILDING				line-line voltage		240	
Total Connected		20000	VA					largest motor (w/ o)		0	
load code:		line 1	line 2	VA		total		calculated load (w/ o)		0	
1. LIGHTS=		1500	1500	0		1,125				0	
2. RECEPT.=		4000	4000	0		3000 + 0.5				3000	
3. HEATING=		4000	4000	0		8000 / 1.00				8000	
4. VENTILATION=		0	0	0		1,000 / 1.00				0	
5. EQUIP.=		6000	3000	0		9000 / 1.00				9000	
6. ELEVATOR=		0	0	0		0 / 1.00				0	
7. SUB-PANEL=		0	0	0		0 / 1.00				0	
(* 125% of the largest motor + 100% of the balance)						TOTAL =				20000	


LIGHTING FIXTURE LIST - CLUBHOUSE					
TYPE	LAMP	MANUFACTURER	CATALOG NUMBER	DESCRIPTION	OPTIONS
A1 A1E	LED 3000K 2000LM/80CRI 25W	LITHONIA (OR APPROVED OTHER)	ZLN SERIES	TYPE :4" GEN. PURPOSE STRIP MOUNTING :SURFACE HOUSING :STEEL LENS/REFL :DIFFUSED ACRYLIC VOLTAGE :MVOLT BALLAST :LED DRIVER	TYPE 'AE' SIMILAR TO TYPE 'A' EXCEPT WITH EMERGENCY BATTERY BACK-UP MAINTENANCE OFFICE, GARAGES
A2	13W A19 LED (60W INCAND. EQUAL) 13 W	BRYANT		TYPE :PORCELAIN KEYLESS SOCKET MOUNTING :WALL +6" ABV. DOOR HOUSING :N/A LENS/REFL :N/A VOLTAGE :120V BALLAST :INTEGRAL LED DRIVER	WITH PULL CHAIN FIRE RISER ROOM
C1 C1E	LED 1300 LM/80CRI 3000K 12W	USA1 LIGHTING (OR APPROVED OTHER)	B4RDF SERIES	TYPE :4.5" DIA. DOWNLIGHT MOUNTING :RECESSED HOUSING :ALUMINUM LENS/REFL :NA VOLTAGE :MVOLT BALLAST :LED DRIVER (0-10 DIMMING)	WHITE TRIM AT GYP. CEILINGS 50 DEGREE BEAM C1E = EMERGENCY BATTERY BACK UP UL LISTED DAMP LOCATION CLUBHOUSE
C2 C2E	LED 1300 LM/80CRI 3000K 12W	USA1 LIGHTING (OR APPROVED OTHER)	B4RDF30 SERIES	TYPE :4.5" DIA. DOWNLIGHT MOUNTING :RECESSED (SLOPED CLNG) HOUSING :ALUMINUM LENS/REFL :NA VOLTAGE :MVOLT BALLAST :LED DRIVER (0-10 DIMMING)	BLACK TRIM AT WOOD CEILINGS 70 DEGREE BEAM C2E = EMERGENCY BATTERY BACK UP UL LISTED DAMP LOCATION CLUBHOUSE
C3 C3E	LED 1075 LM/80CRI 3000K 9W	USA1 LIGHTING (OR APPROVED OTHER)	P4RDF SERIES	TYPE :EXTERIOR 4.5" DIA. DOWNLIGHT MOUNTING :RECESSED HOUSING :ALUMINUM LENS/REFL :ACRYLIC VOLTAGE :MVOLT BALLAST :LED DRIVER	TRIM & FINISH PER ARCHITECT/INTERIORS FLOOD BEAM C3E = EMERGENCY BATTERY BACK UP UL LISTED DAMP LOCATION CLUBHOUSE EXTERIOR CANOPY
DL1	LED 3000K 120W (EQUIVALENT)	MATTEO LIGHTING (OR APPROVED OTHER)	C49703BK SERIES	TYPE :DECORATIVE PENDANT MOUNTING :SUSPENDED HOUSING :STEEL LENS/REFL :GLASS VOLTAGE :MVOLT BALLAST :INTEGRAL (0-10 DIMMING)	BLACK FINISH PER DECORATOR MOUNTING HEIGHT TO BE 6'-6" AFF. CLUBHOUSE
DL2	LED 3000K 150W (EQUIVALENT)	HERMAN MILLER LIGHTING (OR APPROVED OTHER)	H761CCS SERIES	TYPE :DECORATIVE PENDANT MOUNTING :SUSPENDED HOUSING :STEEL LENS/REFL :GLASS VOLTAGE :MVOLT BALLAST :INTEGRAL (0-10 DIMMING)	BRUSHED NICKLE FINISH PER INTERIOR DECORATOR HEIGHT TO BE 6'-6" AFF. STUDY ROOM
DL3	LED 1150 LM 3000K 9W (EQUIVALENT)	USA1 LIGHTING (OR APPROVED OTHER)	LBRP6 SERIES	TYPE :CYLINDER LIGHT MOUNTING :SUSPENDED (CABLE HUNG) HOUSING :STEEL LENS/REFL :GLASS VOLTAGE :MVOLT BALLAST :LED DRIVER (0-10 DIMMING)	WHITE FINISH REFER TO INTERIOR ELEVATIONS FOR MOUNTING HEIGHT TO BE FIELD ADJUSTED CLUBHOUSE
DL4	LED 3000K 75W (EQUIVALENT)	CEDAR & MOSS LIGHTING TILT CONE SERIES (OR APPROVED OTHER)		TYPE :ADJUSTABLE WALL SCONCE MOUNTING :SURFACE HOUSING :STEEL LENS/REFL :GLASS VOLTAGE :MVOLT BALLAST :INTEGRAL (0-10 DIMMING)	MATTE BLACK FINISH REFER TO INTERIOR ELEVATIONS FOR MOUNTING HEIGHT. CLUBHOUSE
DL5	LED 3000K 120W (EQUIVALENT)	ANDREW NEYER LIGHTING (OR APPROVED OTHER)	DUMBBELL SERIES	TYPE :DECORATIVE PENDANT MOUNTING :SUSPENDED HOUSING :STEEL LENS/REFL :GLASS VOLTAGE :MVOLT BALLAST :INTEGRAL (0-10 DIMMING)	BLACK FINISH MOUNTING HEIGHT PER DECORATOR. CLUBHOUSE RESTROOM
x1	LED (GREEN LETTERS) DMF LIGHTING (OR APPROVED OTHER) (1.5W)	LITHONIA (OR APPROVED OTHER)	LE EL N SERIES DL5D500EM-G	TYPE :EXIT SIGN MOUNTING :UNIVERSAL HOUSING :DIE-CAST ALUMINUM LENS/REFL :SINGLE FACE/DUAL FACE VOLTAGE :MVOLT BALLAST :NICKLE CADMIUM BATTERY	

LIGHTING FIXTURE LIST - TYPICAL LIVING UNITS					
TYPE	LAMP	MANUFACTURER	CATALOG NUMBER	DESCRIPTION	OPTIONS
U1a	LED 650 LM 3000K 10W	LIGHTOLIER (OR APPROVED OTHER)	SSR SERIES	TYPE :5" DIA. DOWNLIGHT MOUNTING :SURFACE (4-BOX) HOUSING :ALUMINUM LENS/REFL :ACRYLIC VOLTAGE :MVOLT BALLAST :LED DRIVER (DIMMING)	WHITE FINISH UNIT KITCHEN, HALL, BATHROOM
U1b	LED 750 LM 3000K 10W	LITHONIA (OR APPROVED OTHER)	LK5G SERIES	TYPE :5" DIA. ADJUSTABLE DOWNLIGHT MOUNTING :RECESSED HOUSING :ALUMINUM LENS/REFL :ACRYLIC VOLTAGE :MVOLT BALLAST :LED DRIVER (DIMMING)	WHITE FINISH IC RATED UNIT KITCHEN (VAULTED CLNG ONLY)
U2	LED 1400 LUMEN 3000K 16W	MAXIM LIGHTING (OR APPROVED OTHER)	52102SN SERIES	TYPE :24" VANITY LIGHT MOUNTING :SURFACE (+6" ABOVE MIRROR) HOUSING :STEEL LENS/REFL :GLASS VOLTAGE :120V BALLAST :LED DRIVER	POLISHED CHROME FINISH UNIT BATHROOM
U3a A	LED 3000K 650LM 67W	MINKA AIRE (OR APPROVED OTHER)	F753L-WHF	TYPE :52" DIA CEILING FAN W/ LIGHT MOUNTING :SURFACE HOUSING :ALUMINUM LENS/REFL :ACRYLIC VOLTAGE :120V BALLAST :LED DRIVER (0-10 DIMMING)	WHITE FINISH PROVIDE BRACING AT CEILING TO SUPPORT A MINIMUM OF 35 LBS. PROVIDE WITH DUAL SWITCH CONTROLS
U3b	LED 3000K 650LM 67W	MINKA AIRE (OR APPROVED OTHER)	F753L-WHF	TYPE :52" DIA CEILING FAN W/ LIGHT MOUNTING :SURFACE (SLOPPED CEILING) HOUSING :ALUMINUM LENS/REFL :ACRYLIC VOLTAGE :120V BALLAST :LED DRIVER (0-10 DIMMING)	WHITE FINISH PROVIDE BRACING AT CEILING TO SUPPORT A MINIMUM OF 35 LBS. PROVIDE WITH DUAL SWITCH CONTROLS.
U4	LED 1400 LM 3000K 20W	KUZCO LIGHTING (OR APPROVED OTHER)	FM3511	TYPE :11" DIA CEILING LIGHT MOUNTING :SURFACE HOUSING :STEEL LENS/REFL :GLASS VOLTAGE :120V BALLAST :LED DRIVER (0-10 DIMMING)	CHROME/CLEAR FINISH UNIT DINING ROOM
U5	LED 800 LM 3000K 12W	KUZCO LIGHTING (OR APPROVED OTHER)	EW3105	TYPE :EXTERIOR WALL SCONCE MOUNTING :SURFACE HOUSING :STEEL LENS/REFL :GLASS VOLTAGE :120V BALLAST :LED DRIVER	BLACK FINISH UNIT ENTRY
U6	LED 3000K 200LM 5W	WAC LIGHTING (OR APPROVED OTHER)	HR-LED90 SERIES	TYPE :UNDER CABINET LIGHT MOUNTING :SURFACE HOUSING :ALUMINUM LENS/REFL :ACRYLIC VOLTAGE :24V BALLAST :LED DRIVER (ELV DIMMING)	WHITE FINISH UNIT KITCHEN


LIGHTING FIXTURE LIST - SITE					
TYPE	LAMP	MANUFACTURER	CATALOG NUMBER	DESCRIPTION	OPTIONS
S1	LED 3000K 2632 LM 41 W	LIGMAN LIGHTING (OR APPROVED OTHER)	UAA-20166 SERIES	TYPE :AREA LIGHT MOUNTING :ROUND POLE (16" AFG) HOUSING :STEEL LENS/REFL :OPAL GLASS/STRAIGHT SHADE VOLTAGE :MVOLT BALLAST :LED DRIVER	BLACK FINISH PARKING AREA
S2	LED 3000K 2420 LM 18W	LIGHTWAY LIGHTING DABMAR LIGHTING (OR APPROVED OTHER)	WWP-14LED SERIES GM260 SERIES	TYPE :POST TOP AREA LIGHT MOUNTING :ROUND POLE (8FT AFG) HOUSING :STEEL LENS/REFL :OPAL GLASS VOLTAGE :MVOLT BALLAST :LED DRIVER	BLACK FINISH WALKWAYS
S3	LED 3000K 1856 LM 29W	LIGMAN LIGHTING DABMAR LIGHTING (OR APPROVED OTHER)	UAA-30166 SERIES GM996 SERIES	TYPE :EXTERIOR WALL SCONCE MOUNTING :SURFACE (+8.5 FT AFF) HOUSING :STEEL LENS/REFL :OPAL GLASS/STRAIGHT SHADE VOLTAGE :MVOLT BALLAST :LED DRIVER	BLACK FINISH GARAGES
S4	LED 3000K 4800 LM 48W	SAYLITE LIGHTING	CV800 SERIES	TYPE :4FT ENCLOSED STRIP LIGHT MOUNTING :SURFACE HOUSING :STEEL LENS/REFL :ACRYLIC VOLTAGE :MVOLT BALLAST :LED DRIVER	VANDAL RESISTANT CARPORTS, SHELTERS
S5	LED 3000K 1200 LM 15W	KUZCO LIGHTING	EC44505 SERIES	TYPE :CEILING LIGHT MOUNTING :SURFACE HOUSING :STEEL LENS/REFL :ACRYLIC VOLTAGE :MVOLT BALLAST :LED DRIVER	FINISH PER ARCHITECT BUILDING PORCHES, LANDINGS
S6	LED 3000K 200 LM 2W	HADCO LIGHTING	DAL1 4121 SERIES	TYPE :DECK LIGHT MOUNTING :SURFACE HOUSING :STEEL LENS/REFL :ACRYLIC VOLTAGE :24V BALLAST :INTEGRAL LED DRIVER	FINISH PER ARCHITECT VERIFY MOUNTING HEIGHT PROVIDE WITH APPROPRIATE TRANSFORMERS AND OTHER HARDWARE BUILDING STAIRS
S7	LED 3000K 1454 LM 41W	LIGMAN LIGHTING	UAA-10086 SERIES	TYPE :42" BOLLARD LIGHT MOUNTING :SURFACE HOUSING :STEEL LENS/REFL :LOUVERED GLASS VOLTAGE :120V BALLAST :LED DRIVER	BLACK FINISH PROVIDE WITH ROUND TOP CLUBHOUSE TERRACE

GENERAL LIGHTING NOTES:

- ALL LIGHT FIXTURES SHALL HAVE ENERGY EFFICIENT LAMPING, DRIVERS AND BALLASTS.
- LIGHT FIXTURES FOR LIVING UNITS SHALL BE "ENERGY STAR" RATED.
- EXTERIOR LIGHT FIXTURES SHALL BE "NIGHT SKY" FRIENDLY.
- FOR FIXTURES THAT DO NOT HAVE FINISH SPECIFIED, CONSULT WITH ARCHITECT/INTERIORS PRIOR TO BID.
- CONSULT INTERIORS PLANS FOR FIXTURE MOUNTING HEIGHTS IN THE CLUBHOUSE AND THE ARCHITECTURAL PLANS FOR ALL OTHER FIXTURE MOUNTING HEIGHTS.
- CONSULT INTERIORS PLANS FOR EXACT FIXTURE LOCATIONS IN THE CLUBHOUSE AND THE ARCHITECTURAL PLANS FOR ALL OTHER FIXTURE LOCATIONS.
- ALL INTERIOR LIGHTING SHALL BE 3000 KELVIN UNLESS OTHERWISE NOTED.
- ALL EXTERIOR LIGHTING SHALL BE 3000 KELVIN UNLESS OTHERWISE NOTED.
- ALL PRODUCT SUBSTITUTIONS AND VALUE ENGINEERING SHALL BE SUBMITTED DURING BID PHASE, SHALL MEET DESIGN INTENT AND IS SUBJECT TO OWNER APPROVAL.
- CONTRACTOR SHALL CONSULT MANUFACTURER INSTALLATION INSTRUCTIONS FOR ALL FIXTURES AND DEVICES AND INSTALL AS INSTRUCTED. THIS INCLUDES ALL ELECTRICAL COMPONENTS REQUIRED FOR COMPLETE INSTALLATION. WORK SHALL BE PERFORMED SUCH THAT MANUFACTURER WARRANTY IS NOT VOIDED.
- IF NECESSARY, CONTRACTOR SHALL PROVIDE IC RATED BOXES FOR ANY APPROVED, SUBSTITUTED FIXTURES NOT MEETING INSULATED CEILING REQUIREMENTS.
- SITE LIGHTING AND BUILDING MOUNTED EXTERIOR LIGHTS (EXCEPT APARTMENT PATIO/BALCONY LIGHTS) SHALL BE CONTROLLED VIA PHOTOCELL, EITHER INTEGRAL OR REMOTE FOR DUST-TILL-DAWN OPERATION.
- POLE MOUNTED SITE LIGHTING AND CARPORT LIGHTING SHALL BE PROVIDED WITH THE ABILITY TO REDUCE LIGHT LEVELS BY 30% DURING PERIODS OF LOW NIGHT-TIME ACTIVITY, EITHER BY MOTION SENSING AND/OR TIME CLOCK.
- CONTRACTOR TO PROVIDE SINGLE POLE DIMMER SWITCHES AS INDICATED. DIMMER SWITCHES SHALL MATCH THE DECORATOR TYPE ROCKER SWITCH SPECIFIED IN THE TYPICAL UNIT LIGHTING PLANS OR AS DIRECTED BY THE OWNER. DIMMER SWITCHES SHALL BE COMPATIBLE WITH THE LED LIGHT FIXTURES AND SHALL BE FULLY ADJUSTABLE. CONTRACTOR SHALL FIELD ADJUST TO REDUCE ANY MOMENTARY FLASH DURING START UP.
- PROVIDE BLOCKING AT CEILING TO SUPPORT 35LB., MINIMUM, FOR CEILING FAN INSTALLATION. REFER TO MANUFACTURER'S INSTALLATION INSTRUCTIONS FOR ADDITIONAL INFORMATION AND REQUIREMENTS. PROVIDE FIXTURE CONTROL SWITCH(ES) AS DIRECTED BY MANUFACTURER.
- FOR ANY FIXTURE THAT WOULD REQUIRE RELOCATION DUE TO FIELD CONDITIONS WILL REQUIRE OWNER/ENGINEER WALK-THRU FOR APPROVAL.




BATHROOM W/ EXHAUST FAN
SWITCHED WITH CEILING &
VANITY LIGHTS




BATHROOM W/ VANITY LIGHT SWITCHED
SEPARATE FROM CEILING LIGHTS &
CONTINUOUS OPERATION EXHAUST FAN
ON (30 MIN. MINIMUM) TIMER.

1 BATHROOM SWITCHING DIAGRAMS - TYPICAL E1.21 NO SCALE



2 TYPICAL POLE BASE DETAIL E1.21 NO SCALE



3 EMERGENCY EGRESS LIGHTING - UNSWITCHED E1.21 NO SCALE




Figure 308.2.1
Unobstructed Forward Reach




Figure 308.2.2
Obstructed High Forward Reach





Figure 308.3.2
Obstructed High Side Reach

1 ADA REACH REQUIREMENTS E1.22 NO SCALE

- 308.2 Forward Reach.**
- 308.2.1 Unobstructed.** Where a forward reach is unobstructed, the high forward reach shall be 48" maximum and the low forward reach shall be 15" minimum above the floor or ground.
- 308.2.2 Obstructed High Reach.** Where a high forward reach is over an obstruction, the clear floor or ground space shall extend beneath the element for a distance not less than the required reach depth over the obstruction. The high forward reach shall be 48" maximum where the reach depth is 20" maximum. Where the reach depth exceeds 20", the high forward reach shall be 44" maximum and the reach depth shall be 25" maximum.
- 308.3 Side Reach.**
- 308.3.1 Unobstructed.** Where a clear floor or ground space allows a parallel approach to an object and the side reach is unobstructed, the high side reach shall be 48" maximum and the low side reach shall be 15" minimum above the floor or ground.
- Exception:** Existing elements shall be permitted at 54" maximum above the floor or ground.
- 308.3.2 Obstructed High Reach.** Where a clear floor or ground space allows a parallel approach to an object and the high side reach is over an obstruction, the height of the obstruction shall be 34" maximum and the depth of the obstruction shall be 24" maximum. The high side reach shall be 48" maximum for a reach depth of 10" maximum. Where the reach depth exceeds 10", the high side reach shall be 46" maximum for a reach depth of 24" maximum.



IN THE EVENT CONFLICTS ARE DISCOVERED BETWEEN THE ORIGINAL SIGNED AND SEALED DOCUMENTS PREPARED BY THE ARCHITECTS AND/OR THEIR CONSULTANTS AND ANY COPY OF THE DOCUMENTS TRANSMITTED BY MAIL, FAX, ELECTRONICALLY OR OTHERWISE, THE ORIGINAL SIGNED AND SEALED DOCUMENTS SHALL GOVERN.

PROJECT # 2019-179

DATE: 28 AUGUST 2020


REVISIONS

△ PLAN REVIEW 11.03.2020
 △ PLAN REVIEW 03.19.2021
 △ PLAN REVIEW 05.10.2021
 △ OWNER CHANGES 06.20.2021
 △ UTILITY COORD. 08.19.2021

MCKINNEY LANE APARTMENTS PHASE II
 RUSSELL DRIVE & MCKINNEY LANE
 LEBANON, OREGON

A

E2.01




GENERAL LIGHTING NOTES:

- ELECTRICAL DRAWINGS ARE DIAGRAMMATICAL AND MAY NOT ACCURATELY REFLECT ACTUAL CONSTRUCTION CONDITIONS. THE ELECTRICAL CONTRACTOR SHALL BE RESPONSIBLE FOR COORDINATING THE INSTALLATION OF ALL ELECTRICAL EQUIPMENT, WITH ALL TRADES PRIOR TO AND DURING CONSTRUCTION.
- ALL DISCREPANCIES SHALL BE BROUGHT TO THE ATTENTION OF THE ARCHITECT IMMEDIATELY UPON DISCOVERY.
- REFER TO SHEET E1.21 FOR LIGHT FIXTURE SCHEDULES.
- THE ELECTRICAL CONTRACTOR SHALL REFER TO THE ARCHITECTURAL AND/OR INTERIORS PLAN SETS FOR DIMENSIONED LOCATIONS, MOUNTING HEIGHTS AND FINISHES OF DEVICES AND FIXTURES.
- REFER TO AVAILABLE ARCHITECTURAL AND/OR INTERIOR DESIGN DOCUMENTS & DRAWINGS FOR ADDITIONAL INFORMATION.
- EXTERIOR LIGHTING TO BE CONSTANT "ON" AND PROVIDED WITH PHOTOCELL, EITHER INTEGRAL OR REMOTE) FOR DUSK-TILL-DAWN OPERATION.
- ALL EXTERIOR BUILDING LIGHTS ON HOUSE POWER SHALL BE CONSIDERED EGRESS LIGHTING. FIXTURES ARE TO BE EQUIPPED WITH BATTERY BACK-UP (EITHER INTEGRAL OR REMOTE).
- REFER TO SHEET E1.14 FOR TYPICAL UNIT LOAD CENTER DIRECTORIES.
- ALL LIGHT SWITCHES SHALL BE ROCKER STYLE, SUCH AS LEVITON DECORA, OR APPROVED EQUAL.
- REFER TO ARCHITECTURAL REFLECTED CEILING PLANS FOR EXACT FIXTURE LOCATIONS (DIMENSIONS). CONSULT INTERIOR DESIGNER FOR MOUNTING HEIGHTS NOT SPECIFIED.
- REFER TO ARCHITECTURAL PLANS REGARDING "ACCESSIBLE" UNIT LOCATION(S), INTERIOR ELEVATIONS & DETAILS. COORDINATE INSTALLATION OF ALL DEVICES PER THE "AMERICAN DISABILITIES ACT" (ADA). REFER TO SHEET E1.21 FOR STANDARD ADA REACH REQUIREMENTS.
- CEILING HEATERS SHALL BE PROVIDED AND INSTALLED BY THE ELECTRICAL CONTRACTOR. INSTALLATION TO INCLUDE WIRING AND DEVICES FOR REMOTE THERMOSTATS. CONSULT ARCHITECTURAL PLANS FOR EXACT LOCATIONS. REFER TO E1.11 FOR MORE INFORMATION REGARDING THE WALL HEATERS.

KEYED LIGHTING NOTES:

- REFER TO TYPICAL BATHROOM SWITCHING DETAILS ON SHEET E1.21.
- PROVIDE CEILING FAN CONTROL SWITCH(ES) AS DIRECTED BY MANUFACTURER.
- PROVIDE BLOCKING AT CEILING TO SUPPORT 35LB., MINIMUM, FOR CEILING FAN INSTALLATION.
- PROVIDE WIRE CONNECTION FOR THERMOSTAT(S). COORDINATE WITH ARCHITECT FOR EXACT LOCATION PRIOR TO ROUGH IN. REFER TO ARCHITECTURAL INTERIOR ELEVATIONS FOR DIMENSIONED LOCATIONS OF THERMOSTATS. REFER TO SHEET E1.11 FOR MORE INFORMATION REGARDING WALL HEATERS & T-STATS.
- COORDINATE LOCATION OF POWER CONNECTION FOR FIRE ALARM DEVICES WITH THE SYSTEM CONTRACTOR/INSTALLER.
- TO SWITCHED RECEPTACLE. REFER TO POWER PLANS (E3 SERIES SHEETS) FOR OUTLET LOCATION.



IN THE EVENT CONFLICTS ARE DISCOVERED BETWEEN THE ORIGINAL SIGNED AND SEALED DOCUMENTS PREPARED BY THE ARCHITECTS AND/OR THEIR CONSULTANTS AND ANY COPY OF THE DOCUMENTS TRANSMITTED BY MAIL, FAX, ELECTRONICALLY OR OTHERWISE, THE ORIGINAL SIGNED AND SEALED DOCUMENTS SHALL GOVERN.

PROJECT # 2019-179

DATE: 28 AUGUST 2020


REVISIONS


△ PLAN REVIEW 11.03.2020
 △ PLAN REVIEW 03.19.2021
 △ PLAN REVIEW 05.10.2021
 △ OWNER CHANGES 06.20.2021
 △ UTILITY COORD. 08.19.2021

MCKINNEY LANE APARTMENTS PHASE II
RUSSELL DRIVE & MCKINNEY LANE
 L E B A N O N , O R E G O N

A

E2.02





IN THE EVENT CONFLICTS ARE DISCOVERED BETWEEN THE ORIGINAL SIGNED AND SEALED DOCUMENTS PREPARED BY THE ARCHITECTS AND/OR THEIR CONSULTANTS, ANY COPY OF THE DOCUMENTS TRANSMITTED BY MAIL, MAIL ELECTRONICALLY OR OTHERWISE, THE ORIGINAL SIGNED AND SEALED DOCUMENTS SHALL GOVERN.

PROJECT # 2019-179
DATE: 28 AUGUST 2020


REVISIONS

△ PLAN REVIEW 11.03.2020
△ PLAN REVIEW 03.19.2021
△ PLAN REVIEW 05.10.2021
△ OWNER CHANGES 06.20.2021
△ UTILITY COORD. 08.19.2021

McKINNEY LANE APARTMENTS PHASE II
RUSSELL DRIVE & MCKINNEY LANE
LEBANON, OREGON 97331

A

E3.01




GENERAL POWER NOTES:

- A. ALL PLANS ARE CONSIDERED DIAGRAMMATICAL. THEREFORE ALL EQUIPMENT SIZES AND DEVICE LOCATIONS ARE APPROXIMATE AND SUBJECT TO FIELD CONDITIONS AND PRODUCT APPROVAL.
- B. NOT USED.
- C. ELECTRICAL CONTRACTOR SHALL PROVIDE INSTALLATION AND FINAL CONNECTION OF THERMOSTATS. CONSULT MECHANICAL CONTRACTOR FOR EXACT REQUIREMENTS PRIOR TO ROUGH IN.
- D. REFER TO INTERIOR DECORATOR AND/OR ARCHITECTURAL DRAWINGS FOR DIMENSIONED LOCATION(S) AND ELEVATIONS OF FIXTURES & DEVICES. OTHER DEVICES SHOWN ON THE ELECTRICAL PLANS AND NOT INDICATED ON THE DECORATOR'S OR ARCHITECT'S DRAWINGS, SHALL BE INSTALLED AT STANDARD MOUNTING HEIGHT AS INDICATED THE SYMBOL LIST.
- E. BUILDING ELECTRICAL EQUIPMENT SHOWN IS APPROXIMATE, BASED ON INDUSTRY STANDARD PRODUCTS. CONTRACTOR SHALL VERIFY ANY SUBMITTED EQUIPMENT WILL FIT WITHIN THE SPACE PROVIDED, PRIOR TO PRODUCT SUBMITTAL REVIEW.
- F. ELECTRICAL CONTRACTOR SHALL COORDINATE WITH THE LOW VOLTAGE ('T' SERIES) PLANS, INCLUDING FIRE ALARM AND SYSTEMS INSTALLER, AND PROVIDE ROUGH IN AS NEEDED.
- G. REFER TO ARCHITECTURAL PLANS REGARDING "ACCESSIBLE" UNIT LOCATION(S), INTERIOR ELEVATIONS & DETAILS. COORDINATE INSTALLATION OF ALL DEVICES PER THE "AMERICAN DISABILITIES ACT" (ADA). REFER TO SHEET E1.21 FOR STANDARD ADA REACH REQUIREMENTS.
- H. WALL HEATERS SHALL BE PROVIDED AND INSTALLED BY THE ELECTRICAL CONTRACTOR. INSTALLATION TO INCLUDE WIRING AND DEVICES FOR REMOTE THERMOSTATS. CONSULT ARCHITECTURAL PLANS FOR EXACT LOCATIONS. REFER TO E1.11 FOR MORE INFORMATION REGARDING THE WALL HEATERS.

KEYED POWER NOTES:

1. PROVIDE WIRE CONNECTION FOR THERMOSTAT(S). COORDINATE WITH ARCHITECT FOR EXACT LOCATION PRIOR TO ROUGH IN. REFER TO ARCHITECTURAL INTERIOR ELEVATIONS FOR DIMENSIONED LOCATIONS OF THERMOSTATS. REFER TO SHEET E1.11 FOR MORE INFORMATION REGARDING WALL HEATERS & T-STATS.
2. PROVIDE ONE 20A, 120V, 1P GFCI DUPLEX RECEPTACLE UNDER KITCHEN SINK FOR DISPOSAL POWER CONNECTION.
3. REFER TO DETAIL 1/E1.13 FOR TYPICAL LAUNDRY ALCOVE RECEPTACLE LOCATIONS. COORDINATE INSTALLATION WITH MECHANICAL & PLUMBING CONTRACTOR.
4. PROVIDE ONE 15A, RECEPTACLE CIRCUIT FROM TENANT LOAD CENTER FOR TELECOM SMART PANEL. COORDINATE WORK WITH SERVICE PROVIDER FOR EXACT LOCATION AND FINAL CONNECTION.
5. CONTRACTOR TO VERIFY POWER CONNECTION TYPE FOR THE HOOD/MICROWAVE PRIOR TO ROUGH IN. PROVIDE ONE DEDICATED 20A, 1P DUPLEX RECEPTACLE LOCATED INSIDE THE CABINET OVER THE RANGE FOR APPLIANCES SUPPLIED WITH CORD & PLUG SET. HOOD/MICROWAVES THAT ARE TO BE HARDWIRED, SHALL BE PROVIDED WITH THE DEDICATED CIRCUIT GOING TO A J-BOX WHICH IS TO BE MOUNTED DIRECTLY BEHIND THE APPLIANCE.
6. METER LOCATION PER UTILITY PROVIDER'S APPROVAL (PENDING). REFER TO ONE-LINE DIAGRAM ON SHEET E1.11. PROVIDE NEMA 3R LOCKING CABINET FOR HOUSE PANEL "HP". REFER TO SHEET E1.01 FOR METER & PANEL LOCATION(S) AT EACH BUILDING.
7. 15A SWITCHED SPLIT DUPLEX RECEPTACLE. REFER TO LIGHTING PLANS (E2 SERIES SHEETS) FOR SWITCH LOCATION.

PROVIDE WIRE CONNECTION FOR THERMOSTAT(S) PROVIDED BY MECHANICAL INSTALLER. COORDINATE WITH MECHANICAL INSTALLER FOR EXACT LOCATION AND POWER REQUIREMENTS PRIOR TO ROUGH IN. CEILING HEATER (BY MECHANICAL) TO BE TIED INTO BATHROOM POWER CIRCUIT. REFER TO ARCHITECTURAL INTERIOR ELEVATIONS FOR DIMENSIONED LOCATIONS OF BATHROOM THERMOSTATS.



BLDG 'A'
SECOND FLOOR - POWER PLAN
SCALE: 1/4" = 1'-0"

1.


GENERAL POWER NOTES:

- ALL PLANS ARE CONSIDERED DIAGRAMMATICAL. THEREFORE ALL EQUIPMENT SIZES AND DEVICE LOCATIONS ARE APPROXIMATE AND SUBJECT TO FIELD CONDITIONS AND PRODUCT APPROVAL.
- NOT USED.
- ELECTRICAL CONTRACTOR SHALL PROVIDE INSTALLATION AND FINAL CONNECTION OF THERMOSTATS. CONSULT MECHANICAL CONTRACTOR FOR EXACT REQUIREMENTS PRIOR TO ROUGH IN.
- REFER TO INTERIOR DECORATOR AND/OR ARCHITECTURAL DRAWINGS FOR DIMENSIONED LOCATION(S) AND ELEVATIONS OF FIXTURES & DEVICES. OTHER DEVICES SHOWN ON THE ELECTRICAL PLANS AND NOT INDICATED ON THE DECORATOR'S OR ARCHITECT'S DRAWINGS, SHALL BE INSTALLED AT STANDARD MOUNTING HEIGHT AS INDICATED THE SYMBOL LIST.
- BUILDING ELECTRICAL EQUIPMENT SHOWN IS APPROXIMATE, BASED ON INDUSTRY STANDARD PRODUCTS. CONTRACTOR SHALL VERIFY ANY SUBMITTED EQUIPMENT WILL FIT WITHIN THE SPACE PROVIDED, PRIOR TO PRODUCT SUBMITTAL REVIEW.
- ELECTRICAL CONTRACTOR SHALL COORDINATE WITH THE LOW VOLTAGE ("T" SERIES) PLANS, INCLUDING FIRE ALARM AND SYSTEMS INSTALLER, AND PROVIDE ROUGH IN AS NEEDED.
- REFER TO ARCHITECTURAL PLANS REGARDING "ACCESSIBLE" UNIT LOCATION(S), INTERIOR ELEVATIONS & DETAILS. COORDINATE INSTALLATION OF ALL DEVICES PER THE "AMERICAN DISABILITIES ACT" (ADA). REFER TO SHEET E1.21 FOR STANDARD ADA REACH REQUIREMENTS.
- WALL HEATERS SHALL BE PROVIDED AND INSTALLED BY THE ELECTRICAL CONTRACTOR. INSTALLATION TO INCLUDE WIRING AND DEVICES FOR REMOTE THERMOSTATS. CONSULT ARCHITECTURAL PLANS FOR EXACT LOCATIONS. REFER TO E1.11 FOR MORE INFORMATION REGARDING THE WALL HEATERS.

KEYED POWER NOTES:

- PROVIDE WIRE CONNECTION FOR THERMOSTAT(S). COORDINATE WITH ARCHITECT FOR EXACT LOCATION PRIOR TO ROUGH IN. REFER TO ARCHITECTURAL INTERIOR ELEVATIONS FOR DIMENSIONED LOCATIONS OF THERMOSTATS. REFER TO SHEET E1.11 FOR MORE INFORMATION REGARDING WALL HEATERS & T-STATS.
- PROVIDE ONE 20A, 120V, 1P GFCI DUPLEX RECEPTACLE UNDER KITCHEN SINK FOR DISPOSAL POWER CONNECTION.
- REFER TO DETAIL 1/E1.13 FOR TYPICAL LAUNDRY ALCOVE RECEPTACLE LOCATIONS. COORDINATE INSTALLATION WITH MECHANICAL & PLUMBING CONTRACTOR.
- PROVIDE ONE 15A, RECEPTACLE CIRCUIT FROM TENANT LOAD CENTER FOR TELECOM SMART PANEL. COORDINATE WORK WITH SERVICE PROVIDER FOR EXACT LOCATION AND FINAL CONNECTION.
- CONTRACTOR TO VERIFY POWER CONNECTION TYPE FOR THE HOOD/MICROWAVE PRIOR TO ROUGH IN. PROVIDE ONE DEDICATED 20A, 1P DUPLEX RECEPTACLE LOCATED INSIDE THE CABINET OVER THE RANGE FOR APPLIANCES SUPPLIED WITH CORD & PLUG SET. HOOD/MICROWAVES THAT ARE TO BE HARDWIRED, SHALL BE PROVIDED WITH THE DEDICATED CIRCUIT GOING TO A J-BOX WHICH IS TO BE MOUNTED DIRECTLY BEHIND THE APPLIANCE.
- METER LOCATION PER UTILITY PROVIDER'S APPROVAL (PENDING). REFER TO ONE-LINE DIAGRAM ON SHEET E1.11. PROVIDE NEMA 3R LOCKING CABINET FOR HOUSE PANEL 'HP'. REFER TO SHEET E1.01 FOR METER & PANEL LOCATION(S) AT EACH BUILDING.
- 15A SWITCHED SPLIT DUPLEX RECEPTACLE. REFER TO LIGHTING PLANS (E2 SERIES SHEETS) FOR SWITCH LOCATION.

PROVIDE WIRE CONNECTION FOR THERMOSTAT(S) PROVIDED BY MECHANICAL INSTALLER. COORDINATE WITH MECHANICAL INSTALLER FOR EXACT LOCATION AND POWER REQUIREMENTS PRIOR TO ROUGH IN. CEILING HEATER (BY MECHANICAL) TO BE TIED INTO BATHROOM POWER CIRCUIT. REFER TO ARCHITECTURAL INTERIOR ELEVATIONS FOR DIMENSIONED LOCATIONS OF BATHROOM THERMOSTATS.




- GENERAL LIGHTING NOTES:
- A. ELECTRICAL DRAWINGS ARE DIAGRAMMATICAL AND MAY NOT ACCURATELY REFLECT ACTUAL CONSTRUCTION CONDITIONS. THE ELECTRICAL CONTRACTOR SHALL BE RESPONSIBLE FOR COORDINATING THE INSTALLATION OF ALL ELECTRICAL EQUIPMENT, WITH ALL TRADES PRIOR TO AND DURING CONSTRUCTION.
 - △ B. ALL DISCREPANCIES SHALL BE BROUGHT TO THE ATTENTION OF THE ARCHITECT IMMEDIATELY UPON DISCOVERY.
 - C. REFER TO SHEET E1.21 FOR LIGHT FIXTURE SCHEDULES.
 - △ D. THE ELECTRICAL CONTRACTOR SHALL REFER TO THE ARCHITECTURAL AND/OR INTERIORS PLAN SETS FOR DIMENSIONED LOCATIONS, MOUNTING HEIGHTS AND FINISHES OF DEVICES AND FIXTURES.
 - E. REFER TO AVAILABLE ARCHITECTURAL AND/OR INTERIOR DESIGN DOCUMENTS & DRAWINGS FOR ADDITIONAL INFORMATION.
 - F. EXTERIOR LIGHTING TO BE CONSTANT "ON" AND PROVIDED WITH PHOTOCELL, EITHER INTEGRAL OR REMOTE) FOR DUSK-TILL-DAWN OPERATION.
 - G. ALL EXTERIOR BUILDING LIGHTS ON HOUSE POWER SHALL BE CONSIDERED EGRESS LIGHTING. FIXTURES ARE TO BE EQUIPPED WITH BATTERY BACK-UP (EITHER INTEGRAL OR REMOTE).
 - H. REFER TO SHEET E1.14 FOR TYPICAL UNIT LOAD CENTER DIRECTORIES.
 - I. ALL LIGHT SWITCHES SHALL BE ROCKER STYLE, SUCH AS LEVITON DECORA, OR APPROVED EQUAL.
 - J. REFER TO ARCHITECTURAL REFLECTED CEILING PLANS FOR EXACT FIXTURE LOCATIONS (DIMENSIONS). CONSULT INTERIOR DESIGNER FOR MOUNTING HEIGHTS NOT SPECIFIED.
 - △ K. CEILING HEATERS SHALL BE PROVIDED AND INSTALLED BY THE ELECTRICAL CONTRACTOR. INSTALLATION TO INCLUDE WIRING AND DEVICES FOR REMOTE THERMOSTATS. CONSULT ARCHITECTURAL PLANS FOR EXACT LOCATIONS. REFER TO E1.11 FOR MORE INFORMATION REGARDING THE WALL HEATERS.

- KEYED LIGHTING NOTES:
- 1. REFER TO TYPICAL BATHROOM SWITCHING DETAILS ON SHEET E1.21.
 - 2. PROVIDE CEILING FAN CONTROL SWITCH(ES) AS DIRECTED BY MANUFACTURER.
 - 3. PROVIDE BLOCKING AT CEILING TO SUPPORT 35LB., MINIMUM, FOR CEILING FAN INSTALLATION.
 - △ 4. PROVIDE WIRE CONNECTION FOR THERMOSTAT(S). COORDINATE WITH ARCHITECT FOR EXACT LOCATION PRIOR TO ROUGH IN. REFER TO ARCHITECTURAL INTERIOR ELEVATIONS FOR DIMENSIONED LOCATIONS OF THERMOSTATS. REFER TO SHEET E1.11 FOR MORE INFORMATION REGARDING WALL HEATERS & T-STATS.
 - 5. COORDINATE LOCATION OF POWER CONNECTION FOR FIRE ALARM DEVICES WITH THE SYSTEM CONTRACTOR/INSTALLER.
 - 6. TO SWITCHED RECEPTACLE. REFER TO POWER PLANS (E3 SERIES SHEETS) FOR OUTLET LOCATION.



- A. ELECTRICAL DRAWINGS ARE DIAGRAMMATIC AND MAY NOT ACCURATELY REFLECT ACTUAL CONSTRUCTION CONDITIONS. THE ELECTRICAL CONTRACTOR SHALL BE RESPONSIBLE FOR COORDINATING THE INSTALLATION OF ALL ELECTRICAL EQUIPMENT, WITH ALL TRADES PRIOR TO AND DURING CONSTRUCTION.
-  B. ALL DISCREPANCIES SHALL BE BROUGHT TO THE ATTENTION OF THE ARCHITECT IMMEDIATELY UPON DISCOVERY.
- C. REFER TO SHEET E1.21 FOR LIGHT FIXTURE SCHEDULES.
-  D. THE ELECTRICAL CONTRACTOR SHALL REFER TO THE ARCHITECTURAL AND/OR INTERIORS PLAN SETS FOR DIMENSIONED LOCATIONS, MOUNTING HEIGHTS AND FINISHES OF DEVICES AND FIXTURES.
- E. REFER TO AVAILABLE ARCHITECTURAL AND/OR INTERIOR DESIGN DOCUMENTS & DRAWINGS FOR ADDITIONAL INFORMATION.
- F. EXTERIOR LIGHTING TO BE CONSTANT "ON" AND PROVIDED WITH PHOTOCELL, EITHER INTEGRAL OR REMOTE) FOR DUSK-TILL-DAWN OPERATION.
- G. ALL EXTERIOR BUILDING LIGHTS ON HOUSE POWER SHALL BE CONSIDERED EGRESS LIGHTING. FIXTURES ARE TO BE EQUIPPED WITH BATTERY BACK-UP (EITHER INTEGRAL OR REMOTE).
- H. REFER TO SHEET E1.14 FOR TYPICAL UNIT LOAD CENTER DIRECTORIES.
- I. ALL LIGHT SWITCHES SHALL BE ROCKER STYLE, SUCH AS LEVITON DECORA, OR APPROVED EQUAL.
- J. REFER TO ARCHITECTURAL REFLECTED CEILING PLANS FOR EXACT FIXTURE LOCATIONS (DIMENSIONS). CONSULT INTERIOR DESIGNER FOR MOUNTING HEIGHTS NOT SPECIFIED.
-  K. CEILING HEAVERS SHALL BE PROVIDED AND INSTALLED BY THE ELECTRICAL CONTRACTOR. INSTALLATION TO INCLUDE WIRING AND CONNECTIONS TO REMOTE THERMOSTATS. CONSULT ARCHITECTURAL PLANS FOR EXACT LOCATION. REFER TO E1.11 FOR MORE INFORMATION REGARDING THE WALL HEAVERS.

1. REFER TO TYPICAL BATHROOM SWITCHING DETAILS ON SHEET E1.21.
2. PROVIDE CEILING FAN CONTROL SWITCH(E)S AS DIRECTED BY MANUFACTURER.
3. PROVIDE BLOCKING AT CEILING TO SUPPORT 35LB., MINIMUM, FOR CEILING FAN INSTALLATION.
4. PROVIDE WIRE CONNECTION FOR THERMOSTAT(S). COORDINATE WITH ARCHITECT FOR EXACT LOCATION PRIOR TO RUGH IN. REFER TO ARCHITECTURAL INTERIOR ELEVATIONS FOR DIMENSIONED LOCATION OF THERMOSTATS. REFER TO SHEET E1.11 FOR MORE INFORMATION REGARDING WALL HEATERS & T-SITS.
5. COORDINATE LOCATION OF POWER CONNECTION FOR FIRE ALARM DEVICES WITH THE SYSTEM CONTRACTOR/INSTALLER.
6. TO SWITCHED RECEPTACLE. REFER TO POWER PLANS (E3 SERIES SHEETS) FOR OUTLET LOCATION.




GENERAL POWER NOTES:

- A. ALL PLANS ARE CONSIDERED DIAGRAMMATICAL. THEREFORE ALL EQUIPMENT SIZES AND DEVICE LOCATIONS ARE APPROXIMATE AND SUBJECT TO FIELD CONDITIONS AND PRODUCT APPROVAL.
- △ B. NOT USED.
- C. ELECTRICAL CONTRACTOR SHALL PROVIDE INSTALLATION AND FINAL CONNECTION OF THERMOSTATS. CONSULT MECHANICAL CONTRACTOR FOR EXACT REQUIREMENTS PRIOR TO ROUGH IN.
- D. REFER TO INTERIOR DECORATOR AND/OR ARCHITECTURAL DRAWINGS FOR DIMENSIONED LOCATION(S) AND ELEVATIONS OF FIXTURES & DEVICES. OTHER DEVICES SHOWN ON THE ELECTRICAL PLANS AND NOT INDICATED ON THE DECORATOR'S OR ARCHITECT'S DRAWINGS, SHALL BE INSTALLED AT STANDARD MOUNTING HEIGHT AS INDICATED THE SYMBOL LIST.
- E. BUILDING ELECTRICAL EQUIPMENT SHOWN IS APPROXIMATE, BASED ON INDUSTRY STANDARD PRODUCTS. CONTRACTOR SHALL VERIFY ANY SUBMITTED EQUIPMENT WILL FIT WITHIN THE SPACE PROVIDED, PRIOR TO PRODUCT SUBMITTAL REVIEW.
- F. ELECTRICAL CONTRACTOR SHALL COORDINATE WITH THE LOW VOLTAGE ("T" SERIES) PLANS, INCLUDING FIRE ALARM AND SYSTEMS INSTALLER, AND PROVIDE ROUGH IN AS NEEDED.
- △ G. WALL HEATERS SHALL BE PROVIDED AND INSTALLED BY THE ELECTRICAL CONTRACTOR. INSTALLATION TO INCLUDE WIRING AND DEVICES FOR REMOTE THERMOSTATS. CONSULT ARCHITECTURAL PLANS FOR EXACT LOCATIONS. REFER TO E1.11 FOR MORE INFORMATION REGARDING THE WALL HEATERS.

KEYED POWER NOTES:

- △△ 1. PROVIDE WIRE CONNECTION FOR THERMOSTAT(S). COORDINATE WITH ARCHITECT FOR EXACT LOCATION PRIOR TO ROUGH IN. REFER TO ARCHITECTURAL INTERIOR ELEVATIONS FOR DIMENSIONED LOCATIONS OF THERMOSTATS. REFER TO SHEET E1.11 FOR MORE INFORMATION REGARDING WALL HEATERS & T-STATS.
2. *PROVIDE ONE 20A, 120V, 1P GFCI DUPLEX RECEPTACLE UNDER KITCHEN SINK FOR DISPOSAL POWER CONNECTION.
3. REFER TO DETAIL 1/E1.13 FOR TYPICAL LAUNDRY ALCOVE RECEPTACLE LOCATIONS. COORDINATE INSTALLATION WITH MECHANICAL & PLUMBING CONTRACTOR.
4. PROVIDE ONE 15A RECEPTACLE CIRCUIT FROM TENANT LOAD CENTER FOR TELECOM SMART PANEL. COORDINATE WORK WITH SERVICE PROVIDER FOR EXACT LOCATION AND FINAL CONNECTION.
5. CONTRACTOR TO VERIFY POWER CONNECTION TYPE FOR THE HOOD/MICROWAVE PRIOR TO ROUGH IN. PROVIDE ONE DEDICATED 20A, 1P DUPLEX RECEPTACLE LOCATED INSIDE THE CABINET OVER THE RANGE FOR APPLIANCES SUPPLIED WITH CORD & PLUG SET. HOOD/MICROWAVES THAT ARE TO BE HARDWIRED, SHALL BE PROVIDED WITH THE DEDICATED CIRCUIT GOING TO A J-BOX WHICH IS TO BE MOUNTED DIRECTLY BEHIND THE APPLIANCE.
6. METER LOCATION PER UTILITY PROVIDER'S APPROVAL (PENDING). REFER TO ONE-LINE DIAGRAM ON SHEET E1.11. PROVIDE NEMA 3R LOCKING CABINET FOR HOUSE PANEL 'HP'. REFER TO SHEET E1.01 FOR METER & PANEL LOCATION(S) AT EACH BUILDING.
7. 15A SWITCHED SPLIT DUPLEX RECEPTACLE. REFER TO LIGHTING PLANS (E2 SERIES SHEETS) FOR SWITCH LOCATION.




BLDG "B"
SECOND FLOOR - POWER PLAN
SCALE: 1/4" = 1'-0"

GENERAL POWER NOTES:

- ALL PLANS ARE CONSIDERED DIAGMATICAL. THEREFORE ALL EQUIPMENT SIZES AND DEVICE LOCATIONS ARE APPROXIMATE AND SUBJECT TO FIELD CONDITIONS AND PRODUCT APPROVAL.
- NOT USED.
- ELECTRICAL CONTRACTOR SHALL PROVIDE INSTALLATION AND FINAL CONNECTION OF THERMOSTATS. CONSULT MECHANICAL CONTRACTOR FOR EXACT REQUIREMENTS PRIOR TO ROUGH IN.
- REFER TO INTERIOR DECORATOR AND/OR ARCHITECTURAL DRAWINGS FOR DIMENSIONED LOCATION(S) AND ELEVATIONS OF FIXTURES & DEVICES. OTHER DEVICES SHOWN ON THE ELECTRICAL PLANS AND NOT INDICATED ON THE DECORATOR'S OR ARCHITECT'S DRAWINGS, SHALL BE INSTALLED AT STANDARD MOUNTING HEIGHT AS INDICATED THE SYMBOL LIST.
- BUILDING ELECTRICAL EQUIPMENT SHOWN IS APPROXIMATE, BASED ON INDUSTRY STANDARD PRODUCTS. CONTRACTOR SHALL VERIFY ANY SUBMITTED EQUIPMENT WILL FIT WITHIN THE SPACE PROVIDED, PRIOR TO PRODUCT SUBMITTAL REVIEW.
- ELECTRICAL CONTRACTOR SHALL COORDINATE WITH THE LOW VOLTAGE ("T" SERIES) PLANS, INCLUDING FIRE ALARM AND SYSTEMS INSTALLER, AND PROVIDE ROUGH IN AS NEEDED.
- WALL HEATERS SHALL BE PROVIDED AND INSTALLED BY THE ELECTRICAL CONTRACTOR. INSTALLATION TO INCLUDE WIRING AND DEVICES FOR REMOTE THERMOSTATS. CONSULT ARCHITECTURAL PLANS FOR EXACT LOCATIONS. REFER TO E1.11 FOR MORE INFORMATION REGARDING THE WALL HEATERS.

KEYED POWER NOTES:

- PROVIDE WIRE CONNECTION FOR THERMOSTAT(S). COORDINATE WITH ARCHITECT FOR EXACT LOCATION PRIOR TO ROUGH IN. REFER TO ARCHITECTURAL INTERIOR ELEVATIONS FOR DIMENSIONED LOCATIONS OF THERMOSTATS. REFER TO SHEET E1.11 FOR MORE INFORMATION REGARDING WALL HEATERS & T-STATS.
- PROVIDE ONE 20A, 120V, 1P GFCI DUPLEX RECEPTACLE UNDER KITCHEN SINK FOR DISPOSAL POWER CONNECTION.
- REFER TO DETAIL 1/E1.13 FOR TYPICAL LAUNDRY ALCOVE RECEPTACLE LOCATIONS. COORDINATE INSTALLATION WITH MECHANICAL & PLUMBING CONTRACTOR.
- PROVIDE ONE 15A RECEPTACLE CIRCUIT FROM TENANT LOAD CENTER FOR TELECOM SMART PANEL. COORDINATE WORK WITH SERVICE PROVIDER FOR EXACT LOCATION AND FINAL CONNECTION.
- CONTRACTOR TO VERIFY POWER CONNECTION TYPE FOR THE HOOD/MICROWAVE PRIOR TO ROUGH IN. PROVIDE ONE DEDICATED 20A, 1P DUPLEX RECEPTACLE LOCATED INSIDE THE CABINET OVER THE RANGE FOR APPLIANCES SUPPLIED WITH CORD & PLUG SET. HOOD/MICROWAVES THAT ARE TO BE HARDWIRED, SHALL BE PROVIDED WITH THE DEDICATED CIRCUIT GOING TO A J-BOX WHICH IS TO BE MOUNTED DIRECTLY BEHIND THE APPLIANCE.
- METER LOCATION PER UTILITY PROVIDER'S APPROVAL (PENDING). REFER TO ONE-LINE DIAGRAM ON SHEET E1.11. PROVIDE NEMA 3R LOCKING CABINET FOR HOUSE PANEL "HP". REFER TO SHEET E1.01 FOR METER & PANEL LOCATION(S) AT EACH BUILDING.
- 15A SWITCHED SPLIT DUPLEX RECEPTACLE. REFER TO LIGHTING PLANS (E2 SERIES SHEETS) FOR SWITCH LOCATION.



BLDG "C"
1 FIRST FLOOR - LIGHTING PLAN
E2.01 SCALE: 1/4" = 1'-0"

GENERAL LIGHTING NOTES:

- ELECTRICAL DRAWINGS ARE DIAGRAMMATICAL AND MAY NOT ACCURATELY REFLECT ACTUAL CONSTRUCTION CONDITIONS. THE ELECTRICAL CONTRACTOR SHALL BE RESPONSIBLE FOR COORDINATING THE INSTALLATION OF ALL ELECTRICAL EQUIPMENT, WITH ALL TRADES PRIOR TO AND DURING CONSTRUCTION.
- ALL DISCREPANCIES SHALL BE BROUGHT TO THE ATTENTION OF THE ARCHITECT IMMEDIATELY UPON DISCOVERY.
- REFER TO SHEET E1.21 FOR LIGHT FIXTURE SCHEDULES.
- THE ELECTRICAL CONTRACTOR SHALL REFER TO THE ARCHITECTURAL AND/OR INTERIORS PLAN SETS FOR DIMENSIONED LOCATIONS, MOUNTING HEIGHTS AND FINISHES OF DEVICES AND FIXTURES.
- REFER TO AVAILABLE ARCHITECTURAL AND/OR INTERIOR DESIGN DOCUMENTS & DRAWINGS FOR ADDITIONAL INFORMATION.
- EXTERIOR LIGHTING TO BE CONSTANT "ON" AND PROVIDED WITH PHOTOCELL (EITHER INTEGRAL OR REMOTE) FOR DUSK-TILL-DAWN OPERATION.
- ALL EXTERIOR BUILDING LIGHTS ON HOUSE POWER SHALL BE CONSIDERED EGRESS LIGHTING. FIXTURES ARE TO BE EQUIPPED WITH BATTERY BACK-UP (EITHER INTEGRAL OR REMOTE).
- REFER TO SHEET E1.14 FOR TYPICAL UNIT LOAD CENTER DIRECTORIES.
- ALL LIGHT SWITCHES SHALL BE ROCKER STYLE, SUCH AS LEVITON DECORA, OR APPROVED EQUAL.
- REFER TO ARCHITECTURAL REFLECTED CEILING PLANS FOR EXACT FIXTURE LOCATIONS (DIMENSIONS). CONSULT INTERIOR DESIGNER FOR MOUNTING HEIGHTS NOT SPECIFIED.
- CEILING HEATERS SHALL BE PROVIDED AND INSTALLED BY THE ELECTRICAL CONTRACTOR. INSTALLATION TO INCLUDE WIRING AND DEVICES FOR REMOTE THERMOSTATS. CONSULT ARCHITECTURAL PLANS FOR EXACT LOCATIONS. REFER TO E1.11 FOR MORE INFORMATION REGARDING THE WALL HEATERS.

KEYED LIGHTING NOTES:

- REFER TO TYPICAL BATHROOM SWITCHING DETAILS ON SHEET E1.21.
- PROVIDE CEILING FAN CONTROL SWITCH(ES) AS DIRECTED BY MANUFACTURER.
- PROVIDE BLOCKING AT CEILING TO SUPPORT 35LB., MINIMUM, FOR CEILING FAN INSTALLATION.
- PROVIDE WIRE CONNECTION FOR THERMOSTAT(S). COORDINATE WITH ARCHITECT FOR EXACT LOCATION PRIOR TO ROUGH IN. REFER TO ARCHITECTURAL INTERIOR ELEVATIONS FOR DIMENSIONED LOCATIONS OF THERMOSTATS. REFER TO SHEET E1.11 FOR MORE INFORMATION REGARDING WALL HEATERS & T-STATS.
- COORDINATE LOCATION OF POWER CONNECTION FOR FIRE ALARM DEVICES WITH THE SYSTEM CONTRACTOR/INSTALLER.
- TO SWITCHED RECEPTACLE. REFER TO POWER PLANS (E3 SERIES SHEETS) FOR OUTLET LOCATION.



IN THE EVENT CONFLICTS ARE DISCOVERED
BETWEEN THE ORIGINAL SIGNED AND SEALED
DOCUMENTS PREPARED BY THE ARCHITECTS
AND/OR THEIR CONSULTANTS AND ANY COPY OF
THE DOCUMENTS TRANSMITTED BY MAIL, FAX,
ELECTRONICALLY OR OTHERWISE, THE ORIGINAL
SIGNED AND SEALED DOCUMENTS SHALL GOVERN.


PROJECT # 2019-179
DATE: 28 AUGUST 2020

REVISIONS

△ PLAN REVIEW 11.03.2020
△ PLAN REVIEW 03.19.2021
△ PLAN REVIEW 05.10.2021
△ OWNER CHANGES 06.20.2021
△ UTILITY COORD. 08.19.2021

MCKINNEY LANE APARTMENTS PHASE II
RUSSELL DRIVE & MCKINNEY LANE
LEBANON, OREGON

C
E2.02




△
BLDG 'C'
1 SECOND FLOOR - LIGHTING PLAN
SCALE: 1/4" = 1'-0"

GENERAL LIGHTING NOTES:

- ELECTRICAL DRAWINGS ARE DIAGRAMMATICAL AND MAY NOT ACCURATELY REFLECT ACTUAL CONSTRUCTION CONDITIONS. THE ELECTRICAL CONTRACTOR SHALL BE RESPONSIBLE FOR COORDINATING THE INSTALLATION OF ALL ELECTRICAL EQUIPMENT, WITH ALL TRADES PRIOR TO AND DURING CONSTRUCTION.
- ALL DISCREPANCIES SHALL BE BROUGHT TO THE ATTENTION OF THE ARCHITECT IMMEDIATELY UPON DISCOVERY.
- REFER TO SHEET E1.21 FOR LIGHT FIXTURE SCHEDULES.
- THE ELECTRICAL CONTRACTOR SHALL REFER TO THE ARCHITECTURAL AND/OR INTERIORS PLAN SETS FOR DIMENSIONED LOCATIONS, MOUNTING HEIGHTS AND FINISHES OF DEVICES AND FIXTURES.
- REFER TO AVAILABLE ARCHITECTURAL AND/OR INTERIOR DESIGN DOCUMENTS & DRAWINGS FOR ADDITIONAL INFORMATION.
- EXTERIOR LIGHTING TO BE CONSTANT "ON" AND PROVIDED WITH PHOTOCELL, EITHER INTEGRAL OR REMOTE) FOR DUSK-TO-DAWN OPERATION.
- ALL EXTERIOR BUILDING LIGHTS ON HOUSE POWER SHALL BE CONSIDERED EGRESS LIGHTING. FIXTURES ARE TO BE EQUIPPED WITH BATTERY BACK-UP (EITHER INTEGRAL OR REMOTE).
- REFER TO SHEET E1.14 FOR TYPICAL UNIT LOAD CENTER DIRECTORIES.
- ALL LIGHT SWITCHES SHALL BE ROCKER STYLE, SUCH AS LEVITON DECORA, OR APPROVED EQUAL.
- REFER TO ARCHITECTURAL REFLECTED CEILING PLANS FOR EXACT FIXTURE LOCATIONS (DIMENSIONS). CONSULT INTERIOR DESIGNER FOR MOUNTING HEIGHTS NOT SPECIFIED.
- CEILING HEATERS SHALL BE PROVIDED AND INSTALLED BY THE ELECTRICAL CONTRACTOR. INSTALLATION TO INCLUDE WIRING AND DEVICES FOR REMOTE THERMOSTATS. CONSULT ARCHITECTURAL PLANS FOR EXACT LOCATIONS. REFER TO E1.11 FOR MORE INFORMATION REGARDING THE WALL HEATERS.

KEYED LIGHTING NOTES:

- REFER TO TYPICAL BATHROOM SWITCHING DETAILS ON SHEET E1.21.
- PROVIDE CEILING FAN CONTROL SWITCH(ES) AS DIRECTED BY MANUFACTURER.
- PROVIDE BLOCKING AT CEILING TO SUPPORT 35LB., MINIMUM, FOR CEILING FAN INSTALLATION.
- PROVIDE WIRE CONNECTION FOR THERMOSTAT(S). COORDINATE WITH ARCHITECT FOR EXACT LOCATION PRIOR TO ROUGH IN. REFER TO ARCHITECTURAL INTERIOR ELEVATIONS FOR DIMENSIONED LOCATIONS OF THERMOSTATS. REFER TO SHEET E1.11 FOR MORE INFORMATION REGARDING WALL HEATERS & T-STATS.
- COORDINATE LOCATION OF POWER CONNECTION FOR FIRE ALARM DEVICES WITH THE SYSTEM CONTRACTOR/INSTALLER.
- TO SWITCHED RECEPTACLE. REFER TO POWER PLANS (E3 SERIES SHEETS) FOR OUTLET LOCATION.



BLDG "C"
1 FIRST FLOOR - POWER PLAN
E301 SCALE: 1/4" = 1'-0"

GENERAL POWER NOTES:

- A. ALL PLANS ARE CONSIDERED DIAGRAMMATICAL, THEREFORE ALL EQUIPMENT SIZES AND DEVICE LOCATIONS ARE APPROXIMATE AND SUBJECT TO FIELD CONDITIONS AND PRODUCT APPROVAL.
- B. NOT USED.
- C. ELECTRICAL CONTRACTOR SHALL PROVIDE INSTALLATION AND FINAL CONNECTION OF THERMOSTATS. CONSULT MECHANICAL CONTRACTOR FOR EXACT REQUIREMENTS PRIOR TO ROUGH IN.
- D. REFER TO INTERIOR DECORATOR AND/OR ARCHITECTURAL DRAWINGS FOR DIMENSIONED LOCATION(S) AND ELEVATIONS OF FIXTURES & DEVICES. OTHER DEVICES SHOWN ON THE ELECTRICAL PLANS AND NOT INDICATED ON THE DECORATOR'S OR ARCHITECT'S DRAWINGS, SHALL BE INSTALLED AT STANDARD MOUNTING HEIGHT AS INDICATED THE SYMBOL LIST.
- E. BUILDING ELECTRICAL EQUIPMENT SHOWN IS APPROXIMATE, BASED ON INDUSTRY STANDARD PRODUCTS. CONTRACTOR SHALL VERIFY ANY SUBMITTED EQUIPMENT WILL FIT WITHIN THE SPACE PROVIDED, PRIOR TO PRODUCT SUBMITTAL REVIEW.
- F. ELECTRICAL CONTRACTOR SHALL COORDINATE WITH THE LOW VOLTAGE ("T" SERIES) PLANS, INCLUDING FIRE ALARM AND SYSTEMS INSTALLER, AND PROVIDE ROUGH IN AS NEEDED.
- G. WALL HEATERS SHALL BE PROVIDED AND INSTALLED BY THE ELECTRICAL CONTRACTOR. INSTALLATION TO INCLUDE WIRING AND DEVICES FOR REMOTE THERMOSTATS. CONSULT ARCHITECTURAL PLANS FOR EXACT LOCATIONS. REFER TO E1.11 FOR MORE INFORMATION REGARDING THE WALL HEATERS.

KEYED POWER NOTES:

- 1. PROVIDE WIRE CONNECTION FOR THERMOSTAT(S). COORDINATE WITH ARCHITECT FOR EXACT LOCATION PRIOR TO ROUGH IN. REFER TO ARCHITECTURAL INTERIOR ELEVATIONS FOR DIMENSIONED LOCATIONS OF THERMOSTATS. REFER TO SHEET E1.11 FOR MORE INFORMATION REGARDING WALL HEATERS & T-STATS.
- 2. PROVIDE ONE 20A, 120V, 1P GFCI DUPLEX RECEPTACLE UNDER KITCHEN SINK FOR DISPOSAL POWER CONNECTION.
- 3. REFER TO DETAIL 1/E1.13 FOR TYPICAL LAUNDRY ALCOVE RECEPTACLE LOCATIONS. COORDINATE INSTALLATION WITH MECHANICAL & PLUMBING CONTRACTOR.
- 4. PROVIDE ONE 15A, RECEPTACLE CIRCUIT FROM TENANT LOAD CENTER FOR TELECOM SMART PANEL. COORDINATE WORK WITH SERVICE PROVIDER FOR EXACT LOCATION AND FINAL CONNECTION.
- 5. CONTRACTOR TO VERIFY POWER CONNECTION TYPE FOR THE HOOD/MICROWAVE PRIOR TO ROUGH IN. PROVIDE ONE DEDICATED 20A, 1P DUPLEX RECEPTACLE LOCATED INSIDE THE CABINET OVER THE RANGE FOR APPLIANCES SUPPLIED WITH CORD & PLUG SET. HOOD/MICROWAVES THAT ARE TO BE HARDWIRED, SHALL BE PROVIDED WITH THE DEDICATED CIRCUIT GOING TO A J-BOX WHICH IS TO BE MOUNTED DIRECTLY BEHIND THE APPLIANCE.
- 6. METER LOCATION PER UTILITY PROVIDER'S APPROVAL (PENDING). REFER TO ONE-LINE DIAGRAM ON SHEET E1.11. PROVIDE NEMA 3R LOCKING CABINET FOR HOUSE PANEL "HP". REFER TO SHEET E1.01 FOR METER & PANEL LOCATION(S) AT EACH BUILDING.
- 7. 15A SWITCHED SPLIT DUPLEX RECEPTACLE. REFER TO LIGHTING PLANS (E2 SERIES SHEETS) FOR SWITCH LOCATION.



IN THE EVENT CONFLICTS ARE DISCOVERED
BETWEEN THE ORIGINAL SIGNED AND SEALED
DOCUMENTS PREPARED BY THE ARCHITECTS
AND/OR THEIR CONSULTANTS AND ANY COPY OF
THE DOCUMENTS TRANSMITTED BY MAIL, FAX,
ELECTRONICALLY OR OTHERWISE, THE ORIGINAL
SIGNED AND SEALED DOCUMENTS SHALL GOVERN.

PROJECT # 2019-179
DATE: 28 AUGUST 2020

REVISIONS


△ PLAN REVIEW 11.03.2020
△ PLAN REVIEW 03.19.2021
△ PLAN REVIEW 05.10.2021
△ OWNER CHANGES 06.20.2021
△ UTILITY COORD. 08.19.2021

McKINNEY LANE APARTMENTS PHASE II

RUSSELL DRIVE & MCKINNEY LANE

LEBANON, OREGON

△ C
E3.02




BLDG "C"
1 SECOND FLOOR - POWER PLAN
E302 SCALE: 1/4" = 1'-0"

GENERAL POWER NOTES:

- A. ALL PLANS ARE CONSIDERED DIAGRAMMATICAL, THEREFORE ALL EQUIPMENT SIZES AND DEVICE LOCATIONS ARE APPROXIMATE AND SUBJECT TO FIELD CONDITIONS AND PRODUCT APPROVAL.
- △ B. NOT USED.
- C. ELECTRICAL CONTRACTOR SHALL PROVIDE INSTALLATION AND FINAL CONNECTION OF THERMOSTATS. CONSULT MECHANICAL CONTRACTOR FOR EXACT REQUIREMENTS PRIOR TO ROUGH IN.
- D. REFER TO INTERIOR DECORATOR AND/OR ARCHITECTURAL DRAWINGS FOR DIMENSIONED LOCATION(S) AND ELEVATIONS OF FIXTURES & DEVICES. OTHER DEVICES SHOWN ON THE ELECTRICAL PLANS AND NOT INDICATED ON THE DECORATOR'S OR ARCHITECT'S DRAWINGS, SHALL BE INSTALLED AT STANDARD MOUNTING HEIGHT AS INDICATED THE SYMBOL LIST.
- E. BUILDING ELECTRICAL EQUIPMENT SHOWN IS APPROXIMATE, BASED ON INDUSTRY STANDARD PRODUCTS. CONTRACTOR SHALL VERIFY ANY SUBMITTED EQUIPMENT WILL FIT WITHIN THE SPACE PROVIDED, PRIOR TO PRODUCT SUBMITTAL REVIEW.
- F. ELECTRICAL CONTRACTOR SHALL COORDINATE WITH THE LOW VOLTAGE ("T" SERIES) PLANS, INCLUDING FIRE ALARM AND SYSTEMS INSTALLER, AND PROVIDE ROUGH IN AS NEEDED.
- △ G. WALL HEATERS SHALL BE PROVIDED AND INSTALLED BY THE ELECTRICAL CONTRACTOR. INSTALLATION TO INCLUDE WIRING AND DEVICES FOR REMOTE THERMOSTATS. CONSULT ARCHITECTURAL PLANS FOR EXACT LOCATIONS. REFER TO E1.11 FOR MORE INFORMATION REGARDING THE WALL HEATERS.

KEYED POWER NOTES:

- △ 1. PROVIDE WIRE CONNECTION FOR THERMOSTAT(S). COORDINATE WITH ARCHITECT FOR EXACT LOCATION PRIOR TO ROUGH IN. REFER TO ARCHITECTURAL INTERIOR ELEVATIONS FOR DIMENSIONED LOCATIONS OF THERMOSTATS. REFER TO SHEET E1.11 FOR MORE INFORMATION REGARDING WALL HEATERS & T-STATS.
2. *PROVIDE ONE 20A, 120V, 1P GFCI DUPLEX RECEPTACLE UNDER KITCHEN SINK FOR DISPOSAL POWER CONNECTION.
3. REFER TO DETAIL 1/E1.13 FOR TYPICAL LAUNDRY ALCOVE RECEPTACLE LOCATIONS. COORDINATE INSTALLATION WITH MECHANICAL & PLUMBING CONTRACTOR.
4. PROVIDE ONE 15A, RECEPTACLE CIRCUIT FROM TENANT LOAD CENTER FOR TELECOM SMART PANEL. COORDINATE WORK WITH SERVICE PROVIDER FOR EXACT LOCATION AND FINAL CONNECTION.
5. CONTRACTOR TO VERIFY POWER CONNECTION TYPE FOR THE HOOD/MICROWAVE PRIOR TO ROUGH IN. PROVIDE ONE DEDICATED 20A, 1P DUPLEX RECEPTACLE LOCATED INSIDE THE CABINET OVER THE RANGE FOR APPLIANCES SUPPLIED WITH CORD & PLUG SET. HOOD/MICROWAVES THAT ARE TO BE HARDWIRED, SHALL BE PROVIDED WITH THE DEDICATED CIRCUIT GOING TO A J-BOX WHICH IS TO BE MOUNTED DIRECTLY BEHIND THE APPLIANCE.
6. METER LOCATION PER UTILITY PROVIDER'S APPROVAL (PENDING). REFER TO ONE-LINE DIAGRAM ON SHEET E1.11. PROVIDE NEMA 3R LOCKING CABINET FOR HOUSE PANEL "HP". REFER TO SHEET E1.01 FOR METER & PANEL LOCATION(S) AT EACH BUILDING.
7. 15A SWITCHED SPLIT DUPLEX RECEPTACLE. REFER TO LIGHTING PLANS (E2 SERIES SHEETS) FOR SWITCH LOCATION.




GENERAL LIGHTING NOTES:

- A. ELECTRICAL DRAWINGS ARE DIAGRAMMATICAL AND MAY NOT ACCURATELY REFLECT ACTUAL CONSTRUCTION CONDITIONS. THE ELECTRICAL CONTRACTOR SHALL BE RESPONSIBLE FOR COORDINATING THE INSTALLATION OF ALL ELECTRICAL EQUIPMENT, WITH ALL TRADES PRIOR TO AND DURING CONSTRUCTION.
- B. ALL DISCREPANCIES SHALL BE BROUGHT TO THE ATTENTION OF THE ARCHITECT IMMEDIATELY UPON DISCOVERY.
- C. REFER TO SHEET E1.21 FOR LIGHT FIXTURE SCHEDULES.
- D. THE ELECTRICAL CONTRACTOR SHALL REFER TO THE ARCHITECTURAL AND/OR INTERIORS PLAN SETS FOR DIMENSIONED LOCATIONS, MOUNTING HEIGHTS AND FINISHES OF DEVICES AND FIXTURES.
- E. REFER TO AVAILABLE ARCHITECTURAL AND/OR INTERIOR DESIGN DOCUMENTS & DRAWINGS FOR ADDITIONAL INFORMATION.
- F. EXTERIOR LIGHTING TO BE CONSTANT "ON" AND PROVIDED WITH PHOTOCELL, EITHER INTEGRAL OR REMOTE) FOR DUSK-TILL-DAWN OPERATION.
- G. ALL EXTERIOR BUILDING LIGHTS ON HOUSE POWER SHALL BE CONSIDERED EGRESS LIGHTING. FIXTURES ARE TO BE EQUIPPED WITH BATTERY BACK-UP (EITHER INTEGRAL OR REMOTE).
- H. REFER TO SHEET E1.14 FOR TYPICAL UNIT LOAD CENTER DIRECTORIES.
- I. ALL LIGHT SWITCHES SHALL BE ROCKER STYLE, SUCH AS LEVITON DECORA, OR APPROVED EQUAL.
- J. REFER TO ARCHITECTURAL REFLECTED CEILING PLANS FOR EXACT FIXTURE LOCATIONS (DIMENSIONS). CONSULT INTERIOR DESIGNER FOR MOUNTING HEIGHTS NOT SPECIFIED.
- K. CEILING HEATERS SHALL BE PROVIDED AND INSTALLED BY THE ELECTRICAL CONTRACTOR. INSTALLATION TO INCLUDE WIRING AND DEVICES FOR REMOTE THERMOSTATS. CONSULT ARCHITECTURAL PLANS FOR EXACT LOCATIONS. REFER TO E1.11 FOR MORE INFORMATION REGARDING THE WALL HEATERS.

KEYED LIGHTING NOTES:

1. REFER TO TYPICAL BATHROOM SWITCHING DETAILS ON SHEET E1.21.
2. PROVIDE CEILING FAN CONTROL SWITCH(ES) AS DIRECTED BY MANUFACTURER.
3. PROVIDE BLOCKING AT CEILING TO SUPPORT 35LB., MINIMUM, FOR CEILING FAN INSTALLATION.
4. PROVIDE WIRE CONNECTION FOR THERMOSTAT(S). COORDINATE WITH ARCHITECT FOR EXACT LOCATION PRIOR TO ROUGH IN. REFER TO ARCHITECTURAL INTERIOR ELEVATIONS FOR DIMENSIONED LOCATIONS OF THERMOSTATS. REFER TO SHEET E1.11 FOR MORE INFORMATION REGARDING WALL HEATERS & T-STATS.
5. COORDINATE LOCATION OF POWER CONNECTION FOR FIRE ALARM DEVICES WITH THE SYSTEM CONTRACTOR/INSTALLER.
6. TO SWITCHED RECEPTACLE. REFER TO POWER PLANS (E3 SERIES SHEETS) FOR OUTLET LOCATION.




GENERAL LIGHTING NOTES:

- A. ELECTRICAL DRAWINGS ARE DIAGRAMMATICAL AND MAY NOT ACCURATELY REFLECT ACTUAL CONSTRUCTION CONDITIONS. THE ELECTRICAL CONTRACTOR SHALL BE RESPONSIBLE FOR COORDINATING THE INSTALLATION OF ALL ELECTRICAL EQUIPMENT, WITH ALL TRADES PRIOR TO AND DURING CONSTRUCTION.
- B. ALL DISCREPANCIES SHALL BE BROUGHT TO THE ATTENTION OF THE ARCHITECT IMMEDIATELY UPON DISCOVERY.
- C. REFER TO SHEET E1.21 FOR LIGHT FIXTURE SCHEDULES.
- D. THE ELECTRICAL CONTRACTOR SHALL REFER TO THE ARCHITECTURAL AND/OR INTERIORS PLAN SETS FOR DIMENSIONED LOCATIONS, MOUNTING HEIGHTS AND FINISHES OF DEVICES AND FIXTURES.
- E. REFER TO AVAILABLE ARCHITECTURAL AND/OR INTERIOR DESIGN DOCUMENTS & DRAWINGS FOR ADDITIONAL INFORMATION.
- F. EXTERIOR LIGHTING TO BE CONSTANT "ON" AND PROVIDED WITH PHOTOCELL, EITHER INTEGRAL OR REMOTE) FOR DUSK-TILL-DAWN OPERATION.
- G. ALL EXTERIOR BUILDING LIGHTS ON HOUSE POWER SHALL BE CONSIDERED EGRESS LIGHTING. FIXTURES ARE TO BE EQUIPPED WITH BATTERY BACK-UP (EITHER INTEGRAL OR REMOTE).
- H. REFER TO SHEET E1.14 FOR TYPICAL UNIT LOAD CENTER DIRECTORIES.
- I. ALL LIGHT SWITCHES SHALL BE ROCKER STYLE, SUCH AS LEVITON DECORA, OR APPROVED EQUAL.
- J. REFER TO ARCHITECTURAL REFLECTED CEILING PLANS FOR EXACT FIXTURE LOCATIONS (DIMENSIONS). CONSULT INTERIOR DESIGNER FOR MOUNTING HEIGHTS NOT SPECIFIED.
- K. CEILING HEATERS SHALL BE PROVIDED AND INSTALLED BY THE ELECTRICAL CONTRACTOR. INSTALLATION TO INCLUDE WIRING AND DEVICES FOR REMOTE THERMOSTATS. CONSULT ARCHITECTURAL PLANS FOR EXACT LOCATIONS. REFER TO E1.11 FOR MORE INFORMATION REGARDING THE WALL HEATERS.

KEYED LIGHTING NOTES:

1. REFER TO TYPICAL BATHROOM SWITCHING DETAILS ON SHEET E1.21.
2. PROVIDE CEILING FAN CONTROL SWITCH(ES) AS DIRECTED BY MANUFACTURER.
3. PROVIDE BLOCKING AT CEILING TO SUPPORT 35LB., MINIMUM, FOR CEILING FAN INSTALLATION.
4. PROVIDE WIRE CONNECTION FOR THERMOSTAT(S). COORDINATE WITH ARCHITECT FOR EXACT LOCATION PRIOR TO ROUGH IN. REFER TO ARCHITECTURAL INTERIOR ELEVATIONS FOR DIMENSIONED LOCATIONS OF THERMOSTATS. REFER TO SHEET E1.11 FOR MORE INFORMATION REGARDING WALL HEATERS & T-STATS.
5. COORDINATE LOCATION OF POWER CONNECTION FOR FIRE ALARM DEVICES WITH THE SYSTEM CONTRACTOR/INSTALLER.
6. TO SWITCHED RECEPTACLE. REFER TO POWER PLANS (E3 SERIES SHEETS) FOR OUTLET LOCATION.




GENERAL POWER NOTES:

- A. ALL PLANS ARE CONSIDERED DIAGRAMMATICAL. THEREFORE ALL EQUIPMENT SIZES AND DEVICE LOCATIONS ARE APPROXIMATE AND SUBJECT TO FIELD CONDITIONS AND PRODUCT APPROVAL.
- B. NOT USED.
- C. ELECTRICAL CONTRACTOR SHALL PROVIDE INSTALLATION AND FINAL CONNECTION OF THERMOSTATS. CONSULT MECHANICAL CONTRACTOR FOR EXACT REQUIREMENTS PRIOR TO ROUGH IN.
- D. REFER TO INTERIOR DECORATOR AND/OR ARCHITECTURAL DRAWINGS FOR DIMENSIONED LOCATION(S) AND ELEVATIONS OF FIXTURES & DEVICES. OTHER DEVICES SHOWN ON THE ELECTRICAL PLANS AND NOT INDICATED ON THE DECORATOR'S OR ARCHITECT'S DRAWINGS, SHALL BE INSTALLED AT STANDARD MOUNTING HEIGHT AS INDICATED THE SYMBOL LIST.
- E. BUILDING ELECTRICAL EQUIPMENT SHOWN IS APPROXIMATE, BASED ON INDUSTRY STANDARD PRODUCTS. CONTRACTOR SHALL VERIFY ANY SUBMITTED EQUIPMENT WILL FIT WITHIN THE SPACE PROVIDED, PRIOR TO PRODUCT SUBMITTAL REVIEW.
- F. ELECTRICAL CONTRACTOR SHALL COORDINATE WITH THE LOW VOLTAGE ("T" SERIES) PLANS, INCLUDING FIRE ALARM AND SYSTEMS INSTALLER, AND PROVIDE ROUGH IN AS NEEDED.
- G. WALL HEATERS SHALL BE PROVIDED AND INSTALLED BY THE ELECTRICAL CONTRACTOR. INSTALLATION TO INCLUDE WIRING AND DEVICES FOR REMOTE THERMOSTATS. CONSULT ARCHITECTURAL PLANS FOR EXACT LOCATIONS. REFER TO E1.11 FOR MORE INFORMATION REGARDING THE WALL HEATERS.

KEYED POWER NOTES:

1. PROVIDE WIRE CONNECTION FOR THERMOSTAT(S). COORDINATE WITH ARCHITECT FOR EXACT LOCATION PRIOR TO ROUGH IN. REFER TO ARCHITECTURAL INTERIOR ELEVATIONS FOR DIMENSIONED LOCATIONS OF THERMOSTATS. REFER TO SHEET E1.11 FOR MORE INFORMATION REGARDING WALL HEATERS & T-STATS.
2. PROVIDE ONE 20A, 120V, 1P GFCI DUPLEX RECEPTACLE UNDER KITCHEN SINK FOR DISPOSAL POWER CONNECTION.
3. REFER TO DETAIL 1/E1.13 FOR TYPICAL LAUNDRY ALCOVE RECEPTACLE LOCATIONS. COORDINATE INSTALLATION WITH MECHANICAL & PLUMBING CONTRACTOR.
4. PROVIDE ONE 15A RECEPTACLE CIRCUIT FROM TENANT LOAD CENTER FOR TELECOM SMART PANEL. COORDINATE WORK WITH SERVICE PROVIDER FOR EXACT LOCATION AND FINAL CONNECTION.
5. CONTRACTOR TO VERIFY POWER CONNECTION TYPE FOR THE HOOD/MICROWAVE PRIOR TO ROUGH IN. PROVIDE ONE DEDICATED 20A, 1P DUPLEX RECEPTACLE LOCATED INSIDE THE CABINET OVER THE RANGE FOR APPLIANCES SUPPLIED WITH CORD & PLUG SET. HOOD/MICROWAVES THAT ARE TO BE HARDWIRED, SHALL BE PROVIDED WITH THE DEDICATED CIRCUIT GOING TO A J-BOX WHICH IS TO BE MOUNTED DIRECTLY BEHIND THE APPLIANCE.
6. METER LOCATION PER UTILITY PROVIDER'S APPROVAL (PENDING). REFER TO ONE-LINE DIAGRAM ON SHEET E1.11. PROVIDE NEMA 3R LOCKING CABINET FOR HOUSE PANEL 'HP'. REFER TO SHEET E1.01 FOR METER & PANEL LOCATION(S) AT EACH BUILDING.
7. 15A SWITCHED SPLIT DUPLEX RECEPTACLE. REFER TO LIGHTING PLANS (E2 SERIES SHEETS) FOR SWITCH LOCATION.




GENERAL POWER NOTES:

- A. ALL PLANS ARE CONSIDERED DIAGRAMMATICAL. THEREFORE ALL EQUIPMENT SIZES AND DEVICE LOCATIONS ARE APPROXIMATE AND SUBJECT TO FIELD CONDITIONS AND PRODUCT APPROVAL.
- B. NOT USED.
- C. ELECTRICAL CONTRACTOR SHALL PROVIDE INSTALLATION AND FINAL CONNECTION OF THERMOSTATS. CONSULT MECHANICAL CONTRACTOR FOR EXACT REQUIREMENTS PRIOR TO ROUGH IN.
- D. REFER TO INTERIOR DECORATOR AND/OR ARCHITECTURAL DRAWINGS FOR DIMENSIONED LOCATION(S) AND ELEVATIONS OF FIXTURES & DEVICES. OTHER DEVICES SHOWN ON THE ELECTRICAL PLANS AND NOT INDICATED ON THE DECORATOR'S OR ARCHITECT'S DRAWINGS, SHALL BE INSTALLED AT STANDARD MOUNTING HEIGHT AS INDICATED THE SYMBOL LIST.
- E. BUILDING ELECTRICAL EQUIPMENT SHOWN IS APPROXIMATE, BASED ON INDUSTRY STANDARD PRODUCTS. CONTRACTOR SHALL VERIFY ANY SUBMITTED EQUIPMENT WILL FIT WITHIN THE SPACE PROVIDED, PRIOR TO PRODUCT SUBMITTAL REVIEW.
- F. ELECTRICAL CONTRACTOR SHALL COORDINATE WITH THE LOW VOLTAGE ('T' SERIES) PLANS, INCLUDING FIRE ALARM AND SYSTEMS INSTALLER, AND PROVIDE ROUGH IN AS NEEDED.
- G. WALL HEATERS SHALL BE PROVIDED AND INSTALLED BY THE ELECTRICAL CONTRACTOR. INSTALLATION TO INCLUDE WIRING AND DEVICES FOR REMOTE THERMOSTATS. CONSULT ARCHITECTURAL PLANS FOR EXACT LOCATIONS. REFER TO E1.11 FOR MORE INFORMATION REGARDING THE WALL HEATERS.

KEYED POWER NOTES:

- 1. PROVIDE WIRE CONNECTION FOR THERMOSTAT(S). COORDINATE WITH ARCHITECT FOR EXACT LOCATION PRIOR TO ROUGH IN. REFER TO ARCHITECTURAL INTERIOR ELEVATIONS FOR DIMENSIONED LOCATIONS OF THERMOSTATS. REFER TO SHEET E1.11 FOR MORE INFORMATION REGARDING WALL HEATERS & T-STATS.
- 2. PROVIDE ONE 20A, 120V, 1P GFCI DUPLEX RECEPTACLE UNDER KITCHEN SINK FOR DISPOSAL POWER CONNECTION.
- 3. REFER TO DETAIL 1/E1.13 FOR TYPICAL LAUNDRY ALCOVE RECEPTACLE LOCATIONS. COORDINATE INSTALLATION WITH MECHANICAL & PLUMBING CONTRACTOR.
- 4. PROVIDE ONE 15A RECEPTACLE CIRCUIT FROM TENANT LOAD CENTER FOR TELECOM SMART PANEL. COORDINATE WORK WITH SERVICE PROVIDER FOR EXACT LOCATION AND FINAL CONNECTION.
- 5. CONTRACTOR TO VERIFY POWER CONNECTION TYPE FOR THE HOOD/MICROWAVE PRIOR TO ROUGH IN. PROVIDE ONE DEDICATED 20A, 1P DUPLEX RECEPTACLE LOCATED INSIDE THE CABINET OVER THE RANGE FOR APPLIANCES SUPPLIED WITH CORD & PLUG SET. HOOD/MICROWAVES THAT ARE TO BE HARDWIRED, SHALL BE PROVIDED WITH THE DEDICATED CIRCUIT GOING TO A J-BOX WHICH IS TO BE MOUNTED DIRECTLY BEHIND THE APPLIANCE.
- 6. METER LOCATION PER UTILITY PROVIDER'S APPROVAL (PENDING). REFER TO ONE-LINE DIAGRAM ON SHEET E1.11. PROVIDE NEMA 3R LOCKING CABINET FOR HOUSE PANEL 'HP'. REFER TO SHEET E1.01 FOR METER & PANEL LOCATION(S) AT EACH BUILDING.
- 7. 15A SWITCHED SPLIT DUPLEX RECEPTACLE. REFER TO LIGHTING PLANS (E2 SERIES SHEETS) FOR SWITCH LOCATION.




GENERAL LIGHTING NOTES:

- ELECTRICAL DRAWINGS ARE DIAGRAMMATICAL AND MAY NOT ACCURATELY REFLECT ACTUAL CONSTRUCTION CONDITIONS. THE ELECTRICAL CONTRACTOR SHALL BE RESPONSIBLE FOR COORDINATING THE INSTALLATION OF ALL ELECTRICAL EQUIPMENT, WITH ALL TRADES PRIOR TO AND DURING CONSTRUCTION.
- ALL DISCREPANCIES SHALL BE BROUGHT TO THE ATTENTION OF THE ARCHITECT IMMEDIATELY UPON DISCOVERY.
- REFER TO SHEET E1.21 FOR LIGHT FIXTURE SCHEDULES.
- THE ELECTRICAL CONTRACTOR SHALL REFER TO THE ARCHITECTURAL AND/OR INTERIORS PLAN SETS FOR DIMENSIONED LOCATIONS, MOUNTING HEIGHTS AND FINISHES OF DEVICES AND FIXTURES.
- REFER TO AVAILABLE ARCHITECTURAL AND/OR INTERIOR DESIGN DOCUMENTS & DRAWINGS FOR ADDITIONAL INFORMATION.
- EXTERIOR LIGHTING TO BE CONSTANT "ON" AND PROVIDED WITH PHOTOCELL, EITHER INTEGRAL OR REMOTE) FOR DUSK-TILL-DAWN OPERATION.
- ALL EXTERIOR BUILDING LIGHTS ON HOUSE POWER SHALL BE CONSIDERED EGRESS LIGHTING. FIXTURES ARE TO BE EQUIPPED WITH BATTERY BACK-UP (EITHER INTEGRAL OR REMOTE).
- REFER TO SHEET E1.14 FOR TYPICAL UNIT LOAD CENTER DIRECTORIES.
- ALL LIGHT SWITCHES SHALL BE ROCKER STYLE, SUCH AS LEVITON DECORA, OR APPROVED EQUAL.
- REFER TO ARCHITECTURAL REFLECTED CEILING PLANS FOR EXACT FIXTURE LOCATIONS (DIMENSIONS). CONSULT INTERIOR DESIGNER FOR MOUNTING HEIGHTS NOT SPECIFIED.
- CEILING HEATERS INSTALLED IN THE APARTMENT UNITS ARE TO BE PROVIDED AND INSTALLED BY THE ELECTRICAL CONTRACTOR BASED ON SIZING AND LOCATION REQUIREMENTS INDICATED IN THE MECHANICAL PLAN SET. INSTALLATION TO INCLUDE WIRING AND DEVICES FOR REMOTE THERMOSTATS. COORDINATE WORK WITH THE MECHANICAL CONTRACTOR PRIOR TO ROUGH IN.

KEYED LIGHTING NOTES:

- REFER TO TYPICAL BATHROOM SWITCHING DETAILS ON SHEET E1.21.
- PROVIDE CEILING FAN CONTROL SWITCH(ES) AS DIRECTED BY MANUFACTURER.
- PROVIDE BLOCKING AT CEILING TO SUPPORT 35LB., MINIMUM, FOR CEILING FAN INSTALLATION.
- PROVIDE WIRE CONNECTION FOR THERMOSTAT(S). COORDINATE WITH ARCHITECT FOR EXACT LOCATION PRIOR TO ROUGH IN. REFER TO ARCHITECTURAL INTERIOR ELEVATIONS FOR DIMENSIONED LOCATIONS OF THERMOSTATS. REFER TO SHEET E1.11 FOR MORE INFORMATION REGARDING WALL HEATERS & T-STATS.
- COORDINATE LOCATION OF POWER CONNECTION FOR FIRE ALARM DEVICES WITH THE SYSTEM CONTRACTOR/INSTALLER.
- TO SWITCHED RECEPTACLE. REFER TO POWER PLANS (E3 SERIES SHEETS) FOR OUTLET LOCATION.



IN THE EVENT CONFLICTS ARE DISCOVERED BETWEEN THE ORIGINAL SIGNED AND SEALED DOCUMENTS PREPARED BY THE ARCHITECTS AND OTHER CONSULTANTS, ANY COPY OF THE DOCUMENTS TRANSMITTED BY MAIL, MAIL, ELECTRONICALLY OR OTHERWISE, THE ORIGINAL SIGNED AND SEALED DOCUMENTS SHALL GOVERN.

PROJECT # 2019-179
DATE: 28 AUGUST 2020

REVISIONS


△ PLAN REVIEW 11.03.2020
△ PLAN REVIEW 03.19.2021
△ PLAN REVIEW 05.10.2021
△ OWNER CHANGES 06.20.2021
△ UTILITY COORD. 08.19.2021

MCKINNEY LANE APARTMENTS PHASE II

RUSSELL DRIVE & MCKINNEY LANE

LEBANON, OREGON

△△
E
E2.02




GENERAL LIGHTING NOTES:

- A. ELECTRICAL DRAWINGS ARE DIAGRAMMATICAL AND MAY NOT ACCURATELY REFLECT ACTUAL CONSTRUCTION CONDITIONS. THE ELECTRICAL CONTRACTOR SHALL BE RESPONSIBLE FOR COORDINATING THE INSTALLATION OF ALL ELECTRICAL EQUIPMENT, WITH ALL TRADES PRIOR TO AND DURING CONSTRUCTION.
- △ B. ALL DISCREPANCIES SHALL BE BROUGHT TO THE ATTENTION OF THE ARCHITECT IMMEDIATELY UPON DISCOVERY.
- C. REFER TO SHEET E1.21 FOR LIGHT FIXTURE SCHEDULES.
- △ D. THE ELECTRICAL CONTRACTOR SHALL REFER TO THE ARCHITECTURAL AND/OR INTERIORS PLAN SETS FOR DIMENSIONED LOCATIONS, MOUNTING HEIGHTS AND FINISHES OF DEVICES AND FIXTURES.
- E. REFER TO AVAILABLE ARCHITECTURAL AND/OR INTERIOR DESIGN DOCUMENTS & DRAWINGS FOR ADDITIONAL INFORMATION.
- F. EXTERIOR LIGHTING TO BE CONSTANT "ON" AND PROVIDED WITH PHOTOCELL, EITHER INTEGRAL OR REMOTE) FOR DUSK-TILL-DAWN OPERATION.
- G. ALL EXTERIOR BUILDING LIGHTS ON HOUSE POWER SHALL BE CONSIDERED EGRESS LIGHTING. FIXTURES ARE TO BE EQUIPPED WITH BATTERY BACK-UP (EITHER INTEGRAL OR REMOTE).
- H. REFER TO SHEET E1.14 FOR TYPICAL UNIT LOAD CENTER DIRECTORIES.
- I. ALL LIGHT SWITCHES SHALL BE ROCKER STYLE, SUCH AS LEVITON DECORA, OR APPROVED EQUAL.
- J. REFER TO ARCHITECTURAL REFLECTED CEILING PLANS FOR EXACT FIXTURE LOCATIONS (DIMENSIONS). CONSULT INTERIOR DESIGNER FOR MOUNTING HEIGHTS NOT SPECIFIED.
- △ G. CEILING HEATERS INSTALLED IN THE APARTMENT UNITS ARE TO BE PROVIDED AND INSTALLED BY THE ELECTRICAL CONTRACTOR BASED ON SIZING AND LOCATION REQUIREMENTS INDICATED IN THE MECHANICAL PLAN SET. INSTALLATION TO INCLUDE WIRING AND DEVICES FOR REMOTE THERMOSTATS. COORDINATE WORK WITH THE MECHANICAL CONTRACTOR PRIOR TO ROUGH IN.

KEYED LIGHTING NOTES:

1. REFER TO TYPICAL BATHROOM SWITCHING DETAILS ON SHEET E1.21.
2. PROVIDE CEILING FAN CONTROL SWITCH(ES) AS DIRECTED BY MANUFACTURER.
3. PROVIDE BLOCKING AT CEILING TO SUPPORT 35LB., MINIMUM, FOR CEILING FAN INSTALLATION.
- △ 4. PROVIDE WIRE CONNECTION FOR THERMOSTAT(S). COORDINATE WITH ARCHITECT FOR EXACT LOCATION PRIOR TO ROUGH IN. REFER TO ARCHITECTURAL INTERIOR ELEVATIONS FOR DIMENSIONED LOCATIONS OF THERMOSTATS. REFER TO SHEET E1.11 FOR MORE INFORMATION REGARDING WALL HEATERS & T-STATS.
5. COORDINATE LOCATION OF POWER CONNECTION FOR FIRE ALARM DEVICES WITH THE SYSTEM CONTRACTOR/INSTALLER.
6. TO SWITCHED RECEPTACLE. REFER TO POWER PLANS (E3 SERIES SHEETS) FOR OUTLET LOCATION.




GENERAL POWER NOTES:

- A. ALL PLANS ARE CONSIDERED DIAGRAMMATICAL. THEREFORE ALL EQUIPMENT SIZES AND DEVICE LOCATIONS ARE APPROXIMATE AND SUBJECT TO FIELD CONDITIONS AND PRODUCT APPROVAL.
- B. NOT USED.
- C. ELECTRICAL CONTRACTOR SHALL PROVIDE INSTALLATION AND FINAL CONNECTION OF THERMOSTATS. CONSULT MECHANICAL CONTRACTOR FOR EXACT REQUIREMENTS PRIOR TO ROUGH IN.
- D. REFER TO INTERIOR DECORATOR AND/OR ARCHITECTURAL DRAWINGS FOR DIMENSIONED LOCATION(S) AND ELEVATIONS OF FIXTURES & DEVICES. OTHER DEVICES SHOWN ON THE ELECTRICAL PLANS AND NOT INDICATED ON THE DECORATOR'S OR ARCHITECT'S DRAWINGS, SHALL BE INSTALLED AT STANDARD MOUNTING HEIGHT AS INDICATED THE SYMBOL LIST.
- E. BUILDING ELECTRICAL EQUIPMENT SHOWN IS APPROXIMATE, BASED ON INDUSTRY STANDARD PRODUCTS. CONTRACTOR SHALL VERIFY ANY SUBMITTED EQUIPMENT WILL FIT WITHIN THE SPACE PROVIDED, PRIOR TO PRODUCT SUBMITTAL REVIEW.
- F. ELECTRICAL CONTRACTOR SHALL COORDINATE WITH THE LOW VOLTAGE ("T" SERIES) PLANS, INCLUDING FIRE ALARM AND SYSTEMS INSTALLER, AND PROVIDE ROUGH IN AS NEEDED.
- G. WALL HEATERS INSTALLED IN THE APARTMENT UNITS ARE TO BE PROVIDED AND INSTALLED BY THE ELECTRICAL CONTRACTOR BASED ON SIZING AND LOCATION REQUIREMENTS INDICATED IN THE MECHANICAL PLAN SET. INSTALLATION TO INCLUDE WIRING AND DEVICES FOR REMOTE THERMOSTATS. COORDINATE WORK WITH THE MECHANICAL CONTRACTOR PRIOR TO ROUGH IN.

KEYED POWER NOTES:

1. PROVIDE WIRE CONNECTION FOR THERMOSTAT(S). COORDINATE WITH ARCHITECT FOR EXACT LOCATION PRIOR TO ROUGH IN. REFER TO ARCHITECTURAL INTERIOR ELEVATIONS FOR DIMENSIONED LOCATIONS OF THERMOSTATS. REFER TO SHEET E1.11 FOR MORE INFORMATION REGARDING WALL HEATERS & T-STATS.
2. PROVIDE ONE 20A, 120V, 1P GFCI DUPLEX RECEPTACLE UNDER KITCHEN SINK FOR DISPOSAL POWER CONNECTION.
3. REFER TO DETAIL 1/E1.13 FOR TYPICAL LAUNDRY ALCOVE RECEPTACLE LOCATIONS. COORDINATE INSTALLATION WITH MECHANICAL & PLUMBING CONTRACTOR.
4. PROVIDE ONE 15A RECEPTACLE CIRCUIT FROM TENANT LOAD CENTER FOR TELECOM SMART PANEL. COORDINATE WORK WITH SERVICE PROVIDER FOR EXACT LOCATION AND FINAL CONNECTION.
5. CONTRACTOR TO VERIFY POWER CONNECTION TYPE FOR THE HOOD/MICROWAVE PRIOR TO ROUGH IN. PROVIDE ONE DEDICATED 20A, 1P DUPLEX RECEPTACLE LOCATED INSIDE THE CABINET OVER THE RANGE FOR APPLIANCES SUPPLIED WITH CORD & PLUG SET. HOOD/MICROWAVES THAT ARE TO BE HARDWIRED, SHALL BE PROVIDED WITH THE DEDICATED CIRCUIT GOING TO A J-BOX WHICH IS TO BE MOUNTED DIRECTLY BEHIND THE APPLIANCE.
6. METER LOCATION PER UTILITY PROVIDER'S APPROVAL (PENDING). REFER TO ONE-LINE DIAGRAM ON SHEET E1.11. PROVIDE NEMA 3R LOCKING CABINET FOR HOUSE PANEL "HP". REFER TO SHEET E1.01 FOR METER & PANEL LOCATION(S) AT EACH BUILDING.
7. 15A SWITCHED SPLIT DUPLEX RECEPTACLE. REFER TO LIGHTING PLANS (E2 SERIES SHEETS) FOR SWITCH LOCATION.




GENERAL POWER NOTES:

- A. ALL PLANS ARE CONSIDERED DIAGRAMMATICAL. THEREFORE ALL EQUIPMENT SIZES AND DEVICE LOCATIONS ARE APPROXIMATE AND SUBJECT TO FIELD CONDITIONS AND PRODUCT APPROVAL.
- △ B. NOT USED.
- C. ELECTRICAL CONTRACTOR SHALL PROVIDE INSTALLATION AND FINAL CONNECTION OF THERMOSTATS. CONSULT MECHANICAL CONTRACTOR FOR EXACT REQUIREMENTS PRIOR TO ROUGH IN.
- D. REFER TO INTERIOR DECORATOR AND/OR ARCHITECTURAL DRAWINGS FOR DIMENSIONED LOCATION(S) AND ELEVATIONS OF FIXTURES & DEVICES. OTHER DEVICES SHOWN ON THE ELECTRICAL PLANS AND NOT INDICATED ON THE DECORATOR'S OR ARCHITECT'S DRAWINGS, SHALL BE INSTALLED AT STANDARD MOUNTING HEIGHT AS INDICATED THE SYMBOL LIST.
- E. BUILDING ELECTRICAL EQUIPMENT SHOWN IS APPROXIMATE, BASED ON INDUSTRY STANDARD PRODUCTS. CONTRACTOR SHALL VERIFY ANY SUBMITTED EQUIPMENT WILL FIT WITHIN THE SPACE PROVIDED, PRIOR TO PRODUCT SUBMITTAL REVIEW.
- F. ELECTRICAL CONTRACTOR SHALL COORDINATE WITH THE LOW VOLTAGE ('T' SERIES) PLANS, INCLUDING FIRE ALARM AND SYSTEMS INSTALLER, AND PROVIDE ROUGH IN AS NEEDED.
- △ G. WALL HEATERS INSTALLED IN THE APARTMENT UNITS ARE TO BE PROVIDED AND INSTALLED BY THE ELECTRICAL CONTRACTOR BASED ON SIZING AND LOCATION REQUIREMENTS INDICATED IN THE MECHANICAL PLAN SET. INSTALLATION TO INCLUDE WIRING AND DEVICES FOR REMOTE THERMOSTATS. COORDINATE WORK WITH THE MECHANICAL CONTRACTOR PRIOR TO ROUGH IN.

KEYED POWER NOTES:

- △ 1. PROVIDE WIRE CONNECTION FOR THERMOSTAT(S). COORDINATE WITH ARCHITECT FOR EXACT LOCATION PRIOR TO ROUGH IN. REFER TO ARCHITECTURAL INTERIOR ELEVATIONS FOR DIMENSIONED LOCATIONS OF THERMOSTATS. REFER TO SHEET E1.11 FOR MORE INFORMATION REGARDING WALL HEATERS & T-STATS.
2. *PROVIDE ONE 20A, 120V, 1P GFCI DUPLEX RECEPTACLE UNDER KITCHEN SINK FOR DISPOSAL POWER CONNECTION.
3. REFER TO DETAIL 1/E1.13 FOR TYPICAL LAUNDRY ALCOVE RECEPTACLE LOCATIONS. COORDINATE INSTALLATION WITH MECHANICAL & PLUMBING CONTRACTOR.
4. PROVIDE ONE 15A RECEPTACLE CIRCUIT FROM TENANT LOAD CENTER FOR TELECOM SMART PANEL. COORDINATE WORK WITH SERVICE PROVIDER FOR EXACT LOCATION AND FINAL CONNECTION.
5. CONTRACTOR TO VERIFY POWER CONNECTION TYPE FOR THE HOOD/MICROWAVE PRIOR TO ROUGH IN. PROVIDE ONE DEDICATED 20A, 1P DUPLEX RECEPTACLE LOCATED INSIDE THE CABINET OVER THE RANGE FOR APPLIANCES SUPPLIED WITH CORD & PLUG SET. HOOD/MICROWAVES THAT ARE TO BE HARDWIRED, SHALL BE PROVIDED WITH THE DEDICATED CIRCUIT GOING TO A J-BOX WHICH IS TO BE MOUNTED DIRECTLY BEHIND THE APPLIANCE.
6. METER LOCATION PER UTILITY PROVIDER'S APPROVAL (PENDING). REFER TO ONE-LINE DIAGRAM ON SHEET E1.11. PROVIDE NEMA 3R LOCKING CABINET FOR HOUSE PANEL 'HP'. REFER TO SHEET E1.01 FOR METER & PANEL LOCATION(S) AT EACH BUILDING.
7. 15A SWITCHED SPLIT DUPLEX RECEPTACLE. REFER TO LIGHTING PLANS (E2 SERIES SHEETS) FOR SWITCH LOCATION.




△
1
E2.01
BLDG 'F'
FIRST FLOOR - LIGHTING PLAN
SCALE: 1/4" = 1'-0"
(ACCESSIBLE)

GENERAL LIGHTING NOTES:

- A. ELECTRICAL DRAWINGS ARE DIAGRAMMATICAL AND MAY NOT ACCURATELY REFLECT ACTUAL CONSTRUCTION CONDITIONS. THE ELECTRICAL CONTRACTOR SHALL BE RESPONSIBLE FOR COORDINATING THE INSTALLATION OF ALL ELECTRICAL EQUIPMENT, WITH ALL TRADES PRIOR TO AND DURING CONSTRUCTION.
- △ B. ALL DISCREPANCIES SHALL BE BROUGHT TO THE ATTENTION OF THE ARCHITECT IMMEDIATELY UPON DISCOVERY.
- C. REFER TO SHEET E1.21 FOR LIGHT FIXTURE SCHEDULES.
- △ D. THE ELECTRICAL CONTRACTOR SHALL REFER TO THE ARCHITECTURAL AND/OR INTERIORS PLAN SETS FOR DIMENSIONED LOCATIONS, MOUNTING HEIGHTS AND FINISHES OF DEVICES AND FIXTURES.
- E. REFER TO AVAILABLE ARCHITECTURAL AND/OR INTERIOR DESIGN DOCUMENTS & DRAWINGS FOR ADDITIONAL INFORMATION.
- F. EXTERIOR LIGHTING TO BE CONSTANT "ON" AND PROVIDED WITH PHOTOCELL, (EITHER INTEGRAL OR REMOTE) FOR DUSK-TILL-DAWN OPERATION.
- G. ALL EXTERIOR BUILDING LIGHTS ON HOUSE POWER SHALL BE CONSIDERED EGRESS LIGHTING. FIXTURES ARE TO BE EQUIPPED WITH BATTERY BACK-UP (EITHER INTEGRAL OR REMOTE).
- H. REFER TO SHEET E1.14 FOR TYPICAL UNIT LOAD CENTER DIRECTORIES.
- I. ALL LIGHT SWITCHES SHALL BE ROCKER STYLE, SUCH AS LEVITON DECORA, OR APPROVED EQUAL.
- J. REFER TO ARCHITECTURAL REFLECTED CEILING PLANS FOR EXACT FIXTURE LOCATIONS (DIMENSIONS). CONSULT INTERIOR DESIGNER FOR MOUNTING HEIGHTS NOT SPECIFIED.
- △ K. REFER TO ARCHITECTURAL PLANS REGARDING "ACCESSIBLE" UNIT LOCATION(S), INTERIOR ELEVATIONS & DETAILS. COORDINATE INSTALLATION OF ALL DEVICES PER THE "AMERICAN DISABILITIES ACT" (ADA). REFER TO SHEET E1.21 FOR STANDARD ADA REACH REQUIREMENTS.
- △ L. CEILING HEATERS INSTALLED IN THE APARTMENT UNITS ARE TO BE PROVIDED AND INSTALLED BY THE ELECTRICAL CONTRACTOR BASED ON SIZING AND LOCATION REQUIREMENTS INDICATED IN THE MECHANICAL PLAN SET. INSTALLATION TO INCLUDE WIRING AND DEVICES FOR REMOTE THERMOSTATS. COORDINATE WORK WITH THE MECHANICAL CONTRACTOR PRIOR TO ROUGH IN.

○ KEYED LIGHTING NOTES:

- 1. REFER TO TYPICAL BATHROOM SWITCHING DETAILS ON SHEET E1.21.
- 2. PROVIDE CEILING FAN CONTROL SWITCH(ES) AS DIRECTED BY MANUFACTURER.
- 3. PROVIDE BLOCKING AT CEILING TO SUPPORT 35LB., MINIMUM, FOR CEILING FAN INSTALLATION.
- △ 4. PROVIDE WIRE CONNECTION FOR THERMOSTAT(S). COORDINATE WITH ARCHITECT FOR EXACT LOCATION PRIOR TO ROUGH IN. REFER TO ARCHITECTURAL INTERIOR ELEVATIONS FOR DIMENSIONED LOCATIONS OF THERMOSTATS. REFER TO SHEET E1.11 FOR MORE INFORMATION REGARDING WALL HEATERS & T-STATS.
- 5. COORDINATE LOCATION OF POWER CONNECTION FOR FIRE ALARM DEVICES WITH THE SYSTEM CONTRACTOR/INSTALLER.
- 6. TO SWITCHED RECEPTACLE. REFER TO POWER PLANS (E3 SERIES SHEETS) FOR OUTLET LOCATION.



IN THE EVENT CONFLICTS ARE DISCOVERED BETWEEN THE ORIGINAL SIGNED AND SEALED DOCUMENTS PREPARED BY THE ARCHITECTS AND/OR THEIR CONSULTANTS AND ANY COPY OF THE DOCUMENTS TRANSMITTED BY MAIL, FAX, ELECTRONICALLY OR OTHERWISE, THE ORIGINAL SIGNED AND SEALED DOCUMENTS SHALL GOVERN.

PROJECT # 2019-179

DATE: 28 AUGUST 2020

REVISIONS


△ PLAN REVIEW 11.03.2020
 △ PLAN REVIEW 03.19.2021
 △ PLAN REVIEW 05.10.2021
 △ OWNER CHANGES 06.20.2021
 △ UTILITY COORD. 08.19.2021

MCKINNEY LANE APARTMENTS PHASE II
 RUSSELL DRIVE & MCKINNEY LANE
 LEBANON, OREGON

△

F

E2.02




△
 1 BLDG 'F'
 E2.02 SECOND FLOOR - LIGHTING PLAN
 SCALE: 1/4" = 1'-0"

GENERAL LIGHTING NOTES:

- ELECTRICAL DRAWINGS ARE DIAGRAMMATICAL AND MAY NOT ACCURATELY REFLECT ACTUAL CONSTRUCTION CONDITIONS. THE ELECTRICAL CONTRACTOR SHALL BE RESPONSIBLE FOR COORDINATING THE INSTALLATION OF ALL ELECTRICAL EQUIPMENT, WITH ALL TRADES PRIOR TO AND DURING CONSTRUCTION.
- ALL DISCREPANCIES SHALL BE BROUGHT TO THE ATTENTION OF THE ARCHITECT IMMEDIATELY UPON DISCOVERY.
- REFER TO SHEET E1.21 FOR LIGHT FIXTURE SCHEDULES.
- THE ELECTRICAL CONTRACTOR SHALL REFER TO THE ARCHITECTURAL AND/OR INTERIORS PLAN SETS FOR DIMENSIONED LOCATIONS, MOUNTING HEIGHTS AND FINISHES OF DEVICES AND FIXTURES.
- REFER TO AVAILABLE ARCHITECTURAL AND/OR INTERIOR DESIGN DOCUMENTS & DRAWINGS FOR ADDITIONAL INFORMATION.
- EXTERIOR LIGHTING TO BE CONSTANT "ON" AND PROVIDED WITH PHOTOCELL, EITHER INTEGRAL OR REMOTE) FOR DUSK-TILL-DAWN OPERATION.
- ALL EXTERIOR BUILDING LIGHTS ON HOUSE POWER SHALL BE CONSIDERED EGRESS LIGHTING. FIXTURES ARE TO BE EQUIPPED WITH BATTERY BACK-UP (EITHER INTEGRAL OR REMOTE).
- REFER TO SHEET E1.14 FOR TYPICAL UNIT LOAD CENTER DIRECTORIES.
- ALL LIGHT SWITCHES SHALL BE ROCKER STYLE, SUCH AS LEVITON DECORA, OR APPROVED EQUAL.
- REFER TO ARCHITECTURAL REFLECTED CEILING PLANS FOR EXACT FIXTURE LOCATIONS (DIMENSIONS). CONSULT INTERIOR DESIGNER FOR MOUNTING HEIGHTS NOT SPECIFIED.
- REFER TO ARCHITECTURAL PLANS REGARDING "ACCESSIBLE" UNIT LOCATION(S), INTERIOR ELEVATIONS & DETAILS. COORDINATE INSTALLATION OF ALL DEVICES PER THE "AMERICAN DISABILITIES ACT" (ADA). REFER TO SHEET E1.21 FOR STANDARD ADA REACH REQUIREMENTS.
- CEILING HEATERS INSTALLED IN THE APARTMENT UNITS ARE TO BE PROVIDED AND INSTALLED BY THE ELECTRICAL CONTRACTOR BASED ON SIZING AND LOCATION REQUIREMENTS INDICATED IN THE MECHANICAL PLAN SET. INSTALLATION TO INCLUDE WIRING AND DEVICES FOR REMOTE THERMOSTATS. COORDINATE WORK WITH THE MECHANICAL CONTRACTOR PRIOR TO ROUGH IN.

KEYED LIGHTING NOTES:

- REFER TO TYPICAL BATHROOM SWITCHING DETAILS ON SHEET E1.21.
- PROVIDE CEILING FAN CONTROL SWITCH(ES) AS DIRECTED BY MANUFACTURER.
- PROVIDE BLOCKING AT CEILING TO SUPPORT 35LB., MINIMUM, FOR CEILING FAN INSTALLATION.
- PROVIDE WIRE CONNECTION FOR THERMOSTAT(S). COORDINATE WITH ARCHITECT FOR EXACT LOCATION PRIOR TO ROUGH IN. REFER TO ARCHITECTURAL INTERIOR ELEVATIONS FOR DIMENSIONED LOCATIONS OF THERMOSTATS. REFER TO SHEET E1.11 FOR MORE INFORMATION REGARDING WALL HEATERS & T-STATS.
- COORDINATE LOCATION OF POWER CONNECTION FOR FIRE ALARM DEVICES WITH THE SYSTEM CONTRACTOR/INSTALLER.
- TO SWITCHED RECEPTACLE. REFER TO POWER PLANS (E3 SERIES SHEETS) FOR OUTLET LOCATION.




IN THE EVENT CONFLICTS ARE DISCOVERED
BETWEEN THE ORIGINAL SIGNED AND SEALED
DOCUMENTS PREPARED BY THE ARCHITECTS
AND OTHER CONSULTANTS, ANY COPY OF
THE DOCUMENTS TRANSMITTED BY MAIL SHALL
ELECTRONICALLY OR OTHERWISE, THE ORIGINAL
SIGNED AND SEALED DOCUMENTS SHALL GOVERN.

PROJECT # 2019-179
DATE: 28 AUGUST 2020

REVISIONS
 △ PLAN REVIEW 11.03.2020
 △ PLAN REVIEW 03.19.2021
 △ PLAN REVIEW 05.10.2021
 △ OWNER CHANGES 06.20.2021
 △ UTILITY COORD. 08.19.2021

MCKINNEY LANE APARTMENTS PHASE II
RUSSELL DRIVE & MCKINNEY LANE
LEBANON, OREGON 97335

△ F
E3.01




△
1
E301
BLDG 'F'
FIRST FLOOR — POWER PLAN
SCALE: 1/4" = 1'-0"
(ACCESSIBLE)

GENERAL POWER NOTES:

- ALL PLANS ARE CONSIDERED DIAGRAMMATICAL. THEREFORE ALL EQUIPMENT SIZES AND DEVICE LOCATIONS ARE APPROXIMATE AND SUBJECT TO FIELD CONDITIONS AND PRODUCT APPROVAL.
- NOT USED.
- ELECTRICAL CONTRACTOR SHALL PROVIDE INSTALLATION AND FINAL CONNECTION OF THERMOSTATS. CONSULT MECHANICAL CONTRACTOR FOR EXACT REQUIREMENTS PRIOR TO ROUGH IN.
- REFER TO INTERIOR DECORATOR AND/OR ARCHITECTURAL DRAWINGS FOR DIMENSIONED LOCATION(S) AND ELEVATIONS OF FIXTURES & DEVICES. OTHER DEVICES SHOWN ON THE ELECTRICAL PLANS AND NOT INDICATED ON THE DECORATOR'S OR ARCHITECT'S DRAWINGS, SHALL BE INSTALLED AT STANDARD MOUNTING HEIGHT AS INDICATED THE SYMBOL LIST.
- BUILDING ELECTRICAL EQUIPMENT SHOWN IS APPROXIMATE, BASED ON INDUSTRY STANDARD PRODUCTS. CONTRACTOR SHALL VERIFY ANY SUBMITTED EQUIPMENT WILL FIT WITHIN THE SPACE PROVIDED, PRIOR TO PRODUCT SUBMITTAL REVIEW.
- ELECTRICAL CONTRACTOR SHALL COORDINATE WITH THE LOW VOLTAGE ('T' SERIES) PLANS, INCLUDING FIRE ALARM AND SYSTEMS INSTALLER, AND PROVIDE ROUGH IN AS NEEDED.
- REFER TO ARCHITECTURAL PLANS REGARDING "ACCESSIBLE" UNIT LOCATION(S), INTERIOR ELEVATIONS & DETAILS. COORDINATE INSTALLATION OF ALL DEVICES PER THE "AMERICAN DISABILITIES ACT" (ADA). REFER TO SHEET E1.21 FOR STANDARD ADA REACH REQUIREMENTS.
- WALL HEATERS INSTALLED IN THE APARTMENT UNITS ARE TO BE PROVIDED AND INSTALLED BY THE ELECTRICAL CONTRACTOR BASED ON SIZING AND LOCATION REQUIREMENTS INDICATED IN THE MECHANICAL PLAN SET. INSTALLATION TO INCLUDE WIRING AND DEVICES FOR REMOTE THERMOSTATS. COORDINATE WORK WITH THE MECHANICAL CONTRACTOR PRIOR TO ROUGH IN.

KEYED POWER NOTES:

- PROVIDE WIRE CONNECTION FOR THERMOSTAT(S). COORDINATE WITH ARCHITECT FOR EXACT LOCATION PRIOR TO ROUGH IN. REFER TO ARCHITECTURAL INTERIOR ELEVATIONS FOR DIMENSIONED LOCATIONS OF THERMOSTATS. REFER TO SHEET E1.11 FOR MORE INFORMATION REGARDING WALL HEATERS & T-STATS.
- PROVIDE ONE 20A, 120V, 1P GFCI DUPLEX RECEPTACLE UNDER KITCHEN SINK FOR DISPOSAL POWER CONNECTION.
- REFER TO DETAIL 1/E1.13 FOR TYPICAL LAUNDRY ALCOVE RECEPTACLE LOCATIONS. COORDINATE INSTALLATION WITH MECHANICAL & PLUMBING CONTRACTOR.
- PROVIDE ONE 15A RECEPTACLE CIRCUIT FROM TENANT LOAD CENTER FOR TELECOM SMART PANEL. COORDINATE WORK WITH SERVICE PROVIDER FOR EXACT LOCATION AND FINAL CONNECTION.
- CONTRACTOR TO VERIFY POWER CONNECTION TYPE FOR THE HOOD/MICROWAVE PRIOR TO ROUGH IN. PROVIDE ONE DEDICATED 20A, 1P DUPLEX RECEPTACLE LOCATED INSIDE THE CABINET OVER THE RANGE FOR APPLIANCES SUPPLIED WITH CORD & PLUG SET. HOOD/MICROWAVES THAT ARE TO BE HARDWIRED, SHALL BE PROVIDED WITH THE DEDICATED CIRCUIT GOING TO A J-BOX WHICH IS TO BE MOUNTED DIRECTLY BEHIND THE APPLIANCE.
- METER LOCATION PER UTILITY PROVIDER'S APPROVAL (PENDING). REFER TO ONE-LINE DIAGRAM ON SHEET E1.11. PROVIDE NEMA 3R LOCKING CABINET FOR HOUSE PANEL 'HP'. REFER TO SHEET E1.01 FOR METER & PANEL LOCATION(S) AT EACH BUILDING.
- 15A SWITCHED SPLIT DUPLEX RECEPTACLE. REFER TO LIGHTING PLANS (E2 SERIES SHEETS) FOR SWITCH LOCATION.




△
1 BLDG 'F'
E302 SECOND FLOOR - POWER PLAN
SCALE: 1/4" = 1'-0"

GENERAL POWER NOTES:

- A. ALL PLANS ARE CONSIDERED DIAGRAMMATICAL. THEREFORE ALL EQUIPMENT SIZES AND DEVICE LOCATIONS ARE APPROXIMATE AND SUBJECT TO FIELD CONDITIONS AND PRODUCT APPROVAL.
- △ B. NOT USED.
- C. ELECTRICAL CONTRACTOR SHALL PROVIDE INSTALLATION AND FINAL CONNECTION OF THERMOSTATS. CONSULT MECHANICAL CONTRACTOR FOR EXACT REQUIREMENTS PRIOR TO ROUGH IN.
- D. REFER TO INTERIOR DECORATOR AND/OR ARCHITECTURAL DRAWINGS FOR DIMENSIONED LOCATION(S) AND ELEVATIONS OF FIXTURES & DEVICES. OTHER DEVICES SHOWN ON THE ELECTRICAL PLANS AND NOT INDICATED ON THE DECORATOR'S OR ARCHITECT'S DRAWINGS, SHALL BE INSTALLED AT STANDARD MOUNTING HEIGHT AS INDICATED THE SYMBOL LIST.
- E. BUILDING ELECTRICAL EQUIPMENT SHOWN IS APPROXIMATE, BASED ON INDUSTRY STANDARD PRODUCTS. CONTRACTOR SHALL VERIFY ANY SUBMITTED EQUIPMENT WILL FIT WITHIN THE SPACE PROVIDED, PRIOR TO PRODUCT SUBMITTAL REVIEW.
- F. ELECTRICAL CONTRACTOR SHALL COORDINATE WITH THE LOW VOLTAGE ("T" SERIES) PLANS, INCLUDING FIRE ALARM AND SYSTEMS INSTALLER, AND PROVIDE ROUGH IN AS NEEDED.
- △ G. REFER TO ARCHITECTURAL PLANS REGARDING "ACCESSIBLE" UNIT LOCATION(S), INTERIOR ELEVATIONS & DETAILS. COORDINATE INSTALLATION OF ALL DEVICES PER THE "AMERICAN DISABILITIES ACT" (ADA). REFER TO SHEET E1.21 FOR STANDARD ADA REACH REQUIREMENTS.
- △ H. WALL HEATERS INSTALLED IN THE APARTMENT UNITS ARE TO BE PROVIDED AND INSTALLED BY THE ELECTRICAL CONTRACTOR BASED ON SIZING AND LOCATION REQUIREMENTS INDICATED IN THE MECHANICAL PLAN SET. INSTALLATION TO INCLUDE WIRING AND DEVICES FOR REMOTE THERMOSTATS. COORDINATE WORK WITH THE MECHANICAL CONTRACTOR PRIOR TO ROUGH IN.

○ KEYED POWER NOTES:

- △ 1. PROVIDE WIRE CONNECTION FOR THERMOSTAT(S). COORDINATE WITH ARCHITECT FOR EXACT LOCATION PRIOR TO ROUGH IN. REFER TO ARCHITECTURAL INTERIOR ELEVATIONS FOR DIMENSIONED LOCATIONS OF THERMOSTATS. REFER TO SHEET E1.11 FOR MORE INFORMATION REGARDING WALL HEATERS & T-STATS.
- 2. PROVIDE ONE 20A, 120V, 1P GFCI DUPLEX RECEPTACLE UNDER KITCHEN SINK FOR DISPOSAL POWER CONNECTION.
- 3. REFER TO DETAIL 1/E1.13 FOR TYPICAL LAUNDRY ALCOVE RECEPTACLE LOCATIONS. COORDINATE INSTALLATION WITH MECHANICAL & PLUMBING CONTRACTOR.
- 4. PROVIDE ONE 15A, RECEPTACLE CIRCUIT FROM TENANT LOAD CENTER FOR TELECOM SMART PANEL. COORDINATE WORK WITH SERVICE PROVIDER FOR EXACT LOCATION AND FINAL CONNECTION.
- 5. CONTRACTOR TO VERIFY POWER CONNECTION TYPE FOR THE HOOD/MICROWAVE PRIOR TO ROUGH IN. PROVIDE ONE DEDICATED 20A, 1P DUPLEX RECEPTACLE LOCATED INSIDE THE CABINET OVER THE RANGE FOR APPLIANCES SUPPLIED WITH CORD & PLUG SET. HOOD/MICROWAVES THAT ARE TO BE HARDWIRED, SHALL BE PROVIDED WITH THE DEDICATED CIRCUIT GOING TO A J-BOX WHICH IS TO BE MOUNTED DIRECTLY BEHIND THE APPLIANCE.
- 6. METER LOCATION PER UTILITY PROVIDER'S APPROVAL (PENDING). REFER TO ONE-LINE DIAGRAM ON SHEET E1.11. PROVIDE NEMA 3R LOCKING CABINET FOR HOUSE PANEL 'HP'. REFER TO SHEET E1.01 FOR METER & PANEL LOCATION(S) AT EACH BUILDING.
- 7. 15A SWITCHED SPLIT DUPLEX RECEPTACLE. REFER TO LIGHTING PLANS (E2 SERIES SHEETS) FOR SWITCH LOCATION.



IN THE EVENT CONFLICTS ARE DISCOVERED BETWEEN THE ORIGINAL SIGNED AND SEALED DOCUMENTS PREPARED BY THE ARCHITECTS AND/OR THEIR CONSULTANTS AND ANY COPY OF THE DOCUMENTS TRANSMITTED BY MAIL, FAX, ELECTRONICALLY OR OTHERWISE, THE ORIGINAL SIGNED AND SEALED DOCUMENTS SHALL GOVERN.

PROJECT # 2019-179
DATE: 28 AUGUST 2020

REVISIONS	
△ PLAN REVIEW	11.03.2020
△ PLAN REVIEW	03.19.2021
△ PLAN REVIEW	05.10.2021
△ OWNER CHANGES	06.20.2021
△ UTILITY COORD.	08.19.2021

MCKINNEY LANE APARTMENTS PHASE II
RUSSELL DRIVE & MCKINNEY LANE
LEBANON, OREGON

E5.01


M Consulting Engineers
2007 S.E. Ash St.
Portland, OR 97214
PH: (503) 234-0548
FAX: (503) 234-0877
WWW.MPEA-ENG.COM
CONTACT: DENISE TAYLOR


GENERAL LIGHTING NOTES:

- A. ELECTRICAL DRAWINGS ARE DIAGRAMMATICAL AND MAY NOT ACCURATELY REFLECT ACTUAL CONSTRUCTION CONDITIONS. THE ELECTRICAL CONTRACTOR SHALL BE RESPONSIBLE FOR COORDINATING THE INSTALLATION OF ALL ELECTRICAL EQUIPMENT, WITH ALL TRADES PRIOR TO AND DURING CONSTRUCTION.
- B. THE ELECTRICAL CONTRACTOR SHALL REFER TO THE ARCHITECTURAL DRAWINGS FOR ALL MOUNTING HEIGHTS AND FINISHES OF DEVICES AND FIXTURES.
- C. REFER TO SHEET E1.21 FOR LIGHT FIXTURE SCHEDULES.
- D. THE CONTRACTOR SHALL CONSULT THE ARCHITECT AND/OR INTERIOR DESIGNER FOR THE EXACT LOCATION OF ALL LIGHT FIXTURES PRIOR TO THE START OF ANY ROUGH IN WORK.
- E. REFER TO AVAILABLE ARCHITECTURAL AND/OR INTERIOR DESIGN DOCUMENTS & DRAWINGS FOR ADDITIONAL INFORMATION.
- F. OCCUPANCY SENSORS SHALL BE FIELD ADJUSTED TO ENSURE COVERAGE AND PROPER CONTROL.
- G. ALL EGRESS FIXTURES SHALL BE WIRED SUCH THAT IN THE EVENT OF A POWER FAILURE, ALL LIGHTS WILL AUTOMATICALLY RETURN TO FULL POWER. REFER TO SWITCHING DETAILS ON SHEET E1.22.
- H. EXTERIOR BUILDING LIGHTS TO BE CONTROLLED VIA INTEGRAL AND/OR REMOTE PHOTOCELL FOR DUSK-TILL-DAWN OPERATION. REFER TO LIGHT FIXTURE SCHEDULE ON SHEET E1.21 FOR ADDITIONAL INFORMATION.
- I. ALL LIGHT FIXTURES DESIGNATED AS NIGHT LIGHTS (NL) SHALL BE CIRCUITED VIA TIME CLOCK TO AUTOMATICALLY TURN ON DURING PERIODS OF LOW ACTIVITY.
- J. COORDINATE WITH LANDSCAPE CONTRACTOR TO PROVIDE POWER FOR BOLLARD LIGHTS TO BE INSTALLED IN THE POOL AREA. POWER SOURCE SHALL BE FROM THE POOL BRANCH PANEL ONCE INSTALLED. CONSULT WITH LANDSCAPE CONTRACTOR REGARDING LOCATION(S) AND ROUTE EMPTY CONDUIT(S) WITH FULL STRING & CAPPED AT BOTH ENDS AS REQUIRED.


KEYED NOTES:

- 1. CONTRACTOR TO PROVIDE BLOCKING ABOVE THE CEILING TO SUPPORT A MINIMUM OF 35LBS. FOR CEILING FANS. FANS ARE TO BE PROVIDED BY OTHERS AND INSTALLED BY ELECTRICAL CONTRACTOR.





1 POOL AREA LIGHTING PLAN
SCALE: 3/16" = 1'-0"



2 POOL HOUSE LIGHTING PLAN
SCALE: 1/4" = 1'-0"

GENERAL LIGHTING NOTES:

- ELECTRICAL DRAWINGS ARE DIAGRAMMATICAL AND MAY NOT ACCURATELY REFLECT ACTUAL CONSTRUCTION CONDITIONS. THE ELECTRICAL CONTRACTOR SHALL BE RESPONSIBLE FOR COORDINATING THE INSTALLATION OF ALL ELECTRICAL EQUIPMENT, WITH ALL TRADES PRIOR TO AND DURING CONSTRUCTION.
- THE ELECTRICAL CONTRACTOR SHALL REFER TO THE ARCHITECTURAL DRAWINGS FOR ALL MOUNTING HEIGHTS AND FINISHES OF DEVICES AND FIXTURES.
- REFER TO SHEET E1.21 FOR LIGHT FIXTURE SCHEDULES.
- THE CONTRACTOR SHALL CONSULT THE ARCHITECT AND/OR INTERIOR DESIGNER FOR THE EXACT LOCATION OF ALL LIGHT FIXTURES PRIOR TO THE START OF ANY ROUGH IN WORK.
- REFER TO AVAILABLE ARCHITECTURAL AND/OR INTERIOR DESIGN DOCUMENTS & DRAWINGS FOR ADDITIONAL INFORMATION.
- OCCUPANCY SENSORS SHALL BE FIELD ADJUSTED TO ENSURE COVERAGE AND PROPER CONTROL.
- ALL EGRESS FIXTURES SHALL BE WIRED SUCH THAT IN THE EVENT OF A POWER FAILURE, ALL LIGHTS WILL AUTOMATICALLY RETURN TO FULL POWER. REFER TO SWITCHING DETAILS ON SHEET E1.22.
- EXTERIOR BUILDING LIGHTS TO BE CONTROLLED VIA INTEGRAL AND/OR REMOTE PHOTOCELL FOR DUSK-TILL-DAWN OPERATION. REFER TO LIGHT FIXTURE SCHEDULE ON SHEET E1.21 FOR ADDITIONAL INFORMATION.
- ALL LIGHT FIXTURES DESIGNATED AS NIGHT LIGHTS (NL) SHALL BE CIRCUITED VIA TIME CLOCK TO AUTOMATICALLY TURN ON DURING PERIODS OF LOW ACTIVITY.
- COORDINATE WITH LANDSCAPE CONTRACTOR TO PROVIDE POWER FOR BOLLARD LIGHTS TO BE INSTALLED IN THE POOL AREA. POWER SOURCE SHALL BE FROM THE POOL BRANCH PANEL ONCE INSTALLED. CONSULT WITH LANDSCAPE CONTRACTOR REGARDING LOCATION(S) AND ROUTE EMPTY CONDUIT(S) WITH PULL STRING & CAPPED AT BOTH ENDS AS REQUIRED.

KEYED NOTES:

- CONTRACTOR TO PROVIDE BLOCKING ABOVE THE CEILING TO SUPPORT A MINIMUM OF 35LBS. FOR CEILING FANS. FANS ARE TO BE PROVIDED BY OTHERS AND INSTALLED BY ELECTRICAL CONTRACTOR.

POOL LIGHTING NOTES:

- LIGHT FIXTURES TO BE CIRCUITED TO THE BRANCH PANEL LOCATED IN THE POOL HOUSE.
- EXTERIOR LIGHTS TO BE CONTROLLED VIA PHOTOCELL OR TIME CLOCK PER OWNER'S PREFERENCE.
- ELECTRICAL CONTRACTOR TO PROVIDE UNDERGROUND CONDUIT WITH PULL STRING PER POOL CONTRACTOR'S REQUIREMENTS, FROM POOL HOUSE BRANCH PANEL FOR POOL LIGHTS.
- CONSULT POOL CONTRACTOR AND POOL PLAN SET FOR ADDITIONAL INFORMATION. VERIFY EXACT ELECTRICAL REQUIREMENTS AND ROUTING, PRIOR TO THE START OF ANY WORK.
- ELECTRICAL CONTRACTOR TO INCLUDE "AS-CONSTRUCTED" INFORMATION ON CLOSE OUT DOCUMENTS AT THE END OF THE PROJECT.

GENERAL POWER NOTES:

- ELECTRICAL DRAWINGS ARE DIAGRAMMATICAL AND MAY NOT ACCURATELY REFLECT ACTUAL CONSTRUCTION CONDITIONS. THE ELECTRICAL CONTRACTOR SHALL BE RESPONSIBLE FOR COORDINATING THE INSTALLATION OF ALL ELECTRICAL EQUIPMENT, WITH ALL TRADES PRIOR TO AND DURING CONSTRUCTION.
- THE ELECTRICAL CONTRACTOR SHALL REFER TO THE ARCHITECTURAL AND/OR INTERIOR DESIGNER DRAWINGS FOR ALL MOUNTING HEIGHTS AND FINISHES OF DEVICES AND FIXTURES.
- REFER TO SHEET E1.11 FOR ELECTRICAL ONE-LINE DIAGRAM.
- THE CONTRACTOR SHALL CONSULT THE ARCHITECT AND/OR INTERIOR DESIGNER FOR THE EXACT LOCATION OF ALL AMENITY EQUIPMENT & APPLIANCES PRIOR TO THE START OF ANY ROUGH IN WORK.
- REFER TO AVAILABLE ARCHITECTURAL AND/OR INTERIOR DESIGN DOCUMENTS & DRAWINGS FOR ADDITIONAL INFORMATION.
- ELECTRICAL CONTRACTOR TO PROVIDE THERMOSTATS NOT SUPPLIED BY MECHANICAL CONTRACTOR. CONSULT MECHANICAL PLANS FOR ADDITIONAL INFORMATION.
- ELECTRICAL CONTRACTOR SHALL PROVIDE INSTALLATION AND FINAL CONNECTION OF THERMOSTATS. CONSULT MECHANICAL CONTRACTOR FOR EXACT REQUIREMENTS PRIOR TO ROUGH IN.
- PROVIDE ROUGH IN, FOR WIFI SYSTEM, FIRE ALARM DEVICES, TELECOM DEVICES, SECURITY AND AUDIO SYSTEMS AS REQUIRED. REFER TO "T" SERIES SHEETS FOR ADDITIONAL INFORMATION.
- WALL HEATERS INSTALLED IN THE CLUBHOUSE & POOL SHED ARE TO BE PROVIDED AND INSTALLED BY THE ELECTRICAL CONTRACTOR AS INDICATED. INSTALLATION TO INCLUDE WIRING AND DEVICES FOR REMOTE THERMOSTATS WHERE REQUIRED. CONSULT ARCHITECT FOR EXACT LOCATION. REFER TO E1.11 FOR MORE INFORMATION.


KEYED NOTES:

- PROVIDE ONE 20A, 120V, 1P CIRCUIT FROM PANEL CH, CKT 38 FOR AUTOMATIC DOOR OPENERS.
- PROVIDE ONE 20A, 120V, 1P CIRCUIT FOR DRINKING FOUNTAIN FROM PANEL CH, CKT 24. CONSULT MECHANICAL AND/OR PLUMBING CONTRACTOR FOR EXACT ELECTRICAL REQUIREMENTS PRIOR TO ROUGH IN.
- PROVIDE RECEPTACLE WITH TYPES A & C USB PORTS, LEVITON TS633-T OR APPROVED EQUAL.
- CONSULT ARCHITECT AND/OR MECHANICAL PLANS FOR ADDITIONAL INFORMATION REGARDING THE FIREPLACE. PROVIDE ELECTRICAL CONNECTION(S) AS NEEDED FROM PANEL CH, CKT 20. PROVIDE 120V TWIST TIMER SWITCH (MAX. 60 MINUTES, "NO HOLD") FOR FIREPLACE IGNITER CONTROLS. INTERCONNECT WITH POWER VENT LOCATED ON ROOF. SEE DETAIL 4/E1.12 FOR EMERGENCY SHUFF-OFF DIAGRAM.
- PROVIDE ONE 20A, 120V, 1P CIRCUIT, ROUTED UNDERGROUND IN ONE 3/4" PVC CONDUIT, FROM POOL HOUSE PANEL FOR FIRE TABLE. CONSULT LANDSCAPE PLANS AND/OR DESIGNER FOR ADDITIONAL INFORMATION. COORDINATE INSTALLATION AND FINAL ELECTRICAL CONNECTIONS.
- PROVIDE ONE 20A, 120V, 1P CIRCUIT FROM PANEL CH, CKT 36 FOR LANDSCAPE EQUIPMENT.
- PROVIDE ONE 20A, 120V, 1P CIRCUIT TO A WEATHER PROOF J-BOX IN THE GRILL CABINET, TIED INTO CIRCUIT CH-15, FOR GRILL LIGHT CONNECTION. COORDINATE LOCATION WITH THE LANDSCAPE DESIGNER PRIOR TO ROUGH IN.
- PROVIDE ONE 120V TWIST TIMER SWITCH (MAX. 60 MINUTES, "NO HOLD") IN WEATHER PROOF BOX AT EACH GAS GRILL FOR IGNITER CONTROLS. CIRCUIT FROM PANEL 'CH2'. SEE DETAIL 4/E1.12 FOR EMERGENCY SHUFF-OFF DIAGRAM.
- PROVIDE EMERGENCY SHUTOFF CONTROLS FOR GAS APPLIANCES LOCATED ON TERRACE. COORDINATE INSTALLATION WITH MECHANICAL CONTRACTOR. CIRCUIT FROM PANEL 'CH2'. SEE DETAIL 4/E1.12 FOR EMERGENCY SHUFF-OFF DIAGRAM. PROVIDE WEATHER PROOF LABEL EACH BUTTON WITH DEVICE IT CONTROLS.
- MOUNT WEATHER PROOF GFCI RECEPTACLE NEAR THE BOTTOM SIDE OF THE PERGOLA FOR OWNER INSTALLED STRING LIGHTS.
- PROVIDE ONE 20A, 120V, 1P CIRCUIT FROM PANEL CH, FOR ACCESS CONTROL. REFER TO THE TELECOM PLANS FOR ADDITIONAL INFORMATION & COORDINATE INSTALLATION.
- PROVIDE ONE 1" PVC CONDUIT WITH PULL STRING ROUTED UNDERGROUND FROM THE CLUBHOUSE TO THE POOL MACHINE HOUSE FOR BRANCH PANEL AND DISCONNECT SWITCH TO BE INSTALLED IN COORDINATION WITH THE POOL CONSTRUCTION. CONSULT POOL CONTRACTOR PRIOR TO THE START OF ANY WORK.
- AS PART OF THE POOL HOUSE CONSTRUCTION, THE ELECTRICAL CONTRACTOR SHALL PROVIDE ONE WEATHER PROOF 100A, 208V, 1P DISCONNECT SWITCH AT THE BUILDING EXTERIOR, WITH CONDUCTORS PULLED FROM THE CLUBHOUSE PANEL VIA THE CONDUIT NOTED IN KEY NOTE #12. THE ELECTRICAL CONTRACTOR SHALL INSTALL A 100A, 208V, 1P BRANCH PANEL INSIDE THE POOL EQUIPMENT BUILDING. REFER TO SHEET E1.11 FOR ADDITIONAL INFORMATION.
- PROVIDE AN EMERGENCY SHUT OFF SWITCH WITH AUDIBLE ALARM FOR THE POOL EQUIPMENT, SUCH AS PENTAIR 9237-04 OR SIMILAR. CONSULT WITH POOL CONTRACTOR TO VERIFY COMPATIBILITY & LOCATION PRIOR TO ROUGH IN.
- PROVIDE A 24-HOUR EMERGENCY TELEPHONE. REFER TO THE "T" SERIES SHEETS FOR ADDITIONAL INFORMATION. CONSULT WITH POOL CONTRACTOR TO VERIFY COMPATIBILITY & LOCATION PRIOR TO ROUGH IN.
- PROVIDE WIRE CONNECTION FOR THERMOSTAT(S). COORDINATE WITH ARCHITECT FOR EXACT LOCATION PRIOR TO ROUGH IN. REFER TO ARCHITECTURAL INTERIOR ELEVATIONS FOR DIMENSIONED LOCATIONS OF THERMOSTATS. REFER TO SHEET E1.11 FOR MORE INFORMATION REGARDING WALL HEATERS & T-STATS.

KITCHEN EQUIPMENT KEY:

FOR ADDITIONAL INFORMATION, REFER TO THE INTERIOR DESIGNER'S PLAN SET.

- UNDER COUNTER REFRIGERATOR, PNL CH, CKT 28
- MICROWAVE OVEN, PNL CH, CKT 30
- UNDER COUNTER REFRIGERATOR, PNL CH, CKT 12
- UNDER COUNTER ICE MAKER, PNL CH, CKT 14
- KEGERATOR, PNL CH, CKT 8
- WARMING DRAWER, PNL CH, CKT 16
- MICROWAVE OVEN, PNL CH, CKT 18
- FIREPLACE INSERT, PNL CH, CKT 20
- FLAT SCREEN DISPLAY, PNL CH, CKT 6
- COFFEE MAKER, PNL CH, CKT 22
- PRINTER, PNL CH, CKT 4



1 CLUBHOUSE POWER PLAN
E5.11 SCALE: 3/16" = 1'-0"



IN THE EVENT CONFLICTS ARE DISCOVERED BETWEEN THE ORIGINAL SIGNED AND SEALED DOCUMENTS PREPARED BY THE ARCHITECTS AND/OR ENGINEERS AND ANY COPIES OF THE DOCUMENTS TRANSMITTED BY MAIL, FAX, ELECTRONICALLY OR OTHERWISE, THE ORIGINAL SIGNED AND SEALED DOCUMENTS SHALL GOVERN.

PROJECT # 2019-179
DATE: 28 AUGUST 2020

REVISIONS

△ PLAN REVIEW	11.03.2020
△ PLAN REVIEW	03.19.2021
△ PLAN REVIEW	05.10.2021
△ OWNER CHANGES	06.20.2021
△ UTILITY COORD.	08.19.2021

MCKINNEY LANE APARTMENTS PHASE II
RUSSELL DRIVE & MCKINNEY LANE
LEBANON, OREGON 97331

GENERAL POWER NOTES:



- ELECTRICAL DRAWINGS ARE DIAGRAMMATICAL AND MAY NOT ACCURATELY REFLECT ACTUAL CONSTRUCTION CONDITIONS. THE ELECTRICAL CONTRACTOR SHALL BE RESPONSIBLE FOR COORDINATING THE INSTALLATION OF ALL ELECTRICAL EQUIPMENT, WITH ALL TRADES PRIOR TO AND DURING CONSTRUCTION.
- THE ELECTRICAL CONTRACTOR SHALL REFER TO THE ARCHITECTURAL AND/OR INTERIOR DESIGNER DRAWINGS FOR ALL MOUNTING HEIGHTS AND FINISHES OF DEVICES AND FIXTURES.
- REFER TO SHEET E1.11 FOR ELECTRICAL ONE-LINE DIAGRAM.
- THE CONTRACTOR SHALL CONSULT THE ARCHITECT AND/OR INTERIOR DESIGNER FOR THE EXACT LOCATION OF ALL AMENITY EQUIPMENT & APPLIANCES PRIOR TO THE START OF ANY ROUGH IN WORK.
- REFER TO AVAILABLE ARCHITECTURAL AND/OR INTERIOR DESIGN DOCUMENTS & DRAWINGS FOR ADDITIONAL INFORMATION.
- ELECTRICAL CONTRACTOR TO PROVIDE THERMOSTATS NOT SUPPLIED BY MECHANICAL CONTRACTOR. CONSULT MECHANICAL PLANS FOR ADDITIONAL INFORMATION.
- ELECTRICAL CONTRACTOR SHALL PROVIDE INSTALLATION AND FINAL CONNECTION OF THERMOSTATS. CONSULT MECHANICAL CONTRACTOR FOR EXACT REQUIREMENTS PRIOR TO ROUGH IN.
- PROVIDE ROUGH IN, FOR WIFI SYSTEM, FIRE ALARM DEVICES, TELECOM DEVICES, SECURITY AND AUDIO SYSTEMS AS REQUIRED. REFER TO "T" SERIES SHEETS FOR ADDITIONAL INFORMATION.
- WALL HEATERS INSTALLED IN THE CLUBHOUSE & POOL SHED ARE TO BE PROVIDED AND INSTALLED BY THE ELECTRICAL CONTRACTOR AS INDICATED. INSTALLATION TO INCLUDE WIRING AND DEVICES FOR REMOTE THERMOSTATS WHERE REQUIRED. CONSULT ARCHITECT FOR EXACT LOCATION. REFER TO E1.11 FOR MORE INFORMATION.


KEYED NOTES:

- PROVIDE ONE 20A, 120V, 1P CIRCUIT FROM PANEL CH, CKT 38 FOR AUTOMATIC DOOR OPENERS.
- PROVIDE ONE 20A, 120V, 1P CIRCUIT FOR DRINKING FOUNTAIN FROM PANEL CH, CKT 24. CONSULT MECHANICAL AND/OR PLUMBING CONTRACTOR FOR EXACT ELECTRICAL REQUIREMENTS PRIOR TO ROUGH IN.
- PROVIDE RECEPTACLE WITH TYPES A & C USB PORTS, LEVITON TS633-T OR APPROVED EQUAL.
- CONSULT ARCHITECT AND/OR MECHANICAL PLANS FOR ADDITIONAL INFORMATION REGARDING THE FIREPLACE. PROVIDE ELECTRICAL CONNECTION(S) AS NEEDED FROM PANEL CH, CKT 20. PROVIDE 120V TWIST TIMER SWITCH (MAX. 60 MINUTES, "NO HOLD") FOR FIREPLACE IGNITER CONTROLS. INTERCONNECT WITH POWER VENT LOCATED ON ROOF. SEE DETAIL 4/E1.12 FOR EMERGENCY SHUFF-OFF DIAGRAM.
- PROVIDE ONE 20A, 120V, 1P CIRCUIT, ROUTED UNDERGROUND IN ONE 3/4" PVC CONDUIT, FROM POOL HOUSE PANEL FOR FIRE TABLE. CONSULT LANDSCAPE PLANS AND/OR DESIGNER FOR ADDITIONAL INFORMATION. COORDINATE INSTALLATION AND FINAL ELECTRICAL CONNECTIONS.
- PROVIDE ONE 20A, 120V, 1P CIRCUIT FROM PANEL CH, CKT 36 FOR LANDSCAPE EQUIPMENT.
- PROVIDE ONE 20A, 120V, 1P CIRCUIT TO A WEATHER PROOF J-BOX IN THE GRILL CABINET, TIED INTO CIRCUIT CH-15, FOR GRILL LIGHT CONNECTION. COORDINATE LOCATION WITH THE LANDSCAPE DESIGNER PRIOR TO ROUGH IN.
- PROVIDE ONE 120V TWIST TIMER SWITCH (MAX. 60 MINUTES, "NO HOLD") IN WEATHER PROOF BOX AT EACH GAS GRILL FOR IGNITER CONTROLS. CIRCUIT FROM PANEL "CH2". SEE DETAIL 4/E1.12 FOR EMERGENCY SHUFF-OFF DIAGRAM.
- PROVIDE EMERGENCY SHUTOFF CONTROLS FOR GAS APPLIANCES LOCATED ON TERRACE. COORDINATE INSTALLATION WITH MECHANICAL CONTRACTOR. CIRCUIT FROM PANEL "CH2". SEE DETAIL 4/E1.12 FOR EMERGENCY SHUFF-OFF DIAGRAM. PROVIDE WEATHER PROOF LABEL EACH BUTTON WITH DEVICE IT CONTROLS.
- MOUNT WEATHER PROOF GFCI RECEPTACLE NEAR THE BOTTOM SIDE OF THE PERGOLA FOR OWNER INSTALLED STRING LIGHTS.
- PROVIDE ONE 20A, 120V, 1P CIRCUIT FROM PANEL CH, FOR ACCESS CONTROL. REFER TO THE TELECOM PLANS FOR ADDITIONAL INFORMATION & COORDINATE INSTALLATION.
- PROVIDE ONE 1" PVC CONDUIT WITH PULL STRING ROUTED UNDERGROUND FROM THE CLUBHOUSE TO THE POOL MACHINE HOUSE FOR BRANCH PANEL AND DISCONNECT SWITCH TO BE INSTALLED IN COORDINATION WITH THE POOL CONSTRUCTION. CONSULT POOL CONTRACTOR PRIOR TO THE START OF ANY WORK.
- AS PART OF THE POOL HOUSE CONSTRUCTION, THE ELECTRICAL CONTRACTOR SHALL PROVIDE ONE WEATHER PROOF 100A, 208V, 1P DISCONNECT SWITCH AT THE BUILDING EXTERIOR, WITH CONDUCTORS PULLED FROM THE CLUBHOUSE PANEL VIA THE CONDUIT NOTED IN KEY NOTE #12. THE ELECTRICAL CONTRACTOR SHALL INSTALL A 100A, 208V, 1P BRANCH PANEL INSIDE THE POOL EQUIPMENT BUILDING. REFER TO SHEET E1.11 FOR ADDITIONAL INFORMATION.
- PROVIDE AN EMERGENCY SHUT OFF SWITCH WITH AUDIBLE ALARM FOR THE POOL EQUIPMENT, SUCH AS PENTAIR 9237-04 OR SIMILAR. CONSULT WITH POOL CONTRACTOR TO VERIFY COMPATIBILITY & LOCATION PRIOR TO ROUGH IN.
- PROVIDE A 24-HOUR EMERGENCY TELEPHONE. REFER TO THE "T" SERIES SHEETS FOR ADDITIONAL INFORMATION. CONSULT WITH POOL CONTRACTOR TO VERIFY COMPATIBILITY & LOCATION PRIOR TO ROUGH IN.
- PROVIDE WIRE CONNECTION FOR THERMOSTAT(S). COORDINATE WITH ARCHITECT FOR EXACT LOCATION PRIOR TO ROUGH IN. REFER TO ARCHITECTURAL INTERIOR ELEVATIONS FOR DIMENSIONED LOCATIONS OF THERMOSTATS. REFER TO SHEET E1.11 FOR MORE INFORMATION REGARDING WALL HEATERS & T-STATS.

POOL POWER NOTES:

- AS PART OF THE POOL & POOL HOUSE CONSTRUCTION, THE ELECTRICAL CONTRACTOR SHALL INSTALL THE ELECTRICAL DISCONNECT SWITCH AND BRANCH PANEL DESCRIBED IN SHEET NOTE #13. CONSULT WITH POOL CONTRACTOR/INSTALLER AND POOL CONSTRUCTION DOCUMENTS PRIOR TO THE START OF ANY WORK TO IDENTIFY THE EXACT ELECTRICAL REQUIREMENTS TO BE PROVIDED BY THE ELECTRICAL CONTRACTOR AND COORDINATE ALL WORK.
- COORDINATE WITH POOL INSTALLER TO PROVIDE & INSTALL ONE 50A, 208V, 1P CIRCUIT FROM BRANCH PANEL LOCATED IN THE POOL HOUSE AND PROVIDE ONE 50A, 220V RECEPTACLE (PER MANUFACTURER'S REQUIREMENTS) FOR PUMP MOTOR.
- COORDINATE WITH POOL INSTALLER TO PROVIDE & INSTALL ONE 20A, 120V, 1P CIRCUIT AND ASSOCIATED DEVICE(S) FROM BRANCH PANEL LOCATED IN THE POOL HOUSE FOR POOL LIGHTS.
- COORDINATE WITH POOL CONTRACTOR TO PROVIDE THE APPROPRIATE ELECTRICAL GROUNDING & BONDING CONDUCTORS FOR THE POOL AREA. GROUNDING SHALL ADHERE TO NEC 680 AND ALL OTHER APPLICABLE CODES.
- PROVIDE ONE DEDICATED 20A, 120V, 1P RECEPTACLE FOR POOL CHEMICAL SYSTEM. COORDINATE LOCATION WITH THE POOL CONTRACTOR.
- COORDINATE WITH POOL CONTRACTOR TO PROVIDE CONDUCTOR WIRE AND FINAL CONNECTION FOR THE POOL HEATER. VERIFY ELECTRICAL REQUIREMENTS.
- PROVIDE (4) GENERAL PURPOSE 15A GFCI RATED RECEPTACLE WITHIN THE POOL HOUSE AND (1) 20A WEATHER PROOF GFCI RECEPTACLE ON THE EXTERIOR AS SHOWN. PROVIDE CIRCUITING FROM THE POOL HOUSE BRANCH PANEL.
- PROVIDE ONE 20A, 120V, 1P DEDICATED OUTLET FOR PUMP. COORDINATE LOCATION WITH THE POOL CONTRACTOR.






1
E6.01
TYPICAL GARAGE ELECTRICAL PLAN
SCALE: 1/4" = 1'-0"

GENERAL POWER NOTES:

- A. ELECTRICAL DRAWINGS ARE DIAGRAMMATICAL AND MAY NOT ACCURATELY REFLECT ACTUAL CONSTRUCTION CONDITIONS. THE ELECTRICAL CONTRACTOR SHALL BE RESPONSIBLE FOR COORDINATING THE INSTALLATION OF ALL ELECTRICAL EQUIPMENT, WITH ALL TRADES PRIOR TO AND DURING CONSTRUCTION.
- B. THE ELECTRICAL CONTRACTOR SHALL REFER TO THE ARCHITECTURAL AND/OR INTERIOR DESIGNER DRAWINGS FOR ALL MOUNTING HEIGHTS AND FINISHES OF DEVICES AND FIXTURES.
- C. REFER TO SHEET E1.11 FOR ELECTRICAL ONE-LINE DIAGRAM.
- D. THE CONTRACTOR SHALL CONSULT THE ARCHITECT AND/OR INTERIOR DESIGNER FOR THE EXACT LOCATION OF ALL AMENITY EQUIPMENT & APPLIANCES PRIOR TO THE START OF ANY ROUGH IN WORK.
- E. REFER TO AVAILABLE ARCHITECTURAL AND/OR INTERIOR DESIGN DOCUMENTS & DRAWINGS FOR ADDITIONAL INFORMATION.
- F. ELECTRICAL CONTRACTOR TO PROVIDE THERMOSTATS NOT SUPPLIED BY MECHANICAL CONTRACTOR. CONSULT MECHANICAL PLANS FOR ADDITIONAL INFORMATION.
- G. ELECTRICAL CONTRACTOR SHALL PROVIDE INSTALLATION AND FINAL CONNECTION OF THERMOSTATS. CONSULT MECHANICAL CONTRACTOR FOR EXACT REQUIREMENTS PRIOR TO ROUGH IN.
- H. ELECTRICAL CONTRACTOR SHALL COORDINATE WITH THE LOW VOLTAGE ("T" SERIES) PLANS, INCLUDING FIRE ALARM AND SYSTEMS INSTALLER, AND PROVIDE ROUGH IN AS NEEDED.
- I. WALL HEATERS INSTALLED IN THE CLUBHOUSE & POOL SHED ARE TO BE PROVIDED AND INSTALLED BY THE ELECTRICAL CONTRACTOR AS INDICATED. INSTALLATION TO INCLUDE WIRING AND DEVICES FOR REMOTE THERMOSTATS WHERE REQUIRED. CONSULT ARCHITECT FOR EXACT LOCATION. REFER TO E1.11 FOR MORE INFORMATION.

KEYED NOTES:

- 1. EXTERIOR GARAGE PANELS ARE TO BE NEMA 3R WITH LOCKING COVER. GARAGES ARE FED FROM THE HOUSE PANEL AT BUILDING 'D'. PROVIDE xxA WEATHER PROOF DISCONNECT AHEAD OF THE PANEL AS SHOWN.



2
E6.01
TYPICAL ADA GARAGE ELECTRICAL PLAN
SCALE: 1/4" = 1'-0"