

LIGHTING FIXTURE LIST					
TYPE	LAMP	MANUFACTURER	CATALOG NUMBER	DESCRIPTION	OPTIONS
'A' 'AE'	(2) F28T8 56W	TEXAS FLUORESCENTS (OR APPROVED OTHER)	C SERIES	TYPE :4' GEN. PURPOSE STRIP MOUNTING :SURFACE HOUSING :STEEL LENS/REFL :NA VOLTAGE :MVOLT BALLAST :ELECTRONIC	TYPE 'AE' SIMILAR TO TYPE 'A' EXCEPT WITH EMERGENCY BATTERY BALLAST RETAIL SPACE
'A1' 'A1E'	(2) F28T8 56W	TEXAS FLUORESCENTS (OR APPROVED OTHER)	209A232-ZW-MV	TYPE :4' WRAPAROUND MOUNTING :SURFACE HOUSING :STEEL LENS/REFL :ACRYLIC VOLTAGE :MVOLT BALLAST :ELECTRONIC	TYPE 'A1E' SIMILAR TO 'A1' EXCEPT WITH EMERGENCY BATTERY BALLAST EQUIP. ROOMS, TRASH ROOM
'A2'	(2) F28T8 56W	TEXAS FLUORESCENTS SUNPARK (OR APPROVED OTHER)	TOA SERIES SP-BH48	TYPE :4' ENCLOSED INDUSTRIAL MOUNTING :SURFACE HOUSING :FIBERGLASS LENS/REFL :ACRYLIC VOLTAGE :MVOLT BALLAST :ELECTRONIC	 ELEVATOR PIT
'B'	LED 3500K 3450 LUMENS 32W	TEXAS FLUORESCENTS (OR APPROVED OTHER)	209 SERIES	TYPE :4' WRAP AROUND MOUNTING :SURFACE HOUSING :STEEL LENS/REFL :ACRYLIC VOLTAGE :MVOLT BALLAST :LED DRIVER	 BIKE STORAGE,EQUIP RM, CORRID.
'B1'	LED 3500K 4300 LUMENS 42W	HE WILLIAMS (OR APPROVED OTHER)	SLF SERIES	TYPE :4' WRAP AROUND MOUNTING :SURFACE HOUSING :STEEL LENS/REFL :ACRYLIC VOLTAGE :120V BALLAST :LED DRIVER	PROVIDE W/FACTORY INSTALLED OCCUPANCY SENSOR FOR LIGHT REDUCTION DURING LOW ACTIVITY PERIODS. STAIRWELLS
'B3'	(2) F28T8 56W	TEXAS FLUORESCENTS (OR APPROVED OTHER)	555 SERIES	TYPE :4' WALL BRACKET MOUNTING :SURFACE (ABOVE DOOR) HOUSING :STEEL LENS/REFL :ACRYLIC VOLTAGE :120V BALLAST :ELECTRONIC	 DATA CLOSETS
'C' 'CC'	LED 3500K 2200 LUMENS 20W	BARTCO (OR APPROVED OTHER)	BSS210-45-35-S SERIES	TYPE :4' LINEAR LED LIGHT MOUNTING :SURFACE HOUSING :ALUMINUM LENS/REFL :ACRYLIC VOLTAGE :MVOLT BALLAST :LED DRIVER	TYPE 'CC' SAME AS TYPE 'C' EXCEPT CABLE HUNG. VARIIFY SUSPENDED FIXTURE MOUNTING HEIGHT WITH INTERIOR DESIGNER/ARCH. LOBBY/CORRIDORS
'C1'	LED (A-19) 3500K 780 LUMENS 13.2W	HALO LIGHTING (OR APPROVED OTHER)	SLD6068 SERIES	TYPE :6" DOWN LIGHT MOUNTING :SURFACE (RECESSED J-BOX) HOUSING :ALUMINUM LENS/REFL :ACRYLIC VOLTAGE :MVOLT BALLAST :LED DRIVER	FINISH PER ARCHITECT. CORRIDORS, LOBBYS, LEASE OFFICE
'C2'	LED 3500K 1640 LUMENS 20W	PRUDENTIAL LIGHTING (OR APPROVED OTHER)	BIO-LED-STD-L035 SERIES	TYPE :4FT LINEAR WALL WASHER MOUNTING :SURFACE HOUSING :ALUMINUM LENS/REFL :ACRYLIC VOLTAGE :MVOLT BALLAST :LED DRIVER	 LOBBY
'C3'	LED 2700K 2186 LUMENS 24 W	CREATIVE SYSTEMS LIGHTING (OR APPROVED OTHER)	EDL-ADJ SERIES	TYPE :3" DIA. ADJUSTABLE DOWN LIGHT MOUNTING :RECESSED HOUSING :STEEL LENS/REFL :N/A VOLTAGE :MVOLT BALLAST :LED DRIVER	CONSULT INTERIOR DECORATOR FOR EXACT MOUNTING ANGLE. FINISH PER INTERIOR DECORATOR. LOBBY
'D'	LED 3000K 1400 LUMENS 20W	LBL LIGHTING (OR APPROVED OTHER)	BA840 (DENTON) SERIES	TYPE :2 FT VANITY LIGHT MOUNTING :SURFACE (+6" ABOVE MIRROR) HOUSING :STEEL LENS/REFL :ACRYLIC VOLTAGE :120V BALLAST :LED DRIVER	FINISH PER ARCHITECT. RESTROOMS
'D1'	LED 300K 5W/FT	JESCO LIGHTING GROUP (OR APPROVED OTHER)	DL-AC-FLEX	TYPE :LED TAPE LIGHT MOUNTING :SURFACE HOUSING : LENS/REFL :CLEAR THERMOPLASTIC JACKET VOLTAGE :120V AC BALLAST :INTEGRAL	REFER TO ARCHITECTURAL DETAILS FOR EXACT LOCATION, LENGTH, & MOUNTING MAIL BOX ALCOVE
'D2' 'D2E' (1)	LED 3500K 950LM/LF 9.75 W/LF	FLUXWERX (OR APPROVED OTHER)	NT2A SERIES	TYPE :LINEAR PERIMENTER LIGHTS MOUNTING :COVE MOUNTED HOUSING :STEEL LENS/REFL :ACRYLIC VOLTAGE :MVOLT BALLAST :LED DRIVER (DIMMING)	FIXTURE NOTED AS TYPE 'D2E' TO BE CIRCUITED VIA EMERGENCY POWER SYSTEM. SEE PLANS FOR ADDIT. INFO. ARCHITECT TO DETERMINE TRIM TYPE CORRIDORS
'D3'	(1) F21T5 24 W	VISA LIGHTING (OR APPROVED OTHER)	SLEIGHT SERIES	TYPE :.35" LINEAR SCONCE MOUNTING :SEMI-RECESSED (WALL) HOUSING :STEEL LENS/REFL :ACRYLIC VOLTAGE :120V BALLAST :ELECTRONIC	ARCHITECT TO DETERMINE MOUNTING HEIGHT. MAIN LOBBY, ELEVATOR LOBBIES
'D4'	LED 2700K 8400LM (TOTAL) 105 W (TOTAL)	LBL LIGHTING	SU833, SU767, SU832	TYPE :3-PENDANT CLUSTER MOUNTING :SURFACE HOUSING :STEEL LENS/REFL :ACRYLIC VOLTAGE :MVOLT BALLAST :LED DRIVER	ARCHITECT TO DETERMINE FINISH, PATTERN AND MOUNTING HEIGHT. MAIN LOBBY
'X1' 'X2' 'X3'	LED (GREEN LETTERS) (1.5W)	LITHONIA DMF LIGHTING (OR APPROVED OTHER)	LE EL N SERIES DLED500EM-G	TYPE :EXIT SIGN MOUNTING :UNIVERSAL HOUSING :DIE-CAST ALUMINUM LENS/REFL :SINGLE FACE VOLTAGE :MVOLT BALLAST :NICKLE CADMIUM BATTERY	TYPE 'X2' SIMILAR TO 'X1' EXCEPT WITH DUAL FACE AND/OR DIRCTIONAL ARROWS TYPE 'X3' TO BE EXTERIOR RATED.

LIGHTING FIXTURE LIST – TYPICAL LIVING UNITS					
TYPE	LAMP	MANUFACTURER	CATALOG NUMBER	DESCRIPTION	OPTIONS
'UA'	LED 1100 LUMEN 3000K (16W)	NEXTWAVE LIGHTING (OR APPROVED OTHER)	RH6/NLED/16/IC/AT SERIES RTLED633WH/D TRIM	TYPE :6" DIA. DOWNLIGHT MOUNTING :RECESSED HOUSING :STEEL LENS/REFL :WHITE BAFFLE TRIM VOLTAGE :120V BALLAST :INTEGRAL	FINISH PER ARCHITECT UNIT KITCHEN
'UB'	(3) 18W GU24 MED. BASE CFL 54W	SUNPARK LIGHTING (OR APPROVED OTHER)	DC018 SERIES	TYPE :18" DIA. CLOSE-TO-CEILING MOUNTING :SURFACE HOUSING :SATIN NICKEL FINISH LENS/REFL :ACRYLIC VOLTAGE :120V BALLAST :ELECTRONIC	 UNIT DINING ROOM
'UC1'	(2) 18W GU24 MED. BASE CFL 36W	SUNPARK LIGHTING (OR APPROVED OTHER)	DC014 SERIES	TYPE :14" DIA. CLOSE-TO-CEILING MOUNTING :SURFACE HOUSING :SATIN NICKEL FINISH LENS/REFL :ACRYLIC VOLTAGE :120V BALLAST :SELF-BALLASTED LAMP	 UNIT BEDROOM
'UC2'	(1) 18W GU24 MED. BASE CFL 18W	SUNPARK LIGHTING (OR APPROVED OTHER)	DC010 SERIES	TYPE :10" DIA. CLOSE-TO-CEILING MOUNTING :SURFACE HOUSING :SATIN NICKEL FINISH LENS/REFL :ACRYLIC VOLTAGE :120V BALLAST :SELF-BALLASTED LAMP	 UNIT HALL
'UD'	(1) 13W GU24 (13 W)	SUNSET LIGHTING (OR APPROVED OTHER)	ADR-F9141-53	TYPE :MINI PENDANT MOUNTING :SURFACE HOUSING :BRUSHED NICKEL FINISH LENS/REFL :OPAL GLASS VOLTAGE :120V BALLAST :SELF-BALLASTED LAMP	 UNIT KITCHEN
'UE'	(1) 13W GU24 (15W)	NUVO LIGHTING (OR APPROVED OTHER)	60-2633	TYPE :6 IN. CLOSE-TO-CEILING MOUNTING :SURFACE HOUSING :SATIN NICKEL FINISH LENS/REFL :ALABASTER GLASS VOLTAGE :120V BALLAST :SELF-BALLASTED LAMP	 UNIT CLOSET
'UF'	(3) 13W GU24 (52W)	SUNPARK LIGHTING (OR APPROVED OTHER)	SP-4476-313-62	TYPE :VANITY LIGHT MOUNTING :SURFACE (+6" ABOVE MIRROR) HOUSING :CHROME FINISH LENS/REFL :OPAL GLASS VOLTAGE :120V BALLAST :SELF-BALLASTED LAMP	 UNIT BATHROOM
'UG1'	(1) 17W LED 3000K (17 W)	PROGRESS LIGHTING (OR APPROVED OTHER)	P5674-31/30K	TYPE :EXTERIOR SCONCE MOUNTING :SURFACE (+7"-0" AFF) HOUSING :ALUMINUM LENS/REFL :NA VOLTAGE :120V BALLAST :INTEGRAL LED DRIVER	FINISH PER ARCHITECT UNIT BALCONY
'UG2'	(1) 17W LED 3000K (17 W)	PROGRESS LIGHTING (OR APPROVED OTHER)	P5774-31/30K	TYPE :EXTERIOR CEILING LIGHT MOUNTING :SURFACE HOUSING :ALUMINUM LENS/REFL :NA VOLTAGE :120V BALLAST :INTEGRAL LED DRIVER	FINISH PER ARCHITECT UNIT BALCONY
'UH'	(1) 250W BR40 250 W	BROAN (OR APPROVED OTHER)	161 SERIES	TYPE :HEAT LAMP MOUNTING :RECESSED HOUSING :STEEL LENS/REFL :NA VOLTAGE :120V BALLAST :NA	 UNIT BATHROOM

LIGHTING FIXTURE LIST – BUILDING EXTERIOR					
TYPE	LAMP	MANUFACTURER	CATALOG NUMBER	DESCRIPTION	OPTIONS
'SA'	LED 3000K 1488LM 31W	BEGA (OR APPROVED OTHER)	6057LED SERIES	TYPE :7.5" DIA. CYLINDER MOUNTING :SURFACE HOUSING :ALUMINUM LENS/REFL :PARTIALLY FROSTED GLASS VOLTAGE :MVOLT BALLAST :LED DRIVER	FINISH PER ARCHITECT UL LISTED WET LOCATION BUILDING EXTERIOR, CANOPY
'SB'	LED (3530 LUMENS) 60 W	LSI LIGHTING	CROSSOVER (XPC) SERIES	TYPE :GARAGE LIGHT MOUNTING :SURFACE HOUSING :ALUMINUM LENS/REFL :TEMPERED GLASS VOLTAGE :120V BALLAST :LED DRIVER	 PARKING GARAGE
'SD'	LED 1124 LUMEN 3000K 44.6 W	BEGA LIGHTING (OR APPROVED OTHER)	2260L SERIES	TYPE :WALL SCONCE MOUNTING :SURFACE (+8"-0" AFF MIN) HOUSING :STEEL LENS/REFL :TEMEPERED MATT GLASS VOLTAGE :120V BALLAST :LED DRIVER	FINISH PER ARCHITECT BUILDING EXTERIOR

GENERAL NOTES:

- A. ALL LIGHT FIXTURES SHALL HAVE ENERGY EFFICIENT LAMPING AND BALLASTS.
- B. LIGHT FIXTURES FOR LIVING UNITS SHALL BE "ENERGY STAR" RATED.
- C. VERIFY ALL FIXTURE FINISHES WITH ARCHITECT PRIOR TO BID.
- D. VERIFY ALL FIXTURE MOUNTING HEIGHTS WITH ARCHITECT PRIOR TO BID.
- E. VERIFY ALL FIXTURE LOCATIONS WITH ARCHITECT PRIOR TO ROUGH IN.
- F. ALL INTERIOR LIGHTING SHALL BE 3500 KELVIN UNLESS OTHERWISE NOTED. THE EXCEPTION TO THIS WILL BE THE LIGHT FIXTURES IN THE APARTMENT UNITS, FIXTURES IN MAINTENANCE AREAS AND TEMPORARY LIGHTING.
- G. ALL PRODUCT SUBSTITUTIONS AND VALUE ENGINEERING SHALL BE SUBMITTED DURING BID PHASE, SHALL MEET DESIGN INTENT AND IS SUBJECT TO OWNER APPROVAL.


KEYED LIGHTING NOTES:

1. CONTRACTOR TO DETERMINE FIXTURE LENGTH BASED ON ARCHITECTURAL REFLECTED CEILING PLANS AND ELECTRICAL LIGHTING PLANS. DESIGN INTENT IS FOR THE FIXTURE TO RUN THE ENTIRE LENGTH OF THE "COVE" TO PROVIDE EVEN LIGHT DISTRIBUTION.

FIXTURE TO BE AIMED SUCH THAT THE LIGHT OUTPUT IS DIRECTED TOWARD THE CENTER OF THE CORRIDOR.

FIXTURE(S) SHALL BE PROVIDED WITH DIMMING CAPABILITY AND TIED INTO CEILING MOUNTED OCCUPANCY SENSORS TO REDUCE THE LIGHT LEVELS BY 50% DURING UNOCCUPIED PERIODS.

M
F
I
A
INC.
Consulting Engineers
2007 S.E. Ash St.
Portland, OR 97214
PHN: (503) 234-0548
FAX: (503) 234-0677
WWW.MFIA-ENG.COM
CONTACT: DENISE TAYLOR



IN THE EVENT CONFLICTS ARE DISCOVERED BETWEEN THE ORIGINAL SIGNED AND SEALED DOCUMENTS PREPARED BY THE ARCHITECTS AND/OR THEIR CONSULTANTS, AND ANY COPY OF THE DOCUMENTS TRANSMITTED BY MAIL, FAX, ELECTRONICALLY OR OTHERWISE, THE ORIGINAL SIGNED AND SEALED DOCUMENTS SHALL GOVERN.

PROJECT # 2014-75
DATE: 10-08-2015

REVISIONS	
Δ	02.05.16 PLAN REVIEW