



1 ROOF LEVEL POWER PLAN  
E3.06 SCALE: 1/8" = 1'-0"

### GENERAL NOTES:

- ELECTRICAL DRAWINGS ARE DIAGRAMMATICAL AND MAY NOT ACCURATELY REFLECT ACTUAL CONSTRUCTION CONDITIONS. THE ELECTRICAL CONTRACTOR SHALL BE RESPONSIBLE FOR COORDINATING THE INSTALLATION OF ALL ELECTRICAL EQUIPMENT, WITH ALL TRADES PRIOR TO AND DURING CONSTRUCTION.
- ELECTRICAL CONTRACTOR SHALL COORDINATE WITH THE MECHANICAL EQUIPMENT INSTALLER FOR THE EXACT POWER REQUIREMENTS AND LOCATION OF ALL MECHANICAL EQUIPMENT PRIOR TO ROUGH IN.
- ELECTRICAL CONTRACTOR TO PROVIDE EMPTY CONDUIT FOR FUTURE CONNECTION OF MECHANICAL EQUIPMENT INSTALLED FOR EACH RETAIL SPACE. CONSULT MECHANICAL DRAWINGS AND COORDINATE WITH THE MECHANICAL INSTALLED FOR THE APPROPRIATE CONDUIT SIZE AND ROUTING PRIOR TO ROUGH IN.
- ELECTRICAL CONTRACTOR TO PROVIDE A MINIMUM OF ONE 20A, 120V, 1P RECEPTACLE CIRCUIT FROM PANEL M2 FOR WEATHER PROOF GFCI RATED RECEPTACLES AS REQUIRED BY CODE.

### KEYED NOTES:

- ROUTE EMPTY 1 1/4" CONDUIT WITH PULL STRING FROM LEASE SPACE FOR TENANT SUPPLIED HVAC EQUIPMENT AND CAP OFF.

REVISIONS	
Δ	02.05.16 PLAN REVIEW