

BUILDING METER CENTER
SEE E1.11 FOR ONE-LINE DIAGRAM.
SEE SHEET E2.01 FOR MORE INFO REGARDING
SERVICE ENTRANCE EQUIPMENT LOCATION.

SECONDARY FEEDER PER UTILITY
PROVIDER'S REQUIREMENTS, ROUTED
OVERHEAD FROM POLE MOUNTED
TRANSFORMER. COORDINATE WITH THE
UTILITY FOR WEATHERHEAD LOCATION.

7604 SE 87TH AVE


SITE AREA: 5,682 SF
GROSS BUILDING AREA: 2,520 SF
BUILDING COVERAGE: 24% SF
FAR: 0.4

GENERAL NOTES:

- ALL WORK SHALL BE PERFORMED IN ACCORDANCE WITH ALL APPLICABLE LOCAL, STATE AND NATIONAL CODES.
- ELECTRICAL PLANS ARE DIAGRAMMATIC AND MAY OR MAY NOT REFLECT ACTUAL FIELD CONDITIONS.
- REFER TO LIGHTING PLANS FOR BUILDING MOUNTED LIGHT FIXTURE LOCATIONS.
- COORDINATE WITH LOCAL UTILITY PROVIDER FOR EXACT SERVICE CONDUIT AND CONDUCTORS REQUIREMENTS.
- CONTRACTOR SHALL REVIEW THE UTILITY PROVIDER'S ELECTRICAL SERVICE REQUIREMENTS PRIOR TO THE START OF ANY WORK.
- ALL UTILITY WORK SHALL BE DONE IN ACCORDANCE WITH THE UTILITY PROVIDER'S ELECTRICAL SERVICE REQUIREMENTS.
- REFER TO SHEET E1.11 FOR ONE-LINE DIAGRAM, LOAD SUMMARY INFORMATION AND TYPICAL FEEDER SCHEDULE.
- CONTRACTOR SHALL REVIEW ALL PROJECT DOCUMENTS AND SPECIFICATIONS IN DETAIL AND REFER TO THE DOCUMENTS THROUGHOUT THE CONSTRUCTION.
- CONTRACTOR SHALL REPORT ANY CONFLICTS OR DISCREPANCIES TO THE ARCHITECT IMMEDIATELY UPON DISCOVERY FOR RESOLUTION.
- ALL EQUIPMENT PRODUCTS SUBMITTALS AND SUBSTITUTIONS SHALL BE SUBMITTED TO THE ARCHITECT FOR REVIEW AND/OR APPROVAL PRIOR TO PURCHASE.

UTILITY REQUIREMENTS


- SECONDARY UTILITY FEEDER FROM THE POLE MOUNTED TRANSFORMER TO THE BUILDING WEATHERHEAD, SHALL BE PER THE UTILITY PROVIDER.
- ELECTRICAL CONTRACTOR SHALL COORDINATE WITH THE UTILITY PROVIDER REGARDING THE SECONDARY SERVICE FEEDERS FROM THE WEATHERHEAD TO THE METER & CT CABINET.
- CONSULT WITH UTILITY REPRESENTATIVE 2 WEEKS BEFORE STARTING MAIN POWER TRENCHING FOR A PRE-CONSTRUCTION CONFERENCE. INCLUDED IN THIS CONFERENCE WILL BE EXCAVATOR, CPU, TELCO, AND CATV.



1
E1.01

ELECTRICAL SITE PLAN

SCALE: 1/4" = 1'-0"



Date:	W/D/Y	Proj No:	###	DNT	RLC	DNT	Acad File:	10115
Drawn By:	DNT	Chkd By:	DNT	RLC	DNT	DNT		
DSGN By:	DNT							

VANDERSLICE 4-PLEX
7604 SE 87th AVE.
PORTLAND, OR
ELECTRICAL SITE PLAN

**M
FI
A
INC.**

Consulting Engineers
2007 S.E. Ash St.
Portland, OR 97214
PHONE: (503) 234-0540
FAX: (503) 234-0577
WWW.MFI-ENG.COM

SHEET
E1.01