



COLUMBIA HYDRONICS COMPANY

"Circulating Satisfaction in the Northwest"

11800 N.E. 60th Way • P.O. Box 821050 • Vancouver, WA 98682
PH: (360) 883-2600 FAX: (360) 883-2607 www.columbiahydronics.com

Pressure Booster Worksheet

Job Name: West Wind Location: Portland
Engineer: MFIA
Contact: _____ Sales Engineer: _____
Phone: _____ Phone: _____

Calculated Design Load: 140 GPM
Utility Supply Water Pressure: 68 PSI

Supply Pressure Calculations

Water Meter Loss:	<u>7</u>	PSI
Backflow Preventer Loss:	<u>8</u>	PSI
Friction Loss (Main to Booster):	<u>6</u>	PSI
Static Loss (Main to Booster):		PSI
Static Gain (Main to Booster):		PSI
Total Supply Pressure Available:	<u>47</u>	PSI
or, manual enter Total Available Pressure here:		PSI

Discharge Pressure Calculations

Static Lift (in feet): <i>(top fixture elevation - booster inlet elevation)</i>	<u>82</u>	Feet
Friction Loss: <i>(highest loss circuit in building supply)</i>	<u>15</u>	PSI
PSI required at highest point: <i>(check fixture requirements; normally 30 PSI)</i>	<u>30</u>	PSI
Drawdown differential allowance: <i>(required for 'No-Flow Shutdown' ~ 10 PSI)</i>	<u>10</u>	PSI
Internal Package Loss: <i>(usually figure 4 - 6 PSI for internal valves)</i>	<u>5</u>	PSI
Total Discharge Pressure Required:	<u>96</u>	PSI

Package Pressure Boost Required: 49 PSI